



The University of Maryland, College Park

Americans With Disabilities Act

Transition Plan Update

Prepared by
Department of Planning and Construction
University of Maryland

December 2019

ACKNOWLEDGMENTS

The following people assisted or provided input to the development of this document:

Department of Planning and Construction

Mr. Bill Olen
Mr. Arshad Mughal
Dr. Leonard Azonobi

Office of Diversity and Inclusion

Dr. Georgina Dodge

Accessibility and Disability Service

Dr. Jo Ann Hutchinson

President's Commission on Disability Issues

Dr. Ana Palla-Kane
Dr. Paul J. Jaeger

Facilities Advisory Committee

Ms. Dona-Leigh Morgan

Office of General Counsel

Mr. Devin J. Doolan, Jr.

Residential Facilities

Mr. Gregg Feige

Prepared by

Dr. Leonard M. Azonobi
Capital Budget Planner, Planning & Construction

December 2019

University of Maryland, College Park

Americans With Disabilities Act Transition Plan Update

TABLE OF CONTENTS

EXECUTIVE SUMMARY

I	INTRODUCTION	1
II	PROCESS FOR ADA TRANSITION PLAN UPDATE	3
III	UPDATED INFORMATION ON OFFICIAL RESPONSIBLE	9

APPENDICIES

- A. LIST OF BUILDINGS SURVEYED BY THE DEPARTMENT OF DESIGN AND CONSTRUCTION.
- B. LIST OF BUILDINGS SCHEDULED FOR MAJOR RENOVATION OR DEMOLITION.
- C. LIST OF ENHANCEMENTS TO PROGRAMMATIC ACCESSIBILITY.

AMERICANS WITH DISABILITIES ACT TRANSITION PLAN UPDATE

EXECUTIVE SUMMARY

The University of Maryland, College Park is the Flagship Institution of the University System of Maryland. The main campus has about 1,340 acres, with 20 miles of roads and 66 miles of sidewalks. There are 252 buildings which provide 14.6M GSF of space. The average age of facilities is 47 years. Many of the buildings in the Campus Core of campus were built in the 1930's and 1940's. The oldest building is Rossborough Inn, which was built in 1798. Most campus space was originally built before the advent of design requirements for accessibility.

Title II, Section 35.150 of the Americans with Disabilities Act (ADA) required institutions to prepare a transition plan that identified structural barriers to program access and provide a plan to eliminate them. The university prepared its ADA Transition Plan in July 2000 and updated it in December 2010, 2013 and 2016. The Plans stated that over the years the university has corrected many physical obstacles in campus facilities and all programs have been made accessible to persons with disabilities, but there are many physical enhancements which should be undertaken to continue to enhance program access beyond the minimum requirements of the law. The last updated Plan in 2016 included a total of nearly \$43.2 million (in 2016 dollars) list of recommended enhancements.

The Maryland Department of Disabilities (MDOD) requires institutions to provide an updated ADA Transition Plan every three years. This update is in response to that requirement.

Since the ADA Transition Plan was updated in 2016, the university has completed \$1.74M of the physical enhancements. The list is broken down as follows:

	State-Supported Facilities	Auxiliary Facilities	Total
Site Upgrades¹	\$0.01 M	\$0.004 M ¹	\$0.01 M
Restroom Upgrades	\$1.27 M	\$0.00 M	\$1.27 M
Elevator Projects	\$0.17 M	\$0.00 M	\$0.17 M
Other Upgrades	\$0.29 M	\$0.00 M	\$0.29 M
Total	\$1.74 M	\$0.004 M	\$1.74 M

¹Site Upgrades in Auxiliary Facilities accounted for only \$3,800 since 2016.

The 2020 updated list of physical enhancements totals \$56.6 M (in 2019 dollars), broken down as follows:

	State-Supported Facilities	Auxiliary Facilities	Total
Site Upgrades	\$0.8 M	\$2.0 M	\$2.8 M
Restroom Upgrades	\$24.2 M	\$5.5 M	\$29.7 M
Elevator Projects	\$18.0 M	\$1.5 M	\$19.5 M
Other Upgrades	\$3.7 M	\$0.9 M	\$4.5 M
Total	\$46.7 M	\$9.9 M	\$56.6 M

Individual accessibility enhancement projects for State-supported facilities will continue to be funded from the Access Maryland (State funded) and Access UMD (university funded) Programs. State or university funded renovations of State-supported facilities will continue to include accessibility enhancements. Auxiliary units fund and implement enhancement of their facilities with funds from fee revenues. Auxiliary units will continue to fund individual accessibility enhancement projects and include accessibility enhancements in their renovation projects as funding availability allows.

The priorities for the enhancements are similar to what was included in the 2016 ADA Transition Plan Update and are described below. These priorities will be used as a guide in the development of annual programs/funding requests for accessibility improvements as well as in the development of scopes of planned renovation projects. Deviations from these priorities are expected to occur due to funding availability and other specific circumstances as the annual programs/funding requests and scopes of renovation projects are developed.

A. Priorities by type of enhancement:

1. Access from public sidewalks, parking, or public transportation.
2. Access to areas of a place of public accommodation where goods and services are available to the public.
3. Access to toilet facilities.
4. Access by other means to provide access to goods, services, facilities, privileges, advantages, or accommodations.

B. Priorities by type of building for the State-supported facilities:

1. Academic facilities
2. Library facilities
3. Administrative facilities
4. Academic support facilities (maintenance facilities, storage facilities, public safety facilities, and Maryland Fire and Rescue Institute facilities)

The ADA Transition Plan Update provides current information on the official responsible for ADA compliance. Dr. Jo Ann Hutchinson, Director of Accessibility and Disability Service, is currently the ADA Compliance Officer. This position monitors the institution's efforts for compliance with ADA/Section 504, and represents the institution's interests with federal and state agencies. The ADA Transition Plan Update also provides current information on the university's robust organizational structure to monitor and support the institutions' efforts for ADA compliance and/or provide services for people with disabilities.

AMERICANS WITH DISABILITIES ACT TRANSITION PLAN UPDATE

I. INTRODUCTION

The University of Maryland, College Park (UMD) is the Flagship Institution of the University System of Maryland. The main campus has about 1,340 acres, with 20 miles of roads and 66 miles of sidewalks. There are 252 buildings which provide 14.6M GSF of space. The average age of facilities is 47 years. Many of the buildings in the Campus Core of campus were built in the 1930's and 1940's. The oldest building is Rossborough Inn, which was built in 1798. Most campus space was originally built before the advent of design requirements for accessibility.

Title II, Section 35.150 of the Americans with Disabilities Act (ADA) required institutions to prepare a transition plan that identified structural barriers to program access and provide a plan to eliminate them. The ADA required public entities such as the university to operate each service, program or activity so that the service, program or activity, when viewed in its entirety, is readily accessible to and useable by individuals with disabilities. This general non-discrimination principle is referred to as programmatic accessibility. As long as the university meets this standard, the university need not make each of its existing facilities accessible and useable by individuals with disabilities.

The university prepared its ADA Transition Plan in July 2000 and updated it in December 2010, 2013 and 2016. The updated Plans stated that over the past several years the university has corrected many physical obstacles in existing campus facilities, new facilities have been designed using current accessibility design guidelines, and the university continues to make accommodations for persons with disabilities as needed, and, over the course of time since the ADA went into effect, all programs of the university have been made accessible to individuals with disabilities. Further, the Plans stated that even though the university's programs are accessible, there are many physical enhancements which should be undertaken in order to accomplish our institutional commitment to meeting more than the minimum requirements of the law. The last updated Plan in 2016 included a total of nearly \$43.2 million (in 2016 dollars) list of recommended enhancements that would be addressed as funding availability allowed. The current ADA Transition Plan Update also reached similar conclusions. The updated Plan identifies a total of nearly \$56.6 million (in 2019 dollars) in recommended enhancements. This total excludes projects funded and/or completed since the last update in 2016. The list of physical enhancement projects funded and/or completed since the 2016 update totals \$1.74 million.

The Maryland Department of Disabilities (MDOD) requires institutions to provide an updated ADA Transition Plan every three years, and the university's updated Plan is due on January 1, 2020. The updated Plan will remain on file for three years, after which it should be updated. The updated Plan is required for eligibility to request funds for Fiscal Years 2022, 2023 and 2024. This document has been prepared in response to this requirement.

The 2016 ADA Transition Plan Update addressed the four Transition Plan requirements as follows:

- 1. Identify physical obstacles in the public entity's facilities that limit the accessibility of its programs or activities to individuals with disabilities.**

The Plan noted that the university's programs are accessible, but identified nearly \$43.2 million (in 2016 dollars) in recommended enhancements that would be addressed as funding allows.

- 2. Describe in detail the methods that will be used to make the facilities accessible.**

Since there is no list of physical obstacles to programmatic accessibility, the Plan did not include proposed methods for their removal.

- 3. Specify the schedule for taking the steps necessary to achieve compliance with this section and, if the time period of the transition plan is longer than one year, identify steps that will be taken during each year of the transition period.**

Since the university's programs are accessible to persons with disabilities, the Plan did not include a schedule for achieving programmatic accessibility.

- 4. Indicate the official responsible for implementation of the plan.**

The Plan included this information.

The university's programs continue to be accessible to persons with disabilities, although there continue to be physical enhancements that can be undertaken to improve access. Since the 2016 ADA Transition Plan Update, the university has undertaken some of the proposed physical enhancements and new physical enhancements have been identified. Therefore, this document will update item 1.

II PROCESS FOR ADA TRANSITION PLAN UPDATE

A Working Group was convened to develop a process to update the list of physical enhancements. The Working Group consisted of the ADA Compliance Officer, the Chair of the President's Commission on Disability Issues, the Director of Accessibility and Disability Service, a member of the Facilities Advisory Committee, a representative from the Office of the General Counsel and staff from the Department of Planning and Construction.

The Working Group first reviewed the method used to develop the list of enhancements in the 2016 ADA Transition Plan Update. Potential enhancements were not included in the Transition Plan if they were deemed to fit the following criteria:

1. The enhancement would result in an undue financial burden to the institution.
2. The enhancement would threaten or destroy the historic significance of a historic property (e.g., install an exterior elevator on Rossborough Inn or Morrill Hall).
3. The enhancement would correct a minor deviation from the 2010 Standards for Accessible Design that is not a barrier to most people with disabilities (e.g, toilet stall sizes are somewhat smaller than 2010 Standards).

Individuals preparing the 2020 Transition Plan Update made judgment calls based on these criteria and based on our assessment of the needs of people with disabilities on campus at this time. They also made decisions based on the specific requests for accessibility enhancements the campus has received since the 2016 ADA Transition Plan Update. Over the last decade, more individuals with disabilities are on campus and are functioning more independently. For example, some of these individuals with limited upper body movement and strength are using the larger motorized wheelchairs to travel on campus. Based on specific requests from such individuals as we prepare our annual Access MD and Access UMD Programs, what was previously considered a minor deviation from prior ADA design guidelines is now a challenge for them. Since the 2016 Plan, UMD has received requests for modification of interior doors and doorways to classrooms, class labs and seminar rooms, as well as requests to replace inaccessible water fountains, restrooms, elevators and site upgrades.

The Department of Planning and Construction (P&C) prepared the building survey and asked members of the Facilities Advisory Committee (FAC) and the key occupant who deals with facilities issues to take the lead in providing survey feedback for their respective building(s). All buildings on campus were included in the survey with the exception of buildings scheduled for major renovation or demolition. Appendix A is the list of buildings surveyed, categorized by buildings built or renovated before ADA and built or renovated after ADA. Appendix B is the list of buildings scheduled for major renovation or demolition. In buildings that are assigned to more than one college, each college solicited feedback from key faculty, staff and students, as appropriate. FAC members and the key occupant who deals with facilities issues also reviewed the 2016 updated list of enhancements to confirm which items on the list have been implemented so they could be reflected on the updated list as completed projects, noting date of completion and actual cost as required by MDOD. This list covered restrooms, elevators, site upgrades such

as curb cuts and ramps, and other upgrades including signage, visual alarms, accessible seats, etc. The Department of Residential Facilities surveyed the residence halls to confirm which items on the 2016 list have been implemented.

The updated list of enhancements was developed as follows:

1. ***Retained all items from the list of enhancement prepared in 2010, 2013 and 2016, noting completed projects, dates of completion, and actual cost.*** The updated items are included in the 2020 list.
2. ***Added items not on the 2016 list that we identified via our annual Access UMD or Access MD programs, noting completed projects, dates of completion, and actual or projected cost where applicable.***
3. ***Added items developed as a result of a recent campus-wide survey completed by building occupants.*** All Facilities Advisory Committee members were sent a written survey in June 2019 to distribute to key building occupants, asking if they had any suggestions for physical modifications to enhance program access. The Department of Planning and Construction reviewed the responses and added suggested physical modifications to the updated list.
4. ***Retained door/doorway accessibility modifications developed as a result of the 2013 campus-wide survey of all classrooms, class labs, seminar rooms and lecture halls, noting completed projects, dates of completion, and actual or projected cost where applicable.*** The focus of the survey was to determine doors/doorways that do not meet 2010 ADA Standards, including doors that may require automatic door openers because the doors are too heavy and because of restricted inadequate maneuvering space, and add them to the list of enhancements. These rooms generally have single or double doors and door openings that need to be widened and/or require automatic door openers, door thresholds and accessible hardware.
5. ***Retained water cooler upgrades developed as a result of the 2013 campus-wide survey of water coolers located on the corridors on each floor, noting completed projects, dates of completion, and actual or projected cost where applicable.*** The focus was to survey every floor of each building to identify drinking fountains that do not meet 2010 ADA Standards and add them to the list of enhancements. Most corridors have more than one drinking fountain to be replaced.
6. ***Retained restroom modifications developed as a result of the 2010 campus-wide survey of all restrooms, noting completed projects, dates of completion, and actual or projected cost where applicable.*** The focus of this survey was dimensions of toilet stalls and width of restroom entrance doors as these are the most critical aspects of restroom access. If toilet stall dimensions and/or entrance door widths were not marginally within 2010 ADA Standards (more than one-inch deviation from the guidelines), the restroom was included in the 2010 list. While the surveys focused on toilet stall dimensions and width of entrance doors, there are likely other issues in the restroom such as heights of sinks, paper towel dispensers, mirrors, etc that do not meet 2010 Standards. The

projected cost to upgrade each restroom on the updated list is \$89,000 (in 2019 dollars), which is a budget placeholder amount based on the average cost of recent restroom renovations. This budget placeholder amount will be refined on a case by case basis when the university requests project funding for individual restrooms.

7. ***Retained elevator upgrades developed as a result of the 2010 campus-wide survey of all elevators, noting completed projects, dates of completion, and actual or projected cost where applicable.*** Elevator upgrades fall into the following three categories:

- A. Elevators are too small.** The 2010 campus-wide survey of all elevators focused on the elevator cab dimensions, as this is the most critical aspect of elevator access. If the elevator cab dimensions were not marginally within ADA standards (more than 3-inch deviation from the guidelines), an elevator replacement with a larger sized cab was included in the list of enhancements. Three buildings were added to the 2010 list and retained in updated list: Atlantic Building (formerly Computer and Space Sciences Building), Lee Building, and Marie Mount Hall.
- B. Elevators do not provide access to all floors.** The 2010 ADA Transition Plan Update addressed this issue. One of the four buildings added to the 2010 list was removed from the updated list: Cole Student Activities Building. The remaining three buildings were retained in the updated list: Art-Sociology Building, Tydings Hall, and Jimenez Hall. Prior to 2010, building occupants provided program access by utilizing space on the accessible floors when needed.
- C. Buildings with no elevators.** The 2010 ADA Transition Plan Update addressed this issue. One of the six buildings added to the 2010, 2013 and 2016 lists was removed from the updated list: Potomac Building. This building has been demolished. The remaining five buildings were retained in the updated list: Engineering Lab Building, Preinkert Hall, Reckord Armory, Manufacturing Building, and Varsity Sports Teamhouse. Prior to 2010, access to the Engineering Lab Building was provided albeit inconveniently from an adjacent connected building with an accessible elevator.

The projected cost to address the elevator upgrades on the updated list is \$1,400,000, which is a budget placeholder amount based on the cost of some recent elevator projects. This budget placeholder amount will be refined on a case by case basis when the university requests project funding for individual elevators. This Update continues the approach of the 2010 ADA Transition Plan Update to not include new elevators in *Morrill Hall and Rossborough Inn* because they are historic and a new elevator would impact the historic character of the building.

The updated list was reviewed by the Working Group, which includes members from the Facilities Advisory Committee and the President's Commission on Disability Issues.

Appendix C is the updated list of enhancements to accessibility.

The 2020 updated list of physical enhancements totals \$56.6 million (in 2019 dollars), broken down as follows:

	State-Supported Facilities	Auxiliary Facilities	Total
Site Upgrades	\$0.8 M	\$2.0 M	\$2.8 M
Restroom Upgrades	\$24.2 M	\$5.5 M	\$29.7 M
Elevator Projects	\$18.0 M	\$1.5 M	\$19.5 M
Other Upgrades	\$3.7 M	\$0.9 M	\$4.5 M
Total	\$46.7 M	\$9.9 M	\$56.6 M

The list of physical enhancement projects completed since 2016 update totals \$1.74 million, broken down as follows:

	State-Supported Facilities	Auxiliary Facilities	Total
Site Upgrades¹	\$0.01 M	\$0.004 M	\$0.01 M
Restroom Upgrades	\$1.27 M	\$0.00 M	\$1.27 M
Elevator Projects	\$0.17 M	\$0.00 M	\$0.17 M
Other Upgrades	\$0.29 M	\$0.00 M	\$0.29 M
Total	\$1.74 M	\$0.004 M	\$1.74 M

For the site upgrades, it should be noted that the university expects that it will request funding for site improvements in the future that may not be on the list. As individuals who use wheelchairs travel more around the campus, and as the campus physical plant grows and changes, the university receives requests to add new or modify existing curb cuts, add or modify ramps, or perform other site modifications. Due to these changing dynamics, the number and location of all site work required on campus is constantly changing. As such, the university expects that there will be site upgrades required in the future that are not on the current list.

Priorities for Enhancements

The priorities for the enhancements are similar to what was included in the 2016 ADA Transition Plan Update and are described below. These priorities will be used as a guide in the development of annual programs/funding requests for accessibility improvements as well as in the development of scopes of planned renovation projects. Deviations from these priorities are expected to occur due to funding availability and other specific circumstances as the annual programs/funding requests and scopes of renovation projects are developed.

A. Priorities by type of enhancement.

Title II of ADA addresses non-discrimination on the basis of disability by state and local government entities but does not suggest a system of priorities for removal of physical obstacles. Title III, however, establishes a system of priorities for obstacle removal in public accommodations. The logic underlying the system of priorities for public accommodations can be applied to state and local government entities. Briefly, the order of priority is as follows:

1. Access from public sidewalks, parking, or public transportation.
2. Access to areas in places of public accommodation where goods and services are available to the public.
3. Access to toilet facilities.
4. Access by other means to provide access to goods, services, facilities, privileges, advantages, or accommodations.

B. Priorities by type of facility.

There are different fund sources for State-supported facilities and auxiliary facilities:

State-supported Facilities (\$46.7M of enhancements). These facilities, which generally include the academic and administrative facilities, are funded from the Access Maryland and Access UMD Programs. The State of Maryland currently allocates \$1.6M per year for accessibility modifications to State-supported facilities, and the university annually requests a portion of these funds and receives in the range of \$0.2M to \$0.5M per year. In 2017, the Maryland General Assembly began requiring USM institutions to provide a 30% minimum contribution to Access MD funding request. In addition, the university allocates about \$0.1M per year from its operating budget for accessibility improvements in a program called Access UMD Program. The Access Maryland and Access UMD Program funds are for specific accessibility improvement projects in State-supported facilities. In addition, accessibility improvements are also made when buildings undergo either whole or partial renovations.

The priorities of the listed enhancements for State-supported facilities are as follows:

1. Academic facilities
2. Library facilities

3. Administrative facilities
4. Academic support facilities (maintenance facilities, storage facilities, public safety facilities, and Maryland Fire and Rescue Institute facilities)

The university will continue to develop annual funding requests for the enhancement of access for persons with disabilities. In addition, the university will continue to include physical enhancements, to the extent project funding allows, in the scope of planned renovation projects.

Auxiliary Facilities (\$9.9M of enhancements). These facilities are for self-support functions of the university such as residence halls, dining facilities, recreational facilities, inter-collegiate athletic facilities, parking facilities, and the Stamp Student Union. Auxiliary units fund and implement enhancement of their facilities independently, with funds from revenues of their operations. Like the State-owned facilities, the auxiliary units address accessibility needs via specific, stand-alone physical modifications required to address an access need and via whole or partial building renovations that include such physical modifications. Completion of all listed enhancements of program accessibility will be influenced to a significant degree by funding availability.

III OFFICIAL RESPONSIBLE FOR IMPLEMENTATION OF THE PLAN

The Department of Justice requires that the institution name an individual who is assigned the task of implementing a plan for compliance with the ADA.

The university has assigned responsibility for ensuring the institution's compliance with the ADA, Section 504 of the Rehabilitation Act of 1973 (Section 504), and other applicable federal and State laws regarding discrimination on the basis of disability to the ADA Compliance Officer. Dr. Jo Ann Hutchinson, Director of Accessibility and Disability Service, is currently assigned this responsibility. The officer holding this administrative position monitors the institution's efforts to comply with the ADA/Section 504, and represents the institution's interests with federal and state agencies.

In addition, the university has a robust organizational structure to monitor and support the institution's ADA compliance efforts and/or provision of services for people with disabilities. Following is information on the individuals, groups and units involved and their responsibilities:

ADA Coordinator: This individual coordinates the university's responsibilities in complying with and fulfilling its obligations under the ADA and other federal and state laws that protect persons with disabilities. The ADA Coordinator's key duties are: monitor and coordinate reviews of policies/practices; develop, conduct, and evaluate educational materials and programs for faculty, staff, and students; and act as liaison to units on campus as well as local, state, and national disability organizations. Dr. Jo Ann Hutchinson, Director of Accessibility and Disability Service, is assigned this responsibility.

President's Commission on Disability Issues (PCDI): This advisory board, comprised of individuals from across campus, provides advice to the President concerning issues affecting students and employees with disabilities. Dr. Ana Palla-Kane, Accessibility Specialist in the Division of Information Technology and Dr. Paul T. Jaeger, Professor, College of Information Studies serve as the Co-chairs.

Accessibility and Disability Service (ADS): Established in 1976, ADS has grown steadily from its original clientele of seven persons to over 1,000. The mission of the ADS is to coordinate services that ensure individuals with disabilities have equal access to University programs. ADS provides and coordinates direct services for students, faculty, staff and visitors with disabilities, with services tailored to meet the needs of the individuals. It also educates and provides consultation to faculty, staff and administrators to increase their awareness and sensitivity toward individuals with disabilities, and provides students and staff with disabilities the opportunity to gain the skills necessary to effectively advocate for themselves within the University community.

Services include testing accommodations (extended exam time, private space, testing readers and/or scribes, computer access for exams and enlarged print); reading accommodations (audio books, alternate format of text materials, enlarged print); deaf and hard of hearing services (interpreting services, transcribing and audio systems); and other services (priority registration, note taking, lab/library assistance, adaptive technology lab, individualized coaching, advocacy support, and para-transit registration). Dr. Jo Ann Hutchinson is the Director of ADS.

Facilities Management (FM): FM is responsible for ensuring that new buildings and renovated facilities meet ADA design guidelines; prepares and updates the ADA Transition Plan every three years; and coordinates the Access MD and Access UMD programs for the University. Mr. Charles Reuning is the Associate Vice President and Chief Facilities Officer for Facilities Management.

Department of Transportation Services (DOTS): DOTS manages Shuttle UMD which provides transit services to students, faculty and staff. Shuttle UMD also provides para-transit service, which is a curb-to-curb, on demand and subscription service available to all students, faculty, staff, and visitors with disabilities. During the fall and spring academic semesters, para-transit service hours are twenty-four hours a day, seven days a week. During summer sessions, para-transit service hours are twenty-four hours a day Monday through Friday and on the weekends 5:30 PM until 7:30 AM. Advanced subscription scheduling is available Monday through Friday during the fall and spring academic semesters as well as the summer and winter sessions. When the University is closed, none of Shuttle UMD's transit services, including para-transit, are running. Mr. J. David Allen is the Director of DOTS.

Other Services/Facilities: The UMD Campus Webmap at <http://maps.umd.edu/map/> is part of the first phase of UMD's Enterprise GIS (Geographical Information System) Initiative. The campus map application and related systems support is a collaborative effort led by Facilities Management and the Division of Information Technology, with datasets and application development support provided by the Department of Geographical Sciences. The map allows users to filter out stairs and steep inclines and provides travel routes from one location to another on campus. In addition, the University has installed granite markers throughout campus to indicate the pathways to accessible building entrances.

APPENDIX A

LIST OF BUILDINGS SURVEYED BY THE DEPARTMENT OF PLANNING AND CONSTRUCTION

BUILDINGS BUILT OR RENOVATED PRIOR TO ADA
(enacted July 1990)

NO	BUILDING NAME	BLDG NO	COMMENTS
1	4-H Headquarters	800	
2	A.V. Williams Building	115	
3	Anacostia Building (3907 Metzerott Road)	332	
4	Animal Sciences/Agric. Engineering Bldg.	142	
5	Annapolis Hall (Offices - Student Affairs)	008	
6	Arboretum Outreach Center (formerly Apiary)	156	
7	Architecture Building	145	
8	Astronomical Observatory	221	
9	Astronomy Lecture Building	219	
10	Atlantic Building (formerly Computer & Space Sciences Building)	224	
11	Avrum Gudelsky Veterinary Center	795	
12	Benjamin Building	143	
13	Biology-Psychology Building	144	
14	Biomolecular Sciences Building	296	
15	Bob "Turtle" Smith Stadium at Shipley Field	159	
16	Cambridge Community Center	097	
17	Caroline Hall	070	
18	Carroll Hall	065	
19	Cecil Hall	017	

20	Center for Educational Partnership (CEP)	804	
21	Center For Young Children	381	
22	Central Animal Resources Facility	087	
23	Chemical & Nuclear Engineering Building	090	
24	Chemistry Building (Wings 2, 3, 4 & 5)	091	
25	Chesapeake Building	338	
26	Cole Student Activities Building (unrenovated portion)	162	
27	Energy Research Facility	223	
28	Engineering Annex	093	
29	Engineering Laboratory Building	089	
30	Environmental Service Facility	344	
31	Francis Scott Key Hall	048	
32	Geology Building	237	
33	H.J. Patterson Hall (Wing 2)	073	
34	Hornbake Library	147	
35	Institute For Physical Science & Tech	085	
36	Instructional Television Facility	045	
37	J.M. Patterson Building	083	
38	Jimenez Hall	034	
39	John S. Toll Physics Building	082	
40	Jull Hall	227	

41	Kirwan Hall (formerly Mathematics Building)	084	
42	Lee Building	071	
43	LeFrak Hall	038	
44	Main Administration Building	077	
45	Manufacturing Building	148	
46	Marie Mount Hall	046	
47	Martin Hall	088	
48	Maryland Stadium Concessions 1	362	
49	Maryland Stadium Concessions 2	363	
50	Maryland Stadium Concessions 3	364	
51	Maryland Stadium Concessions 4	365	
52	Maryland Stadium Concessions 5	367	
53	Maryland Stadium Concessions 6	370	
54	McKeldin Library	035	
55	Memorial Chapel	009	
56	MFRI Office/Classroom Building	199	
57	Microbiology Building	231	
58	Mitchell Building	052	
59	Morrill Hall	040	
60	Neutral Buoyancy Research Facility	382	
61	Nyumburu Cultural Center	232	
62	Parren J. Mitchell Art-Sociology Building	146	

63	Patapsco Building	805	
64	Patuxent Building	010	
65	Police Services and Training Facility	809	
66	Police Substation (7505 Yale Avenue)	018	
67	Preinkert Hall	054	
68	Reckord Armory	078	
69	Regents Drive Parking Garage	202	
70	Rossborough Inn	080	
71	School of Public Health Building	255	
72	Shipley Field	159	
73	Skinner Building	044	
74	South Campus Dining Hall	026	
75	Susquehanna Hall	233	
76	Symons Hall	076	
77	Taliaferro Hall	043	
78	Temporary Building (West of 201) 1 (RF Bldg)	207	
79	Turner Hall	079	
80	Tydings Hall	042	
81	Union Lane Parking Garage	179	
82	Van Munching Hall	039	
83	Varsity Sports Teamhouse	158	
84	Wicomico Hall	069	

85	Wind Tunnel Building	081	
86	Woods Hall	047	

**BUILDINGS BUILT OR RENOVATED PRIOR TO ADA
(enacted July 1990)**

NO	BUILDING NAME	BLDG NO	COMMENTS
1	A. James Clark Hall	429	
2	Aquatics Center	399	
3	Biosciences Research Building	413	
4	Brendan IRIBE Center	432	
5	Chincoteague Hall (formerly Journalism Bldg)	059	
6	Clarice Smith Performing Arts Center At Maryland	386	
7	Cole Student Activities Building	162	
8	College Park Fire Station	802	
9	Computer Science Instructional Center	406	
10	Dorchester Hall	064	
11	Edward St. John Learning and Teaching Center	226	
12	Ellicott Area Dining Hall	257	
13	Eppley Recreation Center	068	
14	Field Hockey and Lacrosse Complex	414	
15	Golf Course Club House	166	
16	Gossett Football Team House	379	
17	H.J. Patterson (Wing 1)	073	
18	Health Center	140	
19	Indoor Practice Facility	309	
20	Kehoe Track at Ludwig Field	388	
21	Kim Engineering Building	225	

22	Knight Hall	417	
23	Maryland Softball Stadium	409	
24	Mowatt Lane Parking Garage	404	
25	Paint Branch Building	383	
26	Physical Sciences Complex	415	
27	Plant Sciences Building	036	
28	Pocomoke Building	007	
29	Research Greenhouse	398	
30	Ritchie Coliseum	004	
31	Severn Building	810	
32	Shoemaker Building	037	
33	Stadium Drive Parking Garage	218	
34	Stamp Student Union	163	
35	Tawes Hall	141	
36	Technology Advancement Program Building	387	
37	Terrapin Trail Parking Garage	403	
38	Tyser Tower	361	
39	XFINITY Center	360	

APPENDIX B

LIST OF BUILDINGS SCHEDULED FOR MAJOR RENOVATION OR DEMOLITION

Buildings Scheduled for Major Renovation or Demolition

These buildings are not included in the list of enhancements to accessibility as they are planned to be demolished or undergo major renovation.

Projects in Governors FY 2020-2024 Capital Improvement Program, USM FY 2020-2024 System Funded Construction Program, or approved out-of-cycle by the Board of Regents

Chemistry Building Wing 1 – Demolition and Replacement

Buildings to be Demolished or Renovated for Innovation District Initiative

Building 011 (Motor Pool)

Building 006 (Plant Operations and Maintenance Shops)

APPENDIX C

LIST OF ENHANCEMENTS TO PROGRAMMATIC ACCESSIBILITY

List of Enhancements to Programmatic Accessibility

The following list of enhancements to programmatic accessibility includes cost estimates for each item which are in 2019 dollars. The costs include design, construction and contingencies. The cost estimates were developed as follows:

For items that were included in the 2016 ADA Transition Plan Update list of enhancements, the cost estimates prepared at that time were inflated, using State inflation rates, to the year 2019.

The projected cost to upgrade each restroom added to the list is \$89,000 (in 2019 dollars), which is a budget placeholder amount based on the average cost of recent restroom renovations. This budget placeholder amount will be refined on a case by case basis when the university requests project funding for individual restrooms. The budget placeholder amount in the 2016 ADA Transition Update was \$60,000 (in 2016 dollars). The increase to \$89,000 better aligns with the scope and cost of recently implemented restroom renovations. Recent renovations have been more comprehensive in scope than envisioned in 2016, including replacement of fixtures, plumbing systems and finishes, in order to implement much needed renewal in conjunction with making them accessible.

The projected cost to address the elevator upgrades on the updated list is \$1,400,000 (in 2019 dollars), which is a budget placeholder amount based on the cost of some recent elevator projects. The budget placeholder amount for the elevator upgrades was \$1,150,000 (in 2016 dollars). The increase to \$1,400,000 (in 2019 dollars) better aligns with the scope and cost of recently implemented elevator upgrades. This budget placeholder amount will be refined on a case by case basis when the university requests project funding for individual elevators.

LIST OF ENHANCEMENTS TO PROGRAMMATIC ACCESSIBILITY

ELEVATOR PROJECTS

**ADA TRANSITION PLAN UPDATE 2020
ELEVATOR PROJECTS**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
1	Animal Sciences/Agric. Eng. Building	142	0408	Academic	Elevator /Lift	Install ADA compliant lift in Lecture Hall	\$0	\$170,000	3/28/19	Project not in 2016 Transition Plan, but completed in 2019
2	Art - Sociology Building	146	1299	Academic	Elevator Lobby	Replace missing braille and raised letter sign.	\$3,000	\$0	NA	
3	Art - Sociology Building	146	2399	Academic	Elevator lobby	Install signal announcing arrival of car.	\$5,000	\$0	NA	
4	Art - Sociology Building	146	2399	Academic	Elevator Lobby	Replace missing Braille and raised letter sign.	\$5,000	\$0	NA	
5	Art - Sociology Building	146	3306	Academic	Elevator Lobby	Install signal announcing arrival of car.	\$5,000	\$0	NA	
6	Art - Sociology Building	146	3306	Academic	Elevator Lobby	Replace missing Braille and raised letter sign.	\$3,000	\$0	NA	
7	Art - Sociology Building	146	4199	Academic	Elevator Lobby	Replace missing Braille and raised letter sign.	\$3,000	\$0	NA	
8	Art - Sociology Building	146	1396	Academic	Elevator	Install new accessible elevator to access 1st & 2nd floor mezzanines & the 4th floor.	\$1,375,000	\$0	NA	Does not go to all floors (1st & 2nd Mezzanines & the 4th floor)
9	Art - Sociology Building	146	2213	Academic	Elevator/Lift	Install ADA compliant lift in Art Sociology Library.	\$0	\$0	3/24/10	FY 2010 Access MD Project (\$89,100).
10	Biology - Psychology Building	144	1190	Academic	Elevator Car	Provide visual & audible signal indicating passing floors.	\$25,000	\$0	NA	
11	Biology - Psychology Building	144	1191	Academic	Elevator Car	Provide visual & audible signal indicating passing floors.	\$25,000	\$0	NA	New Survey 2016
12	Biomolecular Science Building	296	1192	Academic	Elevator Car	Install non-verbal signaling system.	\$5,000	\$0	NA	
13	Atlantic Building (formerly Computer & Space Sciences Building)	224	0298 & 1399	Academic	Elevator	Install one new ADA compliant elevator	\$1,375,000	\$0	NA	Provide one accessible elevator that access all floors (there two elevators that too small & one compliant elevator (0492) that does not access all floors)
14	Cole Student Activities Building (unrenovation portion)	162	BLDG	Academic	Elevator	Install new ADA compliant elevator	\$1,375,000	\$0	NA	The original entrance wing of the building has no elevator and not part of Cole renovation project.

**ADA TRANSITION PLAN UPDATE 2020
ELEVATOR PROJECTS**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
15	Engineering Laboratory Building	089	BLDG	Academic	Elevator	Install new ADA compliant elevator	\$1,375,000	\$0	NA	No existing elevator in this building
16	Francis Scott Key Hall	048	3193	Academic	Elevator Lobby	Lower call button ht. to 42 in. on center.	\$4,000	\$0	NA	
17	Hornbake Library	147	0194	Library	Elevator Lobby	Install audible car arrival signal.	\$5,000	\$0	NA	
18	Hornbake Library	147	0195	Library	Elevator Lobby	Install audible car arrival signal.	\$5,000	\$0	NA	
19	Jimenez Hall	034	0195	Academic	Elevator	Install new ADA compliant elevator	\$1,375,000	\$0	NA	and there are steps from the elevator to the corridor on the 4th floor (the only elevator in the building)
20	Lee Building	071	0196	Administrative	Elevator	Install new ADA compliant elevator	\$1,375,000	\$0	NA	Goes to all floors, but too small (the only elevator in the building)
21	LeFrak Hall	038	0293	Academic	Elevator Lobby	Install Braille signs or raised signs as req'd.	\$4,000	\$0	NA	
22	Main Administration	077	N/A	Administrative	Elevator	Replace elevator to comply with 2010 Standards ADA	\$0	\$0	3/26/12	FY 2009 Access UMD & FY 2009 Access MD Funds (1.9M)
23	Manufacturing Building	148	BLDG	Academic	Elevator	Install new ADA compliant elevator (no existing elevator)	\$1,375,000	\$0	NA	No existing elevator in this building (second floor offices have no elevator access)
24	Marie Mount Hall	046	3492 & 3496	Academic	Elevator	Install one new ADA compliant elevator	\$1,375,000	\$0	NA	Goes to all floors, but too small (two elevators in the building)
25	Martin Hall	088	3299	Academic	Elevator Lobby	Install Braille and raised signs at elevator door jamb.	\$3,000	\$0	NA	
26	Kirwan Hall (formerly Mathematics Building)	084	1403	Academic	Elevator Lobby	Install signal announcing arrival of car.	\$5,000	\$0	NA	
27	Kirwan Hall (formerly Mathematics Building)	084	2403	Academic	Elevator Lobby	Install signal announcing arrival of car.	\$5,000	\$0	NA	
28	Kirwan Hall (formerly Mathematics Building)	084	3403	Academic	Elevator Lobby	Install signal announcing arrival of car.	\$5,000	\$0	NA	
29	Kirwan Hall (formerly Mathematics Building)	084	4399	Academic	Elevator Lobby	Install Braille and raised signs at elevator door jamb.	\$3,000	\$0	NA	
30	Kirwan Hall (formerly Mathematics Building)	010	0195	Academic Support	Elevator Lobby	Install Braille and raised signs at elevator door jamb.	\$3,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
ELEVATOR PROJECTS**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
31	Kirwan Hall (formerly Mathematics Building)	010	1195	Academic Support	Elevator Lobby	Install Braille and raised signs at elevator door jamb.	\$2,000	\$0	NA	
32	Kirwan Hall (formerly Mathematics Building)	010	2195	Academic Support	Elevator Lobby	Install Braille and raised signs at elevator door jamb.	\$2,000	\$0	NA	
33	Preinkert Hall	054	BLDG	Academic	Elevator	Install new ADA compliant elevator to access all floors	\$1,375,000	\$0	NA	No existing elevator in this building
34	Reckord Armory	078	BLDG	Administrative	Elevator	Install new ADA compliant elevator to access all floors	\$1,375,000	\$0	NA	No existing elevator in this building
35	School of Public Health	255	1197	Academic	Elevator Lobby	Install signal announcing arrival of car.	\$5,000	\$0	NA	
36	School of Public Health	255	2199	Academic	Elevator Lobby	Install signal announcing arrival of car.	\$5,000	\$0	NA	
37	Service Building	003	NA	Non-Academic	Elevator	Install new ADA compliant elevator (no existing elevator).	\$1,375,000	\$0	NA	No existing elevator in this building (second floor offices have no elevator access)
38	Skinner Building	044	2197	Academic	Elevator Lobby	Install Braille signs or raised signs as req'd.	\$2,000	\$0	NA	
39	Skinner Building	044	3197	Academic	Elevator Lobby	Install Braille signs or raised signs as req'd.	\$2,000	\$0	NA	
40	Turner Hall	079	BLDG	Administrative	Elevator	Install new accessible elevator.	\$1,375,000	\$0	NA	Goes to all floors, but too small
41	Tydings Hall	042	0198	Academic	Elevator	Install new ADA compliant elevator to access the 5th floor.	\$1,375,000	\$0	NA	Does not go to all floors (5th floor)
						SUB-TOTAL STATE SUPPORTED	\$18,014,000	\$170,000		

**ADA TRANSITION PLAN UPDATE 2020
ELEVATOR PROJECTS**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
1	Annapolis Hall	008	0198	Auxiliary-Residence Hall Central Offices	Elevator Car	Provide permanent raised signs by controls.	\$8,000	\$0	NA	
2	Annapolis Hall	008	0198	Auxiliary-Residence Hall Central Offices	Elevator Car	Provide Braille signs by controls.	\$6,000	\$0	NA	
3	Annapolis Hall	008	1199	Auxiliary-Residence Hall Central Offices	Elevator Lobby	Install Braille and raised signs at elevator door jamb.	\$3,000	\$0	NA	
4	Annapolis Hall	008	2199	Auxiliary-Residence Hall Central Offices	Elevator Lobby	Install Braille and raised signs at elevator door jamb.	\$3,000	\$0	NA	
5	Centreville Hall	098	0197	Auxiliary-Residence Hall College Park Scholars	Elevator Lobby	Install Braille and raised signs at jamb as required.	\$2,000	\$0	NA	
6	Centreville Hall	098	0297	Auxiliary-Residence Hall College Park Scholars	Elevator Lobby	Install Braille and raised signs at jamb as required.	\$2,000	\$0	NA	
7	Centreville Hall	098	1193	Auxiliary-Residence Hall College Park Scholars	Elevator Lobby	Install Braille and raised signs at jamb as required.	\$2,000	\$0	NA	
8	Centreville Hall	098	1293	Auxiliary-Residence Hall College Park Scholars	Elevator Lobby	Install Braille and raised signs at jamb as required.	\$2,000	\$0	NA	
9	Centreville Hall	098	2198	Auxiliary-Residence Hall College Park Scholars	Elevator Lobby	Install Braille and raised signs at jamb as required.	\$2,000	\$0	NA	
10	Centreville Hall	098	2298	Auxiliary-Residence Hall College Park Scholars	Elevator Lobby	Install Braille and raised signs at jamb as required.	\$2,000	\$0	NA	
11	Centreville Hall	098	3198	Auxiliary-Residence Hall College Park Scholars	Elevator Lobby	Install Braille and raised signs at jamb as required.	\$2,000	\$0	NA	
12	Centreville Hall	098	3298	Auxiliary-Residence Hall College Park Scholars	Elevator Lobby	Install Braille and raised signs at jamb as required.	\$2,000	\$0	NA	
13	Centreville Hall	098	4198	Auxiliary-Residence Hall College Park Scholars	Elevator Lobby	Install Braille and raised signs at jamb as required.	\$2,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
ELEVATOR PROJECTS**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
14	Centreville Hall	098	4298	Auxiliary-Residence Hall College Park Scholars	Elevator Lobby	Install Braille and raised signs at jamb as required.	\$2,000	\$0	NA	
15	Centreville Hall	098	5198	Auxiliary-Residence Hall College Park Scholars	Elevator Lobby	Install Braille and raised signs at jamb as required.	\$2,000	\$0	NA	
16	Centreville Hall	098	5298	Auxiliary-Residence Hall College Park Scholars	Elevator Lobby	Install Braille and raised signs at jamb as required.	\$2,000	\$0	NA	
17	Centreville Hall	098	6198	Auxiliary-Residence Hall College Park Scholars	Elevator Lobby	Install Braille and raised signs at jamb as required.	\$2,000	\$0	NA	
18	Centreville Hall	098	6298	Auxiliary-Residence Hall College Park Scholars	Elevator Lobby	Install Braille and raised signs at jamb as required.	\$2,000	\$0	NA	
19	Centreville Hall	098	7198	Auxiliary-Residence Hall College Park Scholars	Elevator Lobby	Install Braille and raised signs at jamb as required.	\$2,000	\$0	NA	
20	Centreville Hall	098	7298	Auxiliary-Residence Hall College Park Scholars	Elevator Lobby	Install Braille and raised signs at jamb as required.	\$2,000	\$0	NA	
21	Centreville Hall	098	8298	Auxiliary-Residence Hall College Park Scholars	Elevator Lobby	Install Braille and raised signs at jamb as required.	\$2,000	\$0	NA	
22	Ellicott Hall	256	0193	Auxiliary-Residence Hall Gemstone	Elevator Lobby	Install Braille signs at jamb as required.	\$2,000	\$0	NA	
23	Ellicott Hall	256	3193	Auxiliary-Residence Hall Gemstone	Elevator Lobby	Install Braille signs at jamb as required.	\$2,000	\$0	NA	
24	Ellicott Hall	256	4193	Auxiliary-Residence Hall Gemstone	Elevator Lobby	Install Braille signs at jamb as required.	\$2,000	\$0	NA	
25	Ellicott Hall	256	5193	Auxiliary-Residence Hall Gemstone	Elevator Lobby	Install Braille signs at jamb as required.	\$2,000	\$0	NA	
26	Ellicott Hall	256	6193	Auxiliary-Residence Hall Gemstone	Elevator Lobby	Install Braille signs at jamb as required.	\$2,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
ELEVATOR PROJECTS**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
27	Ellicott Hall	256	7193	Auxiliary-Residence Hall Gemstone	Elevator Lobby	Install Braille signs at jamb as required.	\$2,000	\$0	NA	
28	Ellicott Hall	256	8193	Auxiliary-Residence Hall Gemstone	Elevator Lobby	Install Braille signs at jamb as required.	\$2,000	\$0	NA	
29	LaPlata Hall	259	1193	Auxiliary-Residence Hall Coed	Elevator Lobby	Install Braille and raised letter signs at elev. doorjamb.	\$2,000	\$0	NA	
30	LaPlata Hall	259	6193	Auxiliary-Residence Hall Coed	Elevator Lobby	Install Braille and raised letter signs at elev. doorjamb.	\$2,000	\$0	NA	
31	LaPlata Hall	259	7193	Auxiliary-Residence Hall Coed	Elevator Lobby	Install Braille and raised letter signs at elev. door jamb.	\$2,000	\$0	NA	
32	LaPlata Hall	259	8193	Auxiliary-Residence Hall Coed	Elevator Lobby	Install Braille and raised letter signs at elev. doorjamb.	\$2,000	\$0	NA	
33	LaPlata Hall	259	9193	Auxiliary-Residence Hall Coed	Elevator Lobby	Install Braille and raised letter signs at elev. door jamb.	\$2,000	\$0	NA	
34	LaPlata Hall	259	C0193	Auxiliary-Residence Hall Coed	Elevator Lobby	Install Braille and raised letter signs at elev. doorjamb.	\$2,000	\$0	NA	
35	Varsity Sports Teamhouse	158	BLDG	Auxiliary-ICA	Elevator	Install new accessible elevator.	\$1,375,000	\$0	NA	No existing elevator in this building
						SUB-TOTAL AUXILIARY	\$1,455,000	\$0		
						TOTAL STATE-SUPPORTED AND AUXILIARY	\$19,469,000	\$170,000		

LIST OF ENHANCEMENTS TO PROGRAMATTIC ACCESSIBILITY

RESTROOM UPGRADES

ADA TRANSITION PLAN UPDATE 2020 RESTROOM UPGRADES

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
1	A. V. Williams Building	115	1108	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (statndard stall).
2	A. V. Williams Building	115	1236	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (end of row).
3	A. V. Williams Building	115	3308	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
4	A.V. Williams Building	115	3304	Academic	Men's Toilet	Install new accessible sink in men's restroom 3304 & reconfigure partitions to enclose new sink in partitioned area of men's restroom.	\$0	\$0	7/21/15	FY15 Access UMD project.
5	Anacostia Building (North Campus Office Annex)	332	0101BT	Academic	Toilet Room	Rebuild to provide accessible unisex toilet room.	\$89,000	\$0	NA	
6	Anacostia Building (North Campus Office Annex)	332	0306BT	Academic	Toilet Room	Rebuild to provide accessible unisex toilet room.	\$89,000	\$0	NA	
7	Anacostia Building (North Campus Office Annex)	332	0306	Academic	Unisex Toilet	Replace Restroom Door. Increase Width of room	\$6,000	\$0	NA	
8	Anacostia Building (North Campus Office Annex)	332	0101A	Academic	Unisex Toilet	Replace Restroom Door. Increase Width of room	\$6,000	\$0	NA	
9	Animal Sciences / Agricultural Engineering Building	142	0137	Academic	Unisex Toilet	Install blade-type handles or single lever faucet.	\$3,000	\$0	NA	
10	Animal Sciences / Agricultural Engineering Building	142	1345	Academic	Men's locker room	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
11	Animal Sciences / Agricultural Engineering Building	142	0374	Academic	Men's locker room	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
12	Animal Sciences / Agricultural Engineering Building	142	1399	Academic	Women's locker Room	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (statndard stall).
13	Animal Sciences / Agricultural Engineering Building	142	0376	Academic	Women's locker Room	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (statndard stall).
14	Animal Sciences / Agricultural Engineering Building	142	1145	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (statndard stall).

ADA TRANSITION PLAN UPDATE 2020 RESTROOM UPGRADES

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
15	Arboretum Outreach Center	156	NA	Non-Academic	Restroom	Create an accessible restroom facility on the entry level.	\$117,000	\$0	NA	New Survey
16	Architecture Building	145	0109	Academic	Women's Toilet	Inadequate entry door clearances.	\$6,000	\$0	NA	
17	Architecture Building	145	1109	Academic	Women's Toilet	Inadequate entry door clearances.	\$6,000	\$0	NA	
18	Architecture Building	145	1113	Academic	Men's Toilet	Renovate to comply with ADA	\$24,000	\$0	NA	New survey (Standard stall).
19	Architecture Building	145	1202	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
20	Architecture Building	145	0103	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
21	Architecture Building	145	1203	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (statndard stall).
22	Architecture Building	145	0214	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (statndard stall).
23	Art - Sociology Building	146	2109	Academic	Men's Toilet	Lower existing fixture so rim is <=17" AFF.	\$4,000	\$0	NA	
24	Art - Sociology Building	146	2109	Academic	Men's Toilet	Install blade-type handles or install single lever faucet.	\$3,000	\$0	NA	
25	Art - Sociology Building	146	2109	Academic	Men's Toilet	Move adjoining partitions to create 30" cl. width.	\$3,000	\$0	NA	
26	Art - Sociology Building	146	1303	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (statndard stall).
27	Art - Sociology Building	146	4303	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (statndard stall).
28	Art - Sociology Building	146	3112	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey 2016
29	Art - Sociology Building	146	3117	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey 2016

ADA TRANSITION PLAN UPDATE 2020 RESTROOM UPGRADES

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
30	Art - Sociology Building	146	4119	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey 2016
31	Artboretum Outreach Center (formerly Apiary)	156	B0101A	Administrative	Unisex Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (no stall).
32	Astronomy Lecture Building	219	1100CMT	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	Standard stall (End of row).
33	Astronomy Lecture Building	219	1100BWT	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	Standard stall (End of row):
34	Astronomy Observatory	221	BLDG	Academic	Unisex Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (standard stall).
35	Atlantic Building (formerly Computer & Space Sciences Building)	224	1124	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
36	Atlantic Building (formerly Computer & Space Sciences Building)	224	1221	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
37	Atlantic Building (formerly Computer & Space Sciences Building)	224	2325	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
38	Atlantic Building (formerly Computer & Space Sciences Building)	224	3221	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
39	Atlantic Building (formerly Computer & Space Sciences Building)	224	3325	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
40	Atlantic Building (formerly Computer & Space Sciences Building)	224	4221	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
41	Atlantic Building (formerly Computer & Space Sciences Building)	224	4325	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
42	Atlantic Building (formerly Computer & Space Sciences Building)	224	1120	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
43	Atlantic Building (formerly Computer & Space Sciences Building)	224	1217	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
44	Atlantic Building (formerly Computer & Space Sciences Building)	224	2217	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).

ADA TRANSITION PLAN UPDATE 2020 RESTROOM UPGRADES

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
45	Atlantic Building (formerly Computer & Space Sciences Building)	224	2323	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
46	Atlantic Building (formerly Computer & Space Sciences Building)	224	3217	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
47	Atlantic Building (formerly Computer & Space Sciences Building)	224	3321	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
48	Atlantic Building (formerly Computer & Space Sciences Building)	224	4217	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
49	Atlantic Building (formerly Computer & Space Sciences Building)	224	2120 / 4120 4124 / 3124	Academic	Men's Toilet & Women's Toilet	Redesign rooms 2120, 4120 and 4124 to comply with ADA requirements and reconfigure room 3124 to provide a new handicap accessible shower room.	\$0	\$0	3/29/13	Completed (Operation & Maintenance Project)
50	Avrum Gudelsky Veterinary Center	795	1101	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	End of row
51	Avrum Gudelsky Veterinary Center	795	1135	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
52	Avrum Gudelsky Veterinary Center	795	1431	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
53	Avrum Gudelsky Veterinary Center	795	1212	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
54	Avrum Gudelsky Veterinary Center	795	1102	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (end of row).
55	Avrum Gudelsky Veterinary Center	795	1133	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (statndard stall).
56	Avrum Gudelsky Veterinary Center	795	1429	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (statndard stall).
57	Avrum Gudelsky Veterinary Center	795	1214	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (statndard stall).
58	Benjamin Building	143	3318	Academic	Men's Toilet	Renovate to comply with ADA	\$0	\$0	NA	FY 2012 Access UMD (\$77K)

**ADA TRANSITION PLAN UPDATE 2020
RESTROOM UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
59	Benjamin Building	143	2310	Academic	Men's Toilet	Renovate to comply with ADA	\$0	\$0	NA	FY 2012 Access UMD (\$77K)
60	Benjamin Building	143	1118	Academic	Men's Toilet	Renovate to comply with ADA	\$0	\$0	NA	FY 2012 Access UMD (\$77K)
61	Benjamin Building	143	0310	Academic	Men's Toilet	Renovate to comply with ADA	\$0	\$0	NA	FY 2012 Access UMD (\$77K)
62	Benjamin Building	143	3310	Academic	Women's Toilet	Renovate to comply with ADA	\$0	\$0	NA	FY 2012 Access UMD (\$77K)
63	Benjamin Building	143	2118	Academic	Women's Toilet	Renovate to comply with ADA	\$0	\$0	NA	FY 2012 Access UMD (\$77K)
64	Benjamin Building	143	1310	Academic	Women's Toilet	Renovate to comply with ADA	\$0	\$0	NA	FY 2012 Access UMD (\$77K)
65	Benjamin Building	143	0310 / 1118 2310 / 3310 0118 / 1310 2118 / 3318	Academic	Men's Toilet & Women's Toilet	Renovate toilet rooms: 0310 MT, 1118 MT, 2310 MT, 3310 MT, 0118 WT, 1310 WT, 2118 WT, and 3318 WT.	\$0	\$0	2/4/13	FY12 Access UMD project (\$367,986).
66	Biology - Psychology Building	144	0117	Academic	Men's Toilet	Renovate to comply with ADA	\$0	\$0	12/10/19	FY 2016 Access MD Project (part of item #83 below)
67	Biology - Psychology Building	144	1241	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	FY 2016 Access MD Project
68	Biology - Psychology Building	144	2117	Academic	Men's Toilet	Renovate to comply with ADA	\$0	\$0	12/10/19	FY 2016 Access MD Project (part of item #83 below)
69	Biology - Psychology Building	144	2241	Academic	Men's toilet	Renovate to comply with ADA	\$89,000	\$0	NA	FY 2016 Access MD Project
70	Biology - Psychology Building	144	3241	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	FY 2016 Access MD Project

**ADA TRANSITION PLAN UPDATE 2020
RESTROOM UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
71	Biology - Psychology Building	144	4117	Academic	Men's Toilet	Renovate to comply with ADA	\$0	\$0	12/10/19	FY 2016 Access MD Project (part of item #83 below)
72	Biology - Psychology Building	144	4241	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	FY 2016 Access MD Project
73	Biology - Psychology Building	144	0282	Academic	Women's toilet	Renovate to comply with ADA	\$89,000	\$0	NA	FY 2016 Access MD Project
74	Biology - Psychology Building	144	0119	Academic	Women's Toilet	Renovate to comply with ADA	\$0	\$0	12/10/19	FY 2016 Access MD Project (part of item #83 below)
75	Biology - Psychology Building	144	1119	Academic	Women's Toilet	Renovate to comply with ADA	\$0	\$0	12/10/19	FY 2016 Access MD Project (part of item #83 below)
76	Biology - Psychology Building	144	1218	Academic	Women's toilet	Renovate to comply with ADA	\$0	\$0	12/10/19	FY 2016 Access MD Project (part of item #83 below)
77	Biology - Psychology Building	144	2119	Academic	Women's Toilet	Renovate to comply with ADA	\$0	\$0	12/10/19	FY 2016 Access MD Project (part of item #83 below)
78	Biology - Psychology Building	144	2282	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	FY 2016 Access MD Project
79	Biology - Psychology Building	144	3119	Academic	Women's Toilet	Renovate to comply with ADA	\$0	\$0	12/10/19	FY 2016 Access MD Project (part of item #83 below)
80	Biology - Psychology Building	144	4119	Academic	Women's Toilet	Renovate to comply with ADA	\$0	\$0	12/10/19	FY 2016 Access MD Project (part of item #83 below)
81	Biology - Psychology Building	144	3282	Academic	Restroom	Renovate to comply with ADA	\$89,000	\$0	NA	New survey 2016
82	Biology - Psychology Building	144	4282	Academic	Restroom	Renovate to comply with ADA	\$89,000	\$0	NA	New survey 2016

ADA TRANSITION PLAN UPDATE 2020 RESTROOM UPGRADES

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
83	Biology-Psychology Building	144	0117 / 2117 / 4117, 0119 / 1119, 1218 / 2119, 3119 / 4119	Academic	Men's Toilet & Women's Toilet	Renovate MT 0117, 2117, 4117 & WT 0119, 1119, 1218, 2119, 3119, 4119; Install automatic door opener to doors and replace 9 water coolers.	\$0	\$390,000	12/10/19	FY 2016 Access MD Project
84	Bioscience Research Building	413	1104	Academic	Unisex Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (end of row).
85	Bioscience Research Building	413	3202	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (end of row)
86	Center for Educational Partnership	804	0105	Academic	Unisex Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (standard stall).
87	Center for Educational Partnership	804	0107	Academic	Unisex Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (standard stall).
88	Center for Educational Partnership	804	0145	Academic	Unisex Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (standard stall).
89	Center for Educational Partnership	804	0147	Academic	Unisex Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (standard stall).
90	Center for Educational Partnership	804	0125A	Academic	Unisex Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (standard stall).
91	Center for Educational Partnership	804	0127A	Academic	Unisex Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (standard stall).
92	Center for Educational Partnership	804	0131A	Academic	Unisex Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (standard stall).
93	Center for Educational Partnership	804	0136A	Academic	Unisex Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (standard stall).
94	Center for Educational Partnership	804	0144A	Academic	Unisex Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (standard stall).
95	Center for Educational Partnership	804	0148A	Academic	Unisex Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (standard stall).

**ADA TRANSITION PLAN UPDATE 2020
RESTROOM UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
96	Center for Educational Partnership	804	0152A	Academic	Unisex Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (standard stall).
97	Center for Educational Partnership	804	0156A	Academic	Unisex Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (standard stall).
98	Center for Educational Partnership	804	0160A	Academic	Unisex Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (standard stall).
99	Center for Educational Partnership	804	0153A	Academic	Unisex Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (standard stall).
100	Center for Educational Partnership	804	0155A	Academic	Unisex Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (standard stall).
101	Center for Educational Partnership	804	0212A	Academic	Unisex Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (standard stall).
102	Center for Educational Partnership	804	0216A	Academic	Unisex Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (standard stall).
103	Center for Educational Partnership	804	0208A	Academic	Unisex Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (standard stall).
104	Center for Educational Partnership	804	0220A	Academic	Unisex Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (standard stall).
105	Central Animal Resources Facility	087	1106	Academic	Men's Toilet	Lower towel dispenser/dryer.	\$2,000	\$0	NA	
106	Central Animal Resources Facility	087	1105	Academic	Women's Toilet	Replace exist. grab bar with 42 in. grab bar.	\$4,000	\$0	NA	
107	Chemical and Nuclear Engineering Building	090	2128	Academic	Men's Toilet	Provide accessible stall and fixture.	\$6,000	\$0	NA	
108	Chemical and Nuclear Engineering Building	090	1131	Academic	Women's Toilet	Provide accessible stall and fixture.	\$6,000	\$0	NA	
109	Chemical and Nuclear Engineering Building	090	2118	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (end of row).
110	Chemical and Nuclear Engineering Building	090	1122	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (end of row).

ADA TRANSITION PLAN UPDATE 2020 RESTROOM UPGRADES

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
111	Chemical and Nuclear Engineering Building	090	1204	Academic	Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (standard stall).
112	Chemical and Nuclear Engineering Building	090	2131	Academic	Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (standard stall).
113	Chemical and Nuclear Engineering Building	090	2137	Academic	Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (standard stall).
114	Chemistry Building	091	0116 / 0120	Academic	Men's Toilet & Women's Toilet	Install automatic door openers to the 2nd set of doors (inside doors) to restrooms 0116 and 0120 or add privacy screens and remove the inside doors.	\$0	\$0	8/23/13	FY 2014 Access UMD Project
115	Chesapeake Building	338	3111	Administrative	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (end of row).
116	Chesapeake Building	338	4111	Administrative	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (end of row).
117	Clarice Smith Performing Arts Center	386	2606	Academic	Unisex Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (end of row).
118	College Park Volunteer Fire Station	802	2123	Academic Support	Men's locker room	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
119	College Park Volunteer Fire Station	802	2202A	Academic Support	Unisex Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (no stall).
120	College Park Volunteer Fire Station	802	2201A	Academic Support	Unisex Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (no stall).
121	College Park Volunteer Fire Station	802	2206A	Academic Support	Unisex Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (no stall).
122	College Park Volunteer Fire Station	802	2205A	Academic Support	Unisex Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (no stall).
123	College Park Volunteer Fire Station	802	2210A	Academic Support	Unisex Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (no stall).
124	Computer Science Instructional Center	406	2103	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).

ADA TRANSITION PLAN UPDATE 2020 RESTROOM UPGRADES

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
125	Computer Science Instructional Center	406	1103	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
126	Energy Research Facility	223	0125	Academic	Men's Toilet	Renovate to be fully accessible.	\$89,000	\$0	NA	
127	Energy Research Facility	223	0217MT	Academic	Men's Toilet	Renovate to be fully accessible.	\$89,000	\$0	NA	
128	Energy Research Facility	223	1217	Academic	Men's Toilet	Renovate to comply with ADA	\$0	\$0	00/00/16	New Survey 2016 (Project Completed)
129	Energy Research Facility	223	0213	Academic	Women's Toilet	Renovate to comply with ADA	\$0	\$0	00/00/16	New Survey 2016 (Project Completed)
130	Energy Research Facility	223	1213	Academic	Women's Toilet	Renovate to comply with ADA	\$0	\$0	00/00/16	New Survey 2016 (Project Completed)
131	Engineering Research Building (Engineering Annex)	093	0201E	Academic	Men's Toilet	Renovate to provide fully accessible toilet rm.	\$89,000	\$0	NA	
132	Engineering Research Building (Engineering Annex)	093	0201F	Academic	Women's Toilet	Renovate to provide fully accessible toilet rm.	\$89,000	\$0	NA	
133	Engineering Research Building (Engineering Annex)	093	0102	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (end of row).
134	Francis Scott Key Hall		2108 / 2112	Academic	Men's & Women's Toilet	Install automatic door opener to 2108 WT and 2112 MT.	\$0	\$0	8/1/16	FY 2015 Access UMD Project
135	Francis Scott Key Hall	048	0108 / 0112 1108 / 1114,	Academic	Men's & Women's Toilet & Faculty Water Coolers	Modify toilet rooms (0108, 0112, 1108, 1114) and replace drinking fountain on the third floor corridor to comply with ADA.	\$0	\$0	7/30/12	FY12 Access MD project (\$67,729).
136	Francis Scott Key Hall	048	3112 / 3108 3111.	Academic	Men's/Women's Toilet & Faculty Lounge	Install automatic door opener to women's toilet room 3112, men's toilet room 3108 and faculty lounge room 3111.	\$0	\$19,500	12/10/18	FY 2017 Access UMD Project
137	H. J. Patterson Hall	073	1218	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).

ADA TRANSITION PLAN UPDATE 2020 RESTROOM UPGRADES

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
138	H. J. Patterson Hall	073	0220	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (end of row).
139	H. J. Patterson Hall	073	0218	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
140	H. J. Patterson Hall	073	1115 / 1128 2128	Academic	Women's & Men's Toilet	Renovate to comply with ADA	\$0	\$328,100	12/10/18	Project not in 2016 Transition Plan, but completed in 2017 as part of larger renovation of Wing 1
141	Health Center	140	0135	Academic Support	Toilet Room	Lower paper towel dispenser	\$2,000	\$0	NA	New Survey 2016
142	Health Center	140	1133	Academic Support	Toilet Room	Lower paper towel dispenser	\$2,000	\$0	NA	New Survey 2016
143	Health Center	140	2111A	Academic Support	Toilet Room	Lower paper towel dispenser	\$2,000	\$0	NA	New Survey 2016
144	Health Center	140	1139C	Academic Support	Unisex Toilet	Install braille sign on restroom door	\$2,000	\$0	NA	
145	Hornbake Library	147	2102 / 2215 4104 / 0213 0219 / 2104 2212 / 4106	Library	Men's & Women's Toilet & Elevator	Modify Women's Restrooms (2102, 2215, and 4104) and Men's Restrooms (0213, 0219, 2104, 2212, and 4106) and install audible car signals in two elevator lobbies (0194 and 0195).	\$0	\$0	12/31/14	FY15 Access MD project.
146	Hornbake Library	147	0102 / 1217 3102 / 3215 0104 / 1214 3104 / 3212 3102 / 3104 3102	Academic	Men's & Women's Toilet	Modify women's toilet rooms (0102, 1217, 3102, and 3215) and men's toilet rooms (0104, 1214, 3104 and 3212); widen doors (3102, 3104) and install automatic door opener 3102 to comply with 2010 ADA Standards.	\$0	\$0	8/31/14	FY13 Access MD Project
147	Hornbake Library	147	0219MT	Library	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
148	Hornbake Library	147	2104MT	Library	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
149	Hornbake Library	147	4106MT	Library	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).

ADA TRANSITION PLAN UPDATE 2020 RESTROOM UPGRADES

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
150	Hornbake Library	147	0213MT	Library	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
151	Hornbake Library	147	2212MT	Library	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
152	Hornbake Library	147	2102WT	Library	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
153	Hornbake Library	147	4104WT	Library	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
154	Hornbake Library	147	2215WT	Library	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
155	Hornbake Library	147	3102, 1001, 3112	Library	Women's Toilet & Men's Toilet	Modify toilet rooms	\$89,000	\$0	NA	New survey (standard stall).
156	Institute for Physical Science & Technology	085	0103MT	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
157	J. M. Patterson Building	083	1107MT	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
158	J. M. Patterson Building	083	2234MT	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
159	J. M. Patterson Building	083	3234MT	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
160	J. M. Patterson Building	083	1106WT	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
161	J. M. Patterson Building	083	2232WT	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
162	J. M. Patterson Building	083	3232WT	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
163	Jimenez Hall	034	0210MT	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
164	Jimenez Hall	034	2113MT	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).

ADA TRANSITION PLAN UPDATE 2020 RESTROOM UPGRADES

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
165	Jimenez Hall	034	3113MT	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
166	Jimenez Hall	034	4113MT	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
167	Jimenez Hall	035	0113MT	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
168	Jimenez Hall	034	0211WT	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
169	Jimenez Hall	034	1210WT	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
170	Jimenez Hall	034	3208WT	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
171	John S. Toll Physics Building	082	0215	Academic	Restroom	Demolish existing urinal and install new urinal in Room 0215.	\$0	\$0	9/4/12	FY 2011 Access UMD Project (\$10,200)
172	Jull Hall	227	1117A	Academic	Women's Toilet	Renovate to comply with ADA	\$0	\$0	00/00/16	New Survey 2016 (Project Completed)
173	Jull Hall	227	2122WT	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
174	Kirwan Hall (formerly Mathematics Building)	084	B0434	Academic	Men's Toilet	Renovate to comply with ADA	\$0	\$0	NA	FY 20 Access MD Project (part of item # 190)
175	Kirwan Hall (formerly Mathematics Building)	084	0204	Academic	Men's Toilet	Renovate to comply with ADA	\$0	\$0	NA	FY 20 Access MD Project (part of item # 190)
176	Kirwan Hall (formerly Mathematics Building)	084	1204	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
177	Kirwan Hall (formerly Mathematics Building)	084	1403D	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
178	Kirwan Hall (formerly Mathematics Building)	084	2206	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).

ADA TRANSITION PLAN UPDATE 2020 RESTROOM UPGRADES

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
179	Kirwan Hall (formerly Mathematics Building)	084	2403C	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
180	Kirwan Hall (formerly Mathematics Building)	084	3204	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
181	Kirwan Hall (formerly Mathematics Building)	084	3403B	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
182	Kirwan Hall (formerly Mathematics Building)	084	0212	Academic	Women's Toilet	Renovate to comply with ADA	\$0	\$0	TBD	FY 2020 Access MD Project (part of item # 190)
183	Kirwan Hall (formerly Mathematics Building)	084	0412	Academic	Women's Toilet	Renovate to comply with ADA	\$0	\$0	TBD	FY 2020 Access MD Project (part of item # 190)
184	Kirwan Hall (formerly Mathematics Building)	084	1212	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (End of row)
185	Kirwan Hall (formerly Mathematics Building)	084	1403E	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (End of row)
186	Kirwan Hall (formerly Mathematics Building)	084	2212	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (End of row)
187	Kirwan Hall (formerly Mathematics Building)	084	2403D	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (End of row)
188	Kirwan Hall (formerly Mathematics Building)	084	3210	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (End of row)
189	Kirwan Hall (formerly Mathematics Building)	084	3403C	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (End of row)
190	Kirwan Hall (formerly Mathematics Building)	084	B0434, 0204 0212, 0412	Academic	Men's and Women's Toilet	Renovate men's and women's restrooms and install automatic door opener to comply with ADA	\$0	\$200,000	TBD	FY 2020 Access MD Funded Project
191	Knight Hall	417	3106	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (end of row).
192	Lee Building	071	2104MT	Administrative	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (end of row).

**ADA TRANSITION PLAN UPDATE 2020
RESTROOM UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
193	Lee Building	071	3104MT	Administrative	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
194	Lee Building	071	0104MT	Administrative	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
195	Lee Building	071	2130WT	Administrative	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
196	Lee Building	071	3130WT	Administrative	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
197	Lee Building	071	1130WT	Administrative	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
198	Lee Building	071	0130WT	Administrative	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
199	LeFrak Hall	038	1212MT	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
200	LeFrak Hall	038	2101MT	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
201	LeFrak Hall	038	0202WT	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
202	LeFrak Hall	038	1216WT	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
203	LeFrak Hall	038	2117WT	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
204	LeFrak Hall	038	0109	Academic	Men's Toilet	Modify men's toilet room (0109) and replace 1 water cooler.	\$0	\$0	7/3/13	FY 2012 Access MD Project (\$19700)
205	LeFrak Hall	038	1101	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey 2016
206	LeFrak Hall	038	1109	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey 2016
207	LeFrak Hall	038	2214	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey 2016

ADA TRANSITION PLAN UPDATE 2020 RESTROOM UPGRADES

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
208	LeFrak Hall	038	2210	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey 2016
209	LeFrak Hall	038	0207	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey 2016
210	LeFrak Hall	038	0206	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey 2016
211	LeFrak Hall	038	0101	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey 2016
212	LeFrak Hall	038	0121	Academic	Unisex Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey 2016
213	Main Administration Building	077	0123 / 0125	Administrative	Women's Toilet	Convert the women's restroom 0123 on the first floor to an "ADA" accessible restroom".	\$0	\$0	9/2/13	UMD Funded Project (\$10,000).
214	Main Administration Building	077	1123	Administrative	Women's Toilet	Create more clearance at strike side or reverse dr. swing.	\$4,000	\$0	NA	
215	Main Administration Building	077	1123	Administrative	Women's Toilet	Increase ht. of knee space to min. 29 in. AFF.	\$3,000	\$0	NA	
216	Main Administration Building	077	1123	Administrative	Women's Toilet	Lower towel dispenser/dryer.	\$2,000	\$0	NA	
217	Main Administration Building	077	0113	Administrative	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
218	Main Administration Building	077	1113	Administrative	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
219	Main Administration Building	077	0109	Administrative	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
220	Marie Mount Hall	046	0107	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (End of row)
221	Marie Mount Hall	046	1107	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (End of row)
222	Marie Mount Hall	046	1425	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (End of row)

**ADA TRANSITION PLAN UPDATE 2020
RESTROOM UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
223	Marie Mount Hall	046	2107	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (End of row)
224	Marie Mount Hall	046	2425	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (End of row)
225	Marie Mount Hall	046	3107	Academic	Men's Toilet	Renovate to comply with ADA	\$0	\$0	NA	New Survey 2016 (Project Completed)
226	Marie Mount Hall	046	3425	Academic	Men's Toilet	Renovate to comply with ADA	\$0	\$0	NA	New Survey 2016 (Project Completed)
227	Marie Mount Hall	046	1421	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (End of row)
228	Marie Mount Hall	046	2421	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (End of row)
229	Marie Mount Hall	046	3421	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (End of row)
230	Marie Mount Hall	046	0103 / 1103, 2103 / 3103	Academic	Men's & Women's Toilet & Water Coolers	Modify women's toilet rms. 0103, 1103, 2103, 3103; replace 4 water coolers & replace door knobs on exit doors to stairwell with levers.	\$0	\$0	12/15/10	FY11 Access MD project (\$58,583).
231	Martin Hall	088	0117	Academic	Women's Toilet	Install blade-type handles or single lever faucet.	\$3,000	\$0	NA	
232	Martin Hall	088	0113	Academic	Men's Toilet	Renovate to comply with ADA	\$0	\$0	NA	FY 2015 Access UMD Project (part of item 234 below)
233	Martin Hall	088	3165	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (End of row)
234	Martin Hall	088	3169	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (End of row)

ADA TRANSITION PLAN UPDATE 2020 RESTROOM UPGRADES

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
235	Martin Hall, Physics Building, and Engineering lab Building (Muilt Buildings)	MLT		Academic	Men's Toilet & automatic door openers	Renovate Men's restroom 0113 in Martin Hall, install automatic door openers to restroom 0113, hallway door 0229 and Engineering Lab Hallway door 0193/0195 and Physics Lecture Hall 1410.	\$0	\$0	3/29/16	FY 2015 Access UMD Project
236	McKeldin Library	035	2203	Library	Men's Toilet	Install blade-type handles or a single lever faucet.	\$3,000	\$0	NA	
237	McKeldin Library	035	3205	Library	Men's Toilet	Install blade-type handles or a single lever faucet.	\$3,000	\$0	NA	
238	McKeldin Library	035	7114	Library	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
239	McKeldin Library	035	6110	Library	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
240	McKeldin Library	035	4106	Library	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
241	McKeldin Library	035	3107	Library	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
242	McKeldin Library	035	3203	Library	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
243	McKeldin Library	035	2203	Library	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
244	McKeldin Library	035	1127	Library	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
245	McKeldin Library	035	1203	Library	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
246	McKeldin Library	035	B0205	Library	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
247	McKeldin Library	035	B0101	Library	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
248	McKeldin Library	035	7112	Library	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).

**ADA TRANSITION PLAN UPDATE 2020
RESTROOM UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
249	McKeldin Library	035	7205	Library	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
250	McKeldin Library	035	6112	Library	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
251	McKeldin Library	035	6205	Library	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
252	McKeldin Library	035	4110	Library	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
253	McKeldin Library	035	4205	Library	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
254	McKeldin Library	035	3109	Library	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
255	McKeldin Library	035	3205	Library	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
256	McKeldin Library	035	2123	Library	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
257	McKeldin Library	035	2205	Library	Women's Toilet	Redesign 2205 WT to provide ADA compliant stall.	\$0	\$21,000	10/13/17	FY2016 Access UMD Funded Project
258	McKeldin Library	035	1129	Library	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
259	McKeldin Library	035	1205	Library	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
260	McKeldin Library	035	B0207	Library	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
261	McKeldin Library	035	B0103	Library	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
262	McKeldin Library	035	NA	Library	Restroom	Install privacy partition in the family restroom	\$0	\$0	8/8/11	FY 2010 Access UMD project; Holzapfel & McKeldin Library (\$505)

ADA TRANSITION PLAN UPDATE 2020 RESTROOM UPGRADES

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
263	MFRI Office/ Classroom Bldg. (College Park, MD)	199	1104 / 1106	Academic Support	Men's & Women's Toilet	Install automatic door opener to the main entrance door to the building & modify women's restroom 1104 and men's restroom 1106 to comply with 2010 ADA Standards.	\$0	\$0	8/23/13	FY14 Access UMD project.
264	MFRI Office/ Classroom Bldg. (College Park, MD)	199	1111C	Academic Support	Men's locker room	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
265	MFRI Office/ Classroom Bldg. (College Park, MD)	199	1108A	Academic Support	Men's locker room	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (end of row).
266	MFRI Office/ Classroom Bldg. (College Park, MD)	199	1210	Academic Support	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (End of row)
267	MFRI Office/ Classroom Bldg. (College Park, MD)	199	2210	Academic Support	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (End of row)
268	Morrill Hall	040	1108MT	Academic	Men's Toilet	Install new urinal w/elongated rim in accessible location.	\$4,000	\$0	NA	
269	Morrill Hall	040	1108MT	Academic	Men's Toilet	Move adj. partitions to create 30 in. cl. width.	\$8,000	\$0	NA	
270	Morrill Hall	040	1108MT	Academic	Men's Toilet	Install a raised seat at 17 - 19 in. AFF.	\$3,000	\$0	NA	
271	Neutal Buoyancy Research Facility		1100B	Academic	Unisex Toilet	Renovate to comply with ADA	\$0	\$0	3/4/15	FY 2013 Access MD Project
272	Nyumburu Cultural Center	232	1104	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
273	Patapsco Building	805	1105	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
274	Patapsco Building	805	1120	Academic	Unisex Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (no stall).
275	Patapsco Building	805	1103	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).

ADA TRANSITION PLAN UPDATE 2020 RESTROOM UPGRADES

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
276	Patapsco Building	805	2103	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
277	Physics Building	082	3125M	Academic	Men's Toilet	Install blade-type handles or a single lever faucet.	\$3,000	\$0	NA	
278	Physics Building	082	4322W	Academic	Women's Toilet	Install blade-type handles or a single lever faucet.	\$3,000	\$0	NA	
279	Physics Building	082	1401	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
280	Physics Building	082	3125M	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
281	Physics Building	082	0205	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
282	Physics Building	082	0215	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
283	Physics Building	082	3315	Academic	Unisex Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (statndard stall).
284	Physics Building	082	4215	Academic	Unisex Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (statndard stall).
285	Physics Building	082	2125	Academic	Unisex Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (statndard stall).
286	Physics Building	082	2328	Academic	Unisex Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (statndard stall).
287	Physics Building	082	1318W	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
288	Plant Operations and Maintenance	006	0103	Non-Academic	Men's Toilet	Renovate to comply with 2010 Standards	\$89,000	\$0	NA	New Survey (end of row)
289	Plant Operations and Maintenance	006	1103A	Non-Academic	Women's Toilet	Renovate to comply with 2010 Standards	\$89,000	\$0	NA	New Survey (end of row)
290	Plant Operations and Maintenance	006	1103B	Non-Academic	Men's Toilet	Renovate to comply with 2010 Standards	\$89,000	\$0	NA	New Survey (end of row)

**ADA TRANSITION PLAN UPDATE 2020
RESTROOM UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
291	Plant Operations and Maintenance	006	1122	Non-Academic	Unisex Toilet	Renovate to comply with 2010 Standards	\$89,000	\$0	NA	New Survey (end of row)
292	Plant Operations and Maintenance	006	1124	Non-Academic	Unisex Toilet	Renovate to comply with 2010 Standards	\$89,000	\$0	NA	New Survey (end of row)
293	Plant Sciences Building	036	6105	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
294	Plant Sciences Building	036	6103	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (end of row)
295	Preinkert Hall	054	0103D	Academic	Men's locker room	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (no stall)
296	Preinkert Hall	054	1111	Academic	Men's Toilet	Renovate to comply with ADA	\$0	\$60,000	12/10/19	Completed 2020 Survey
297	Preinkert Hall	054	1118	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
298	School of Public Health	255	0130D	Academic	Men's locker room	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
299	School of Public Health	255	2331	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (end of row)
300	School of Public Health	255	3308	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
301	School of Public Health	255	1311	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
302	School of Public Health	255	1120B	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (end of row).
303	School of Public Health	255	0115	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
304	School of Public Health	255	2237	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	Standard stall (end of row)

ADA TRANSITION PLAN UPDATE 2020 RESTROOM UPGRADES

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
305	School of Public Health	255	1102	Academic	Restroom	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (standard stall).
306	School of Public Health	255	0126C	Academic	Women faculty Locker room	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (statndard stall).
307	School of Public Health	255	2335	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
308	School of Public Health	255	3304	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
309	School of Public Health	255	1309	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
310	School of Public Health	255	1234B	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
311	School of Public Health	255	1120A	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
312	School of Public Health	255	0109	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
313	Service Building	003	0108	Non-Academic	Women's Toilet	Renovate to comply with 2010 Standards	\$89,000	\$0	NA	New Survey
314	Service Building	003	0505	Non-Academic	Women's Toilet	Renovate to comply with 2010 Standards	\$89,000	\$0	NA	New Survey
315	Service Building	003	1303	Non-Academic	Women's Toilet	Renovate to comply with 2010 Standards	\$89,000	\$0	NA	New Survey
316	Service Building	003	1600G	Non-Academic	Women's Toilet	Renovate to comply with 2010 Standards	\$89,000	\$0	NA	New Survey
317	Service Building	003	2304	Non-Academic	Women's Toilet	Renovate to comply with 2010 Standards	\$89,000	\$0	NA	New Survey
318	Service Building	003	1600D	Non-Academic	Men's Toilet	Renovate to comply with 2010 Standards	\$89,000	\$0	NA	New Survey
319	Service Building	003	2303	Non-Academic	Men's Toilet	Renovate to comply with 2010 Standards	\$89,000	\$0	NA	New Survey

ADA TRANSITION PLAN UPDATE 2020 RESTROOM UPGRADES

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
320	Service Building	003	0600U	Non-Academic	Men's Toilet	Renovate to comply with 2010 Standards	\$89,000	\$0	NA	New Survey
321	Service Building	003	0110	Non-Academic	Men's Toilet	Renovate to comply with 2010 Standards	\$89,000	\$0	NA	New Survey
322	Service Building	003	0503	Non-Academic	Men's Toilet	Renovate to comply with 2010 Standards	\$89,000	\$0	NA	New Survey
323	Service Building	003	1305	Non-Academic	Men's Toilet	Renovate to comply with 2010 Standards	\$89,000	\$0	NA	New Survey
324	Shoemaker Building	037	0114 / 1204, 1206 / 0101.	Academic	Men's & Women's Toilet	Install automatic door openers to doors leading to Testing Room 0114 and Restrooms 1204, 1206, and 0101.	\$0	\$0	8/1/16	FY 2015 Access UMD Project
325	Skinner Building	044	1111WT	Academic	Women's Toilet	Lower towel dispenser/dryer.	\$2,000	\$0	NA	
326	Skinner Building	044	2107WT	Academic	Women's Toilet	Lower towel dispenser/dryer.	\$2,000	\$0	NA	
327	Skinner Building	044	3109	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (end of row)
328	Skinner Building	044	0111	Academic	Men's Toilet	Modify Men's Toilet Room (0111).	\$0	\$0	6/29/10	FY 2010 Access MD Project (\$12,529)
329	Susquehanna Hall (Cmpus Surge Bldg.)	233	1102A	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (standard stall).
330	Susquehanna Hall (Cmpus Surge Bldg.)	233	2102A	Academic	Men's Toilet	Renovate to comply with ADA	\$0	\$60,000	12/10/19	New survey (end of row) Completed 2020 Survey
331	Susquehanna Hall (Cmpus Surge Bldg.)	233	3104	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (standard stall).
332	Susquehanna Hall (Cmpus Surge Bldg.)	233	4102	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (standard stall).
333	Susquehanna Hall (Cmpus Surge Bldg.)	233	1106	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (end of row)

**ADA TRANSITION PLAN UPDATE 2020
RESTROOM UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
334	Susquehanna Hall (Cmpus Surge Bldg.)	233	2106	Academic	Women's Toilet	Renovate to comply with ADA	\$0	\$60,000	12/10/19	New survey (end of row) Completed 2020 Survey
335	Susquehanna Hall (Cmpus Surge Bldg.)	233	4106	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (end of row)
336	Symons Hall	076	1101MT	Academic	Men's Toilet	Install new urinal with elongated rim.	\$4,000	\$0	NA	
337	Symons Hall	076	1101MT	Academic	Men's Toilet	Lower towel dispenser/dryer.	\$2,000	\$0	NA	
338	Symons Hall	076	2101	Academic	Women's Toilet	Widen second door to women's toilet 0210, install automatic door opener to first door, and redesign space to provide ADA compliant stall.	\$0	\$28,000	12/10/18	FY 2016 Access UMD Project
339	Symons Hall	076	0203	Academic	Men's Toilet	Widen door to Men's Room 0203, install automatic door opener and redesign space to provide ADA compliant stall.	\$0	\$105,000	12/10/19	FY16 Access UMD project.
340	Symons Hall	076	0125 / 1203 1125 / 0202	Academic	Men's & Women's Toilet	Renovate toilet room 0125 Men's toilet and replace 3 water cooler next to rooms 1203, 1125 and 0202 to comply with ADA.	\$0	\$0	7/6/15	FY 2013 Access UMD Project
341	Symons Hall	076	2125	Academic	Men's Toilet	Widen 2nd door to restroom 2125MT, install automatic door opener to the 1st floor and redesign space to provide ADA compliant urinal.	\$0	\$0	8/23/13	FY14 Access UMD project.
342	Symons Hall	076	0103	Academic	Women's Toilet	Widen secod door to Women's Toilet 0103, Install automatic door opener to first door and redesign space to provide ADA compliant stall.	\$0	\$0	7/6/15	FY 2015 Access UMD Project

**ADA TRANSITION PLAN UPDATE 2020
RESTROOM UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
343	Taliaferro Hall	043	2153	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (end of row).
344	Taliaferro Hall	043	3105	Academic	Unisex Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (end of row).
345	Taliaferro Hall	043	0127	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (end of row)
346	Taliaferro Hall	043	0106	Academic	Women's Toilet	Install infant changing station.	\$4,000	\$0	NA	New Survey 2016
347	Taliaferro Hall	043	1129	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey 2016
348	Taliaferro Hall	043	0104 / 0106 1129 / 1127	Academic	Men's & Women's Toilet & Water Coolers	Modify men's (0104) and women's (0106) toilet rooms and replace water cooler; adjust fixtures in toilet rooms 1129 (women's) and 1127 (men's).	\$0	\$0	7/30/12	FY12 Access UMD project (\$27,000)
349	Tawes Hall	141	1st Floor	Academic	Women's Toilet	Install auto door openers	\$9,000	\$0	NA	
350	Tawes Hall	141	3212	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
351	Technology Ventures Building	806	1110	Academic	Restroom	Renovate women's and men's restroom 1110 to comply with ADA.	\$89,000	\$0	NA	New survey
352	Technology Ventures Building	806	1114	Academic	Restroom	Renovate women's and men's restroom 1114 to comply with ADA.	\$89,000	\$0	NA	New survey
353	Turner Hall	079	3113	Administrative	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (end of row).
354	Turner Hall	079	2101P	Administrative	Unisex Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
355	Turner Hall	079	3111	Administrative	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (end of row)
356	Tydings Hall	042	0105	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (end of row).

ADA TRANSITION PLAN UPDATE 2020 RESTROOM UPGRADES

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
357	Tydings Hall	042	3124	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (end of row).
358	Tydings Hall	042	3131	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
359	Tydings Hall	042	1124	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey 2016
360	Tydings Hall	042	1131A	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey 2016
361	Tydings Hall	042	4126A	Academic	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey 2016
362	Tydings Hall	042	4125	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey 2016
363	Tydings Hall	042	0125 / 2132; 0105 / 2125	Academic	Men's & Women's Toilet	Modify women's toilet rooms 0125 and 2132 and men's toilet rooms 0105 and 2125.	\$0	\$0	6/29/15	FY 2013 Access MD Project
364	Wind Tunnel Building	081	2105B	Academic	Men's Toilet	Install new urinal with elongated rim.	\$4,000	\$0	NA	
365	Wind Tunnel Building	081	1105MT	Academic	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (end of row)
366	Woods Hall	047	0114 / 0117 / 1114 / 1134 / 1135	Academic	Men's & Women's Toilet	Modify men's (0114) and women's (0117) toilet rooms; widen classroom door (1114) and replace faucet handles in men's and women's toilet rooms (1134 and 1135).	\$0	\$0	7/30/12	FY 2012 Access MD Project (\$26,620)
						SUB-TOTAL STATE SUPPORTED	\$24,211,000	\$1,271,600		

ADA TRANSITION PLAN UPDATE 2020 RESTROOM UPGRADES

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
1	Annapolis Hall	008	1103MT	Auxiliary-Residence Hall Central Offices	Men's Toilet	Install blade-type handles or install single lever faucet.	\$3,000	\$0	NA	
2	Annapolis Hall	008	0101E	Auxiliary-Residence Hall Central Offices	Unisex Toilet	Install blade-type handles or install single lever faucet.	\$3,000	\$0	NA	
3	Annapolis Hall	008	0101E	Auxiliary-Residence Hall Central Offices	Unisex Toilet	Lower towel dispenser.	\$2,000	\$0	NA	
4	Annapolis Hall	008	0102P	Auxiliary-Residence Hall Central Offices	Unisex Toilet	Install blade-type handles or install single lever faucet.	\$3,000	\$0	NA	
5	Annapolis Hall	008	0102P	Auxiliary-Residence Hall Central Offices	Unisex Toilet	Lower towel dispenser.	\$2,000	\$0	NA	
6	Annapolis Hall	008	1104WT	Auxiliary-Residence Hall Central Offices	Women's Toilet	Install blade-type handles or install single lever faucet.	\$3,000	\$0	NA	
7	Anne Arundel Hall	060	1110	Auxiliary-Residence Hall Honors and Humanities	Toilet Room	Increase width of knee space to be min. 30 in.	\$4,000	\$0	NA	
8	Anne Arundel Hall	060	1110	Auxiliary-Residence Hall Honors and Humanities	Toilet Room	Provide lower mirror at lavatory1 sink counter.	\$4,000	\$0	NA	
9	Aquatics Center	399	1202	Auxiliary-Recreation	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (end of row).
10	Byrd Concessions	364	1100MT	Auxiliary-ICA	Men's Toilet	Install new urinal with elongated rim.	\$4,000	\$0	NA	
11	Centreville Hall	098	1114	Auxiliary-Residence Hall College Park Scholars	Toilet Room	Install blade-type handles or install single lever faucet.	\$3,000	\$0	NA	
12	Elkton Hall	254	End-Suite	Auxiliary-Residence Hall	Toilet Room	Renovate to provide accessible tlt. rm. w/ bathing facilities.	\$177,000	\$0	NA	New Survey 2016
13	Ellicott Area Dining Hall	257	1136	Auxiliary - Dining	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).

**ADA TRANSITION PLAN UPDATE 2020
RESTROOM UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
14	Ellicott Area Dining Hall	257	1105	Auxiliary - Dining	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
15	Ellicott Area Dining Hall	257	1135	Auxiliary - Dining	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
16	Golf Course Club House	166	C0120	Auxiliary - Golf Course	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey. Standard stall.
17	Golf Course Club House	166	0106	Auxiliary - Golf Course	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey. Standard stall. End of row.
18	Harford Hall	014	Suite 0112	Auxiliary-Residence Hall	Toilet Room	Renovate to provide accessible tlt. rm. w/ bathing facilities.	\$206,000	\$0	NA	New Survey 2016
19	Harford Hall	014	Suite 0114	Auxiliary-Residence Hall	Toilet Room	Renovate to provide accessible tlt. rm. w/ bathing facilities.	\$206,000	\$0	NA	New Survey 2016
20	House 1 (Kappa Alpha Fraternity)	126	1104	Auxiliary-Fraternity / Sorority Row Houses	Toilet Room	Renovate to provide accessible tlt. rm. w/ bathing facilities.	\$89,000	\$0	NA	
21	House 1 (Kappa Alpha Fraternity)	126	0104	Auxiliary-Fraternity / Sorority Row Houses	Toilet Room	Renovate to provide accessible tlt. rm. w/ bathing facilities.	\$89,000	\$0	NA	
22	House 10	135		Auxiliary-Fraternity / Sorority Row Houses	Toilet Room	Renovate to provide accessible tlt. rm. w/ bathing facilities.	\$89,000	\$0	NA	New Survey 2016
23	House 11	136		Auxiliary-Fraternity / Sorority Row Houses	Toilet Room	Renovate to provide accessible tlt. rm. w/ bathing facilities.	\$89,000	\$0	NA	New Survey 2016
24	House 12	137		Auxiliary-Fraternity / Sorority Row Houses	Toilet Room	Renovate to provide accessible tlt. rm. w/ bathing facilities.	\$89,000	\$0	NA	New Survey 2016
25	House 13 (Zeta Psi Fraternity)	138	0102	Auxiliary-Fraternity / Sorority Row Houses	Toilet Room	Renovate to provide accessible toilet room.	\$89,000	\$0	NA	
26	House 13 (Zeta Psi Fraternity)	138	1102	Auxiliary-Fraternity / Sorority Row Houses	Toilet Room	Renovate to provide accessible tlt. Rm. w/ bathing facilities.	\$89,000	\$0	NA	
27	House 14 (Sigma Chi)	139	1102	Auxiliary-Fraternity / Sorority Row Houses	Toilet Room	Renovate to provide accessible tlt. rm. w/ bathing facilities.	\$89,000	\$0	NA	

ADA TRANSITION PLAN UPDATE 2020 RESTROOM UPGRADES

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
28	House 14 (Sigma Chi)	139	0103A	Auxiliary-Fraternity / Sorority Row Houses	Toilet Room	Renovate to provide accessible tlt. rm. w/ bathing facilities.	\$89,000	\$0	NA	
29	House 2 (Pi Kappa Alpha Fraternity)	127	1100	Auxiliary-Fraternity / Sorority Row Houses	Toilet Room	Renovate to provide accessible tlt. rm. w/ bathing facilities.	\$89,000	\$0	NA	
30	House 3 (Tau Kappa Epsilon Fraternity)	128	1102	Auxiliary-Fraternity / Sorority Row Houses	Toilet Room	Renovate to provide accessible tlt. Rm. w/ bathing facilities.	\$89,000	\$0	NA	
31	House 4 (Alpha Epsilon Pi Fraternity)	129	1102	Auxiliary-Fraternity / Sorority Row Houses	Toilet Room	Renovate to provide accessible Rm. w/ bathing facilities.	\$89,000	\$0	NA	
32	House 5 (Phi Kappa Tau Fraternity)	130	0103A	Auxiliary-Fraternity / Sorority Row Houses	Toilet Room	Renovate to provide accessible tlt. rm. & laundry facilities.	\$89,000	\$0	NA	
33	House 5 (Phi Kappa Tau Fraternity)	130	1102	Auxiliary-Fraternity / Sorority Row Houses	Toilet Room	Renovate to provide accessible tlt. rm. w/ bathing facilities.	\$89,000	\$0	NA	
34	House 6 (Delta Chi Fraternity)	131	0103A	Auxiliary-Fraternity / Sorority Row Houses	Toilet Room	Renovate to provide accessible tlt. Rm. & laundry facilities.	\$89,000	\$0	NA	
35	House 6 (Delta Chi Fraternity)	131	1102	Auxiliary-Fraternity / Sorority Row Houses	Toilet Room	Renovate to provide accessible tlt. Rm. w/ bathing facilities.	\$89,000	\$0	NA	
36	House 7 (Lamda Chi Alpha Fraternity)	132	1102	Auxiliary-Fraternity / Sorority Row Houses	Toilet Room	Renovate to provide accessible tlt. Rm. w/ bathing facilities.	\$89,000	\$0	NA	
37	House 8	133		Auxiliary-Fraternity / Sorority Row Houses	Toilet Room	Renovate to provide accessible tlt. rm. w/ bathing facilities.	\$89,000	\$0	NA	New Survey 2016
38	House 9	134		Auxiliary-Fraternity / Sorority Row Houses	Toilet Room	Renovate to provide accessible tlt. rm. w/ bathing facilities.	\$89,000	\$0	NA	New Survey 2016
39	Kehoe Track at Ludwig Field	388	1101	Auxiliary-ICA	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
40	Leonardtown Office Building	201	1201/3	Auxiliary-Central Offices	Toilet Room	Renovate to provide fully accessible unisex tlt. rm.	\$89,000	\$0	NA	

ADA TRANSITION PLAN UPDATE 2020 RESTROOM UPGRADES

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
41	New Leonardtown	249	Suite 249-1	Auxiliary-Residence Hall	Toilet Room	Renovate to provide accessible tlt. rm. w/ bathing facilities.	\$200,000	\$0	NA	New Survey 2016
42	New Leonardtown	248	Suite 249-6	Auxiliary-Residence Hall	Toilet Room	Renovate to provide accessible tlt. rm. w/ bathing facilities.	\$118,000	\$0	NA	New Survey 2016
43	Reckord Armory	078	BLDG	Auxiliary	Toilet Room - First Floor	Provide accessible restrooms on 1st floor for CRS	\$89,000	\$0	NA	
44	Reckord Armory	078	0123	Auxiliary	Women's Toilet	Lower towel dispenser.	\$2,000	\$0	NA	
45	Reckord Armory	078	0111	Auxiliary	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (Standard stall).
46	Reckord Armory	078	2117	Auxiliary	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	Standard stall (end of row)
47	Reckord Armory	078	2115	Auxiliary	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (end of row)
48	Reckord Armory	078	0111	Auxiliary	Restroom	Demolish existing urinal and re-configure stall partition (0111), and replace water cooler in corridor.	\$0	\$0	2/17/11	FY 2011 Access UMD Project (\$9,213)
49	Regents Drive Parking Garage (formerly PG 2)	202	0120MT	Auxiliary-Campus Parking	Men's Toilet	Increase knee space height to 29 in. min.	\$4,000	\$0	NA	
50	Regents Drive Parking Garage (formerly PG 2)	202	0120MT	Auxiliary-Campus Parking	Men's Toilet	Install new urinal with elongated rim	\$4,000	\$0	NA	
51	Regents Drive Parking Garage (formerly PG 2)	202	0124WT	Auxiliary-Campus Parking	Women's Toilet	Increase knee space height to 29 in. min.	\$4,000	\$0	NA	
52	Regents Drive Parking Garage (formerly PG 2)	202	0124WT	Auxiliary-Campus Parking	Women's Toilet	Lower towel dispenser/dryer	\$2,000	\$0	NA	
53	Regents Drive Parking Garage (formerly PG 2)	202	0200G	Auxiliary-Campus Parking	Men's Toilet	Install 36-in. long grab bar on wall behind fixture.	\$3,000	\$0	NA	
54	Regents Drive Parking Garage (formerly PG 2)	202	0200G	Auxiliary-Campus Parking	Men's Toilet	Lower towel dispenser/dryer.	\$2,000	\$0	NA	

ADA TRANSITION PLAN UPDATE 2020 RESTROOM UPGRADES

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
55	Regents Drive Parking Garage (formerly PG 2)	202	0200G	Auxiliary-Campus Parking	Men's Toilet	Install new urinal with elongated rim.	\$4,000	\$0	NA	
56	Regents Drive Parking Garage (formerly PG 2)	202	0120MT	Auxiliary-Campus Parking	Men's Toilet	Provide accessible door hardware.	\$3,000	\$0	NA	
57	Regents Drive Parking Garage (formerly PG 2)	202	0120MT	Auxiliary-Campus Parking	Men's Toilet	Lower towel dispenser/dryer.	\$2,000	\$0	NA	
58	Regents Drive Parking Garage (formerly PG 2)	202	0200J	Auxiliary-Campus Parking	Women's Toilet	Install 36-in. long grab bar on wall behind fixture.	\$2,000	\$0	NA	
59	Regents Drive Parking Garage (formerly PG 2)	202	0200J	Auxiliary-Campus Parking	Women's Toilet	Lower towel dispenser/dryer.	\$2,000	\$0	NA	
60	Regents Drive Parking Garage (formerly PG 2)	202	0124WT	Auxiliary-Campus Parking	Women's Toilet	Provide accessible door hardware.	\$3,000	\$0	NA	
61	Regents Drive Parking Garage (formerly PG 2)	202	0124WT	Auxiliary-Campus Parking	Women's Toilet	Lower towel dispenser/dryer.	\$2,000	\$0	NA	
62	Regents Drive Parking Garage (formerly PG 2)	202	0200J	Auxiliary-Campus Parking	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (end of row).
63	Regents Drive Parking Garage (formerly PG 2)	202	0504CWT	Auxiliary-Campus Parking	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (end of row).
64	Ritchie Coliseum	004	0105	Auxiliary-Recreation	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (end of row)
65	Ritchie Coliseum	004	2104	Auxiliary-Recreation	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (end of row)
66	Ritchie Coliseum	004	0104	Auxiliary-Recreation	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (end of row)
67	Ritchie Coliseum	004	2103	Auxiliary-Recreation	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (end of row)
68	Shipley Field	159	BLDG	Auxiliary-ICA	Men's Toilet	Provide an accessible restroom	\$89,000	\$0	NA	

ADA TRANSITION PLAN UPDATE 2020 RESTROOM UPGRADES

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
69	South Campus Dining Hall	026	2103	Auxiliary-Dining	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey, 2016
70	South Campus Dining Hall	026	2105	Auxiliary-Dining	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey, 2016
71	South Campus Dining Hall	026	2147	Auxiliary-Dining	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey, 2016
72	South Campus Dining Hall	026	2145	Auxiliary-Dining	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey, 2016
73	South Campus Dining Hall	026	1126	Auxiliary-Dining	Men's Toilet /Locker Room	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey, 2016
74	South Campus Dining Hall	026	1128	Auxiliary-Dining	Women's Toilet /Locker Room	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey, 2016
75	St. Mary's Hall	062	0109	Auxiliary-Residence Hall Language House	Men's Toilet	Install new urinal with elongated rim.	\$4,000	\$0	NA	
76	St. Mary's Hall	062	0108	Auxiliary-Residence Hall Language House	Men's Toilet	Install full-length mirror, or lower existing.	\$2,000	\$0	NA	
77	Stamp Student Union	163	2206	Auxiliary-Stamp Student Union	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (standard stall).
78	Tyser Tower	361	5131	Auxiliary-ICA	Women's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New survey (end of row)
79	Varsity Sports Teamhouse	158	1105	Auxiliary-ICA	Men's Toilet	Install blade-type handles or single lever faucet.	\$3,000	\$0	NA	
80	Varsity Sports Teamhouse	158	1118	Auxiliary-ICA	Men's Toilet	Install blade-type handles or single lever faucet.	\$3,000	\$0	NA	
81	Varsity Sports Teamhouse	158	1118	Auxiliary-ICA	Men's Toilet	Lower towel dispenser/dryer.	\$2,000	\$0	NA	
82	Varsity Sports Teamhouse	158	0110	Auxiliary-ICA	Women's Toilet	Relocate door next to room 0110 at Varsity Team House to provide access to the women's restroom.	\$0	\$0	12/2/12	Operation & Maintenance (\$3,586)
83	Washington Hall	023	Suite 1105	Auxiliary-Residence Hall	Toilet Room	Renovate to provide accessible tlt. rm. w/ bathing facilities.	\$177,000	\$0	NA	New Survey 2016

**ADA TRANSITION PLAN UPDATE 2020
RESTROOM UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
84	Washington Hall	023	Suite 1111	Auxiliary-Residence Hall	Toilet Room	Renovate to provide accessible tlt. rm. w/ bathing facilities.	\$177,000	\$0	NA	New Survey 2016
85	Women's Softball Stadium	409	1106	Auxiliary-ICA	Men's Toilet	Renovate to comply with ADA	\$89,000	\$0	NA	New Survey (end of row)
						SUB-TOTAL AUXILIARY	\$5,528,000	\$0		
						TOTAL STATE-SUPPORTED AND AUXILIARY	\$29,739,000	\$1,271,600		

LIST OF ENHANCEMENTS TO PROGRAMMATIC ACCESSIBILITY

SITE UPGRADES

**ADA TRANSITION PLAN UPDATE 2020
SITE UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
1	Astronomy Observatory	221	1101	Academic	Ramp	Rebuild ramp with slope <=4.76 deg.	\$76,000	\$0	NA	
2	Atlantic Building (formerly Computer and Space Sciences Building)	224	NA	Academic	Accessible Sidewalk	Rebuild new 23 foot accessible sidewalk by the north-east corner of Parking Lot Q.	\$0	\$0	1/30/11	FY 2011 Access UMD Project (\$7,205)
3	Biology-Psychology Building	144	1299	Academic	Ramp	Instal ramp next to stairs 1299 (stairs level change).	\$71,000	\$0	NA	New Survey 2016
4	Center for Young Children	381	SITE	Academic	Ramp (Curb Ramp)	Rebuild curb ramps to eliminate uneven joints and to make bottom landing flat and flush with parking lot surface	\$22,000	\$0	NA	
5	Center for Young Children	381	SITE	Academic	Ramp (Sidewalks)	Rebuild walks as required to eliminate unven joints.	\$22,000	\$0	NA	
6	Chemistry Building	091	BLDG	Academic	Ramp	Install ramp in front of Chem Library	\$71,000	\$0	NA	Installed signes to direct peple to accessible entrance, no need for ramp.
7	Chincoteague Hall (formerly Journalism Building)	059		Academic	Ramp	Install accessible ramp.	\$0	\$0	11/11/11	FY 2011 Access UMD Project (\$75,000)
8	Engineering Research Building (formerly Engineering Annex)	093	NE0307	Academic	Ramp	Rebuild ramp and add handrails.	\$71,000	\$0	NA	
9	Jull Hall	227	1197	Academic	Ramp	Install missing handrail(s).	\$11,000	\$0	NA	
10	Jull Hall	227	1198	Academic	Ramp	Install missing handrail(s).	\$11,000	\$0	NA	
11	Lee Building	071	BLDG	Administrative	Ramp - Ground Floor	Provide accessible entrance to rear ground level	\$71,000	\$0	NA	
12	Lefrak Hall	038		Academic	Ramp	Rebuild ramp with 1/12 inch slope or less or install lift at corner of room 0295 / 0296.	\$71,000	\$0	NA	New survey 2016

**ADA TRANSITION PLAN UPDATE 2020
SITE UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
13	Morrill Hall	040	EE1198	Academic	Ramp	Install exterior ramp in front of entrance.	\$71,000	\$0	NA	
14	Physics Building	082	2323	Academic	Ramp (Stairway)	Replace existing handrail(s) with new handrail(s).	\$11,000	\$0	NA	
15	Rosshoroug Inn	080		Administrative	Sidewalk	Rebuild walkway/sidewalk to comply with ADA and improve drainage, etc.	\$0	\$10,000	12/10/17	New Survey, 2016 Operation & Maintenance (Part of larger Capital Project)
16	Skinner Building	044	0197	Academic	Ramp	Install missing handrails.	\$11,000	\$0	NA	
17	Susquahanna Hall	233	Site	Academic	Ramp, handrail, curb cuts & sidewalk	Install ramp, handrails, & curb cuts on Susquahanna Hall- Garret Hall pathway	\$96,000	\$0	NA	
18	Turner Hall	079	SE1199	Administrative	Ramp	Install exterior ramp in front of entrance.	\$71,000	\$0	NA	
19	Tydings Hall	042		Academic	Handrailing	Install ADA compliant handrailing at north entrance.	\$0	\$0	6/1/12	FY 2011 Access UMD Project (\$7,249)
						SUB-TOTAL STATE-SUPPORTED	\$757,000	\$10,000		

**ADA TRANSITION PLAN UPDATE 2020
SITE UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
1	Centreville Hall	098	WE1190	Auxiliary-Residence Hall College Park Scholars	Ramp	Reset handrail height between 34 - 38 in. AFF.	\$5,000	\$0	NA	
2	House 1 (Kappa Alpha Fraternity)	126	EE0105	Auxiliary-Fraternity / Sorority Row Houses	Ramp	Install exterior ramp/wheelchair lift at main entrance.	\$118,000	\$0	NA	
3	House 1 (Kappa Alpha Fraternity)	126	SE1109	Auxiliary-Fraternity / Sorority Row Houses	Wheelchair lift /ramp	Install exterior ramp or lift at entrance.	\$71,000	\$0	NA	
4	House 13 (Zeta Psi Fraternity)	138	EE0105	Auxiliary-Fraternity / Sorority Row Houses	Ramp	Install exterior ramp/wheelchair lift at main entrance.	\$118,000	\$0	NA	
5	House 13 (Zeta Psi Fraternity)	138	SE1192	Auxiliary-Fraternity / Sorority Row Houses	Wheelchair lift /ramp	Install exterior ramp or lift at entrance.	\$71,000	\$0	NA	
6	House 14 (Zeta Beta Tau Fraternity)	139	WE0105	Auxiliary-Fraternity / Sorority Row Houses	Ramp	Install exterior ramp/wheelchair lift at main entrance.	\$118,000	\$0	NA	
7	House 14 (Zeta Beta Tau Fraternity)	139	NE1199	Auxiliary-Fraternity / Sorority Row Houses	Wheelchair lift /ramp	Install exterior ramp or lift at entrance.	\$71,000	\$0	NA	
8	House 2 (Pi Kappa Alpha Fraternity)	127	NE0102	Auxiliary-Fraternity / Sorority Row Houses	Ramp	Install exterior ramp/wheelchair lift at main entrance.	\$118,000	\$0	NA	
9	House 2 (Pi Kappa Alpha Fraternity)	127	SE1195	Auxiliary-Fraternity / Sorority Row Houses	Wheelchair lift /ramp	Install exterior ramp or lift at entrance.	\$71,000	\$0	NA	
10	House 3 (Tau Kappa Epsilon Fraternity)	128	NE0102	Auxiliary-Fraternity / Sorority Row Houses	Ramp	Install exterior ramp/wheelchair lift at main entrance.	\$118,000	\$0	NA	
11	House 3 (Tau Kappa Epsilon Fraternity)	128	SE1198	Auxiliary-Fraternity / Sorority Row Houses	Wheelchair lift /ramp	Install exterior ramp or lift at entrance.	\$71,000	\$0	NA	
12	House 4 (Alpha Epsilon Pi Fraternity)	129	NE0101	Auxiliary-Fraternity / Sorority Row Houses	Ramp	Install exterior ramp/wheelchair lift at main entrance.	\$118,000	\$0	NA	
13	House 4 (Alpha Epsilon Pi Fraternity)	129	SE1198	Auxiliary-Fraternity / Sorority Row Houses	Wheelchair lift /ramp	Install exterior ramp or lift at entrance.	\$71,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
SITE UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
14	House 5 (Phi Kappa Tau Fraternity)	130	NE0102	Auxiliary-Fraternity / Sorority Row Houses	Ramp	Install exterior ramp/wheelchair lift at main entrance.	\$118,000	\$0	NA	
15	House 5 (Phi Kappa Tau Fraternity)	130	SE1198	Auxiliary-Fraternity / Sorority Row Houses	Wheelchair lift /ramp	Install exterior ramp or lift at entrance.	\$71,000	\$0	NA	
16	House 6 (Delta Chi Fraternity)	131	NE0102	Auxiliary-Fraternity / Sorority Row Houses	Ramp	Install exterior ramp/wheelchair lift at main entrance.	\$118,000	\$0	NA	
17	House 6 (Delta Chi Fraternity)	131	SE1198	Auxiliary-Fraternity / Sorority Row Houses	Wheelchair lift /ramp	Install exterior ramp or lift at entrance.	\$71,000	\$0	NA	
18	House 7 (Lamda Chi Alpha Fraternity)	132	Entrance	Auxiliary-Fraternity / Sorority Row Houses	Ramp	Install exterior ramp/wheelchair lift at main entrance.	\$118,000	\$0	NA	
19	House 7 (Lamda Chi Alpha Fraternity)	132	NE0101	Auxiliary-Fraternity / Sorority Row Houses	Wheelchair lift /ramp	Install exterior ramp or lift at entrance.	\$71,000	\$0	NA	
20	Leonardtown Office Building	201	NE1294	Auxiliary-Central Offices	Ramp (Curb Ramp)	Rebuild ramp with 1/12 slope or less.	\$63,000	\$0	NA	
21	Reckord Armory	078	BLDG	Auxiliary	Ramp - First Floor	Provide accessible entrance to 1st floor.	\$63,000	\$0	NA	
22	Regents Drive Parking Garage	202	NA	Auxiliary - Campus Parking	Sidewalk & Accessible Parking	Install accessible sidewalk on the SE side of the garage-leading from sidewalk into the garage; provide accessible parking and signs on the 3rd floor near the bridge to Hornbake Plaza.	\$0	\$0	8/1/13	Project Funded by UMD DOT
23	South Campus Dining Hall	026	1182	Auxiliary-Dining	Ramp	Install ramp or lift to comply with ADA.	\$71,000	\$0	NA	New Survey, 2016
24	South Campus Dining Hall	026	2197	Auxiliary-Dining	Ramp	Install ramp or lift to comply with ADA.	\$71,000	\$0	NA	New Survey, 2016

**ADA TRANSITION PLAN UPDATE 2020
SITE UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
25	St. Mary's Hall	062	NE1199	Auxiliary-Residence Hall Language House	Ramp	Install missing handrails.	\$11,000	\$0	NA	
26	Union Drive	NA	LOT Z	Auxiliary - Campus Parking	Curb Cut	Install one curb cut on Union Drive next to the accessible parking spaces on Lot Z (Adjacent to Knight Hall)	\$0	\$0	7/30/12	FY 2012 Access UMD Project (\$1,200)
27	Union Lane	NA	NA	Auxiliary - Campus Parking	Curb Cut	Install one curb cut at Union Lane (on the west side, about 20' from the intersection with Campus Drive.	\$0	\$0	5/9/10	FY 2012 Access UMD Project (\$1,000)
28	Varsity Team House	158	BLDG	Auxiliary-ICA	Curb Cut	Install one curb cut on Stadium Drive next to Varsity Team Houses on North Campus.	\$0	\$3,800	12/10/17	New Survey, 2016
29	Varsity Team House	158	BLDG	Auxiliary-ICA	Ramp	Install ramp connecting front entrance to parking lot	\$71,000	\$0	NA	
						SUB-TOTAL AUXILIARY	\$2,056,000	\$3,800		
						TOTAL STATE-SUPPORTED AND AUXILIARY	\$2,813,000	\$13,800		

LIST OF ENHANCEMENTS TO PROGRAMMATIC ACCESSIBILITY

OTHER UPGRADES

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
1	4-H Headquarters	800	BLDG	Non-Academic General	Bldg Signage	Install info. signs w/ raised contrast. color letters.	\$16,000	\$0	NA	
2	4-H Headquarters	800	BLDG	Non-Academic General	Bldg Signage	Install signs adj. to doors between 54 - 60 in. above finish floor (AFF).	\$16,000	\$0	NA	
3	A. V. Williams Building	115	BLDG	Academic	Bldg. Signs	Install signs with raised contrasting symbols.	\$16,000	\$0	NA	
4	A. V. Williams Building	115	Next to room 2306	Academic	Hallway	Raise water cooler to comply with ADA	\$4,000	\$0	NA	
5	A. V. Williams Building	115	Next to room 2424	Academic	Hallway	Raise water cooler to comply with ADA	\$4,000	\$0	NA	
6	A. V. Williams Building	115	2448	Academic	Visual Alarms	Remount visual alarms at correct height.	\$4,000	\$0	NA	
7	A. V. Williams Building	115	1360	Academic	Class lab	Replace door knob with lever	\$3,000	\$0	NA	
8	A. V. Williams Building	115	2358	Academic	Lab	Replace door knob with lever	\$3,000	\$0	NA	
9	A. V. Williams Building	115	4424	Academic	Seminar Room	Replace door knob with lever	\$3,000	\$0	NA	
10	Anacostia Building (formerly North Campus Office Annex)	332	0102	Academic	Manual door/opng.	Replace door to provide 32 in. min. cl. opng.	\$6,000	\$0	NA	
11	Anacostia Building (formerly North Campus Office Annex)	332	0202	Academic	Manual door/opng.	Replace door to provide 32 in. min. cl. opng.	\$6,000	\$0	NA	
12	Anacostia Building (formerly North Campus Office Annex)	332	0302	Academic	Manual door/opng.	Replace door to provide 32 in. min. cl. opng.	\$6,000	\$0	NA	
13	Anacostia Building (formerly North Campus Office Annex)	332	0199	Academic	Manual door/opng.	Replace door to provide 32 in. min. cl. opng.	\$5,000	\$0	NA	
14	Anacostia Building (formerly North Campus Office Annex)	332	0200A	Academic	Manual door/opng.	Replace door to provide 32 in. min. cl. opng.	\$6,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
15	Animal Science/Agriculture Engineering Building	142	Next to room 1150	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
16	Animal Science/Agriculture Engineering Building	142	Next to room 0422	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
17	Animal Science/Agriculture Engineering Building	142	Adjacent to room 0517	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
18	Animal Science/Agriculture Engineering Building	142	Adjacent to room 4141	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
19	Animal Science/Agriculture Engineering Building	142	Next to room 0536	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
20	Animal Science/Agriculture Engineering Building	142	Next to room 2142	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
21	Animal Science/Agriculture Engineering Building	142	Next to room 3140	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
22	Animal Sciences / Agricultural Engineering Building	142	1144	Academic	Fixed Work Area	Install controls which do not require tight grasp/twist.	\$4,000	\$0	NA	
23	Animal Sciences / Agricultural Engineering Building	142	1150	Academic	Fixed Work Area	Install controls which do not require tight grasp/twist.	\$4,000	\$0	NA	
24	Animal Sciences / Agricultural Engineering Building	142	2142	Academic	Fumehood - Fixed Work Area	Install controls which do not require tight grasp/twist.	\$4,000	\$0	NA	
25	Animal Sciences / Agricultural Engineering Building	142	2142	Academic	Fume Hood	Install hood controls that do not require tight grasp/twist.	\$4,000	\$0	NA	
26	Animal Sciences / Agricultural Engineering Building	142	1150A	Academic	Fume Hood	Install hood controls which do not require tight grasp/twist.	\$4,000	\$0	NA	
27	Animal Sciences / Agricultural Engineering Building	142	0116	Academic	Manual door/opng.	Install lever or other accessible hardware.	\$3,000	\$0	NA	
28	Animal Sciences / Agricultural Engineering Building	142	1140	Academic	Manual door/opng.	Install lever or other accessible hardware.	\$3,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
29	Animal Sciences / Agricultural Engineering Building	142	1150	Academic	Manual door/opng.	Install lever or other accessible hardware.	\$3,000	\$0	NA	
30	Animal Sciences / Agricultural Engineering Building	142	3105	Academic	Manual door/opng.	Install lever or other accessible hardware.	\$3,000	\$0	NA	
31	Animal Sciences / Agricultural Engineering Building	142	2142	Academic	Fume Hood	Lower ht. of hood cabinet to be between 28 to 34 in. AFF.	\$3,000	\$0	NA	
32	Animal Sciences / Agricultural Engineering Building	142	0402	Academic	Seminar room	Replace door knob with lever	\$3,000	\$0	NA	
33	Animal Sciences / Agricultural Engineering Building	142	0404	Academic	Seminar room	Replace door knob with lever	\$3,000	\$0	NA	
34	Animal Sciences / Agricultural Engineering Building	142	1140	Academic	Manual door/opng.	Replace door to provide min. 32 in. cl. opng.	\$6,000	\$0	NA	
35	Animal Sciences / Agricultural Engineering Building	142	4130	Academic	Manual door/opng.	Replace door to provide min. 32 in. cl. opng.	\$6,000	\$0	NA	
36	Animal Sciences / Agricultural Engineering Building	142	1144	Academic	Class lab	Widen doors and replace door knob to lever	\$6,000	\$0	NA	
37	Animal Sciences / Agricultural Engineering Building	142	1150	Academic	Class lab	Widen doors and replace door knob with lever	\$6,000	\$0	NA	
38	Arboretum Outreach Center	156	BLDG	Administrative	Bldg Signage	Install info. signs w/ raised contrast. color letters.	\$16,000	\$0	NA	
39	Arboretum Outreach Center	156	1105	Non-Academic	Class l ab	Replace door knob with lever	\$3,000	\$0	NA	
40	Architecture Building	145	1107	Academic	computer l ab	Replace door knob with lever	\$3,000	\$0	NA	
41	Architecture Building	145	1117	Academic	Class lab	Replace door knob with lever	\$3,000	\$0	NA	
42	Architecture Building	145	1125	Academic	seminar room	Replace door knob with lever	\$3,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
43	Architecture Building	145	1102A	Academic	Study room	Replace door knob with lever	\$3,000	\$0	NA	
44	Architecture Building	145	Adjacent to room 0111	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
45	Architecture Building	145	Adjacent to room 1107	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
46	Architecture Building	145	Adjacent to room 1115	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
47	Architecture Building	145	Next to room 0216	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
48	Architecture Building	145	next to room 1202	Academic	Hallway	Replace non-ADA water cooler	\$5,000	\$0	NA	
49	Architecture Building	145	0110	Academic	Lab	Widen door and replace door knob with lever	\$6,000	\$0	NA	
50	Architecture Building	145	0101	Academic	Class lab	Widen door to comply with ADA	\$6,000	\$0	NA	
51	Architecture Building	145	0204	Academic	Lecture room	Widen door to comply with ADA	\$6,000	\$0	NA	
52	Architecture Building	145	0102	Academic	Class lab	Widen doors and replace door knob with lever	\$6,000	\$0	NA	
53	Art - Sociology Building	146	Next to room 1307	Academic	Hallway	Raise water cooler to Comply with ADA	\$3,000	\$0	NA	
54	Art - Sociology Building	146	Next to room 2314	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
55	Art - Sociology Building	146	Next to room 3318	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
56	Art - Sociology Building	146	Next to room 1115	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
57	Art-Sociology Building	146	NA	Academic	Hallway	Install automatic door opener to double doors in the hallway between bldg wings.	\$10,000	\$0	NA	New Survey, 2013

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
58	Art-Sociology Building	146	1303 / 1399	Academic	Auto Door Opener	Install automatic door opener, one each, to toilet room 1303 door, and to one door in the pair of doors in corridor 1399.	\$0	\$0	00/00/00	FY 2010 Access UMD Project (\$7,970)
59	Art-Sociology Building	146	1117	Academic	lab	Replace door knob with lever	\$3,000	\$0	NA	
60	Art-Sociology Building	146	1310	Academic	lab	Replace door knob with lever	\$3,000	\$0	NA	
61	Art-Sociology Building	146	1311	Academic	lab	Replace door knob with lever	\$3,000	\$0	NA	
62	Art-Sociology Building	146	1314	Academic	Lab	Replace door knob with lever	\$3,000	\$0	NA	
63	Art-Sociology Building	146	1317	Academic	lab	Replace door knob with lever	\$3,000	\$0	NA	
64	Art-Sociology Building	146	2311	Academic	Lab	Replace door knob with lever	\$3,000	\$0	NA	
65	Art-Sociology Building	146	2314	Academic	lab	Replace door knob with lever	\$3,000	\$0	NA	
66	Art-Sociology Building	146	2317	Academic	Lab	Replace door knob with lever	\$3,000	\$0	NA	
67	Art-Sociology Building	146	2318	Academic	laboratory	Replace door knob with lever	\$3,000	\$0	NA	
68	Art-Sociology Building	146	2321	Academic	lab	Replace door knob with lever	\$3,000	\$0	NA	
69	Art-Sociology Building	146	3203	Academic	classroom	Replace door knob with lever	\$3,000	\$0	NA	
70	Art-Sociology Building	146	4304	Academic	Seminar Room	Replace door knob with lever	\$3,000	\$0	NA	
71	Art-Sociology Building	146	4306	Academic	Seminar Room	Replace door knob with lever	\$3,000	\$0	NA	
72	Art-Sociology Building	146	3311B	Academic	laboratory	Replace door knob with lever	\$3,000	\$0	NA	
73	Art-Sociology Building	146	3311C	Academic	laboratory	Replace door knob with lever	\$3,000	\$0	NA	
74	Art-Sociology Building	146	M2326	Academic	Lab	Replace door knob with lever	\$4,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
75	Art-Sociology Building	146	3203	Academic	classroom	Widen door and replace door knob with lever	\$6,000	\$0	NA	
76	Art-Sociology Building	146	3207	Academic	classroom	Widen door and replace door knob with lever	\$6,000	\$0	NA	
77	Art-Sociology Building	146	3215	Academic	classroom	Widen door and replace door knob with lever	\$6,000	\$0	NA	
78	Art-Sociology Building	146	3217	Academic	classroom	Widen door and replace door knob with lever	\$6,000	\$0	NA	
79	Art-Sociology Building	146	3219	Academic	classroom	Widen door and replace door knob with lever	\$6,000	\$0	NA	
80	Art-Sociology Building	146	3221	Academic	classroom	Widen door and replace door knob with lever	\$6,000	\$0	NA	
81	Art-Sociology Building	146	1118	Academic	Computer lab	Widen door to comply with ADA	\$6,000	\$0	NA	
82	Art-Sociology Building	146	3211	Academic	classroom	Widen door to comply with ADA	\$6,000	\$0	NA	
83	Art-Sociology Building	146	BLDG	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	New Survey 2016
84	Astronomical Observatory	221	1101	Academic	Meeting room	Install beveled door threshold	\$8,000	\$0	NA	
85	Astronomy Lecture Building	219	BLDG	Academic	Bldg. Signage	Install new signs adj. to doors 54 - 60 in. AFF.	\$16,000	\$0	NA	
86	Astronomy Lecture Building	219	1100	Academic	Drinking Fountain	Replace exist. fountain with accessible unit.	\$6,000	\$0	NA	
87	Atlantic Building (formerly Computer & Space Science Building)	224	0201	Academic	Seating/Assembly	Provide one wheelchair space.	\$3,000	\$0	NA	
88	Atlantic Building (formerly Computer & Space Science Building)	224	2321	Academic	Manual door/opng	Replace door to provide 32 in. min. clear opening.	\$8,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
89	Atlantic Building (formerly Computer & Space Science Building)	224	1113	Academic	lecture room	Widen door and replace door knob with lever	\$6,000	\$0	NA	
90	Atlantic Building (formerly Computer & Space Science Building)	224	Next to room 1436	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
91	Atlantic Building (formerly Computer & Space Science Building)	224	Next to room 1120	Academic	Hallway	Raise water cooler to comply with ADA	\$4,000	\$0	NA	
92	Atlantic Building (formerly Computer & Space Science Building)	224	0246	Academic	computer lab	Replace door knob with lever	\$3,000	\$0	NA	
93	Atlantic Building (formerly Computer & Space Science Building)	224	Adjacent to room B0259	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
94	Atlantic Building (formerly Computer & Space Science Building)	224	Next to room 2351	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
95	Atlantic Building (formerly Computer & Space Science Building)	224	Next to room 3351	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
96	Atlantic Building (formerly Computer & Space Science Building)	224	Next to room 4353	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
97	Atlantic Building (formerly Computer & Space Science Building)	224	1109	Academic	class lab	Widen door and replace door knob with lever	\$6,000	\$0	NA	
98	Atlantic Building (formerly Computer & Space Science Building)	224	0201	Academic	classroom	Widen door and replace door knob with lever	\$6,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
99	Atlantic Building (formerly Computer & Space Science Building)	224	0246	Academic	computer lab	Widen door and replace door knob with lever	\$6,000	\$0	NA	
100	Atlantic Building (formerly Computer & Space Science Building)	224	1106	Academic	study room	Widen door to comply with ADA	\$6,000	\$0	NA	
101	Atlantic Building (formerly Computer & Space Science Building)	224	1109	Academic	class lab	Widen door to comply with ADA	\$6,000	\$0	NA	
102	Atlantic Building (formerly Computer & Space Science Building)	224	2324	Academic	lecture room	Provide wheelchair accessible space in classroom 2324, replace double doors with ADA compliant door and install auto door opener.	\$0	\$21,500	1/4/18	FY 2017 Access UMD Project
103	Atlantic Building (formerly Computer & Space Science Building)	224	2334	Academic	lecture room	Widen door to comply with ADA	\$8,000	\$0	NA	
104	Atlantic Building (formerly Computer & Space Science Building)	224	3330	Academic	Study lab	Widen door to comply with ADA	\$8,000	\$0	NA	
105	Atlantic Building (formerly Computer & Space Science Building)	224	3332	Academic	Study lab	Widen door to comply with ADA	\$8,000	\$0	NA	
106	Avrum Gudelsky Veterinary Center	795	1110	Academic	Hallway	Lower water cooler to Comply with ADA	\$4,000	\$0	NA	
107	Benjamin Building	143	0230	Academic	Computer lab	Replace door knob with lever	\$3,000	\$0	NA	
108	Benjamin Building	143	Adjacent to room 1201	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
109	Benjamin Building	143	Next to room 0202	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
110	Benjamin Building	143	Next to room 0238	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
111	Benjamin Building	143	Next to room 1244	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
112	Benjamin Building	143	Next to room 2200	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
113	Benjamin Building	143	Next to room 2234	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
114	Benjamin Building	143	Next to room 3202	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
115	Benjamin Building	143	Next to room 3242	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
116	Benjamin Building	143	1299	Academic	Drinking Fountain	Replace non-ADA water cooler	\$6,000	\$0	NA	
117	Benjamin Building	143	2299	Academic	Drinking Fountain	Replace non-ADA water cooler	\$6,000	\$0	NA	
118	Benjamin Building	143	3299	Academic	Drinking Fountain	Replace non-ADA water cooler	\$6,000	\$0	NA	
119	Benjamin Building	143	1299	Academic	Auto Door Opener	Install automatic door openers to two doors at corridor 1299.	\$10,000	\$0	NA	New Survey, 2013
120	Biology - Psychology Building	144	1144	Academic	Fixed Work Area	Adjust work area height, between 28-34 in. AFF.	\$4,000	\$0	NA	
121	Biology - Psychology Building	144	1290	Academic	Circulation Spaces	Bevel change of level with max. slope of 1:2.	\$3,000	\$0	NA	
122	Biology - Psychology Building	144	0213	Academic	Fume Hood	Increase depth of knee space to 19 in. min.	\$4,000	\$0	NA	
123	Biology - Psychology Building	144	1144	Academic	Fixed Work Area	Increase height of knee space to 27 in. min.	\$5,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
124	Biology - Psychology Building	144	4245F	Academic	Manual door/opening	Install beveled threshold.	\$8,000	\$0	NA	
125	Biology - Psychology Building	144	0263	Academic	Fume Hood	Install hood controls that do not require tight grasp/twist.	\$4,000	\$0	NA	
126	Biology - Psychology Building	144	BLDG	Academic	Bldg Signs	Install new info. signs w/ raised contrast. symbols.	\$18,000	\$0	NA	
127	Biology - Psychology Building	144	BLDG	Academic	Bldg Signs	Install new signs adjacent to doors, 54 - 60 in. AFF.	\$18,000	\$0	NA	
128	Biology - Psychology Building	144	2245	Academic	Emergency Shower	Lower control mechanism to 54 in. AFF.	\$3,000	\$0	NA	
129	Biology - Psychology Building	144	4227	Academic	Emergency Shower	Lower control mechanism to 54 in. AFF.	\$3,000	\$0	NA	
130	Biology - Psychology Building	144	4231	Academic	Emergency Shower	Lower control mechanism to 54 in. AFF.	\$3,000	\$0	NA	
131	Biology - Psychology Building	144	4239	Academic	Emergency Shower	Lower control mechanism to 54 in. AFF.	\$3,000	\$0	NA	
132	Biology - Psychology Building	144	0275	Academic	Emergency Shower	Lower control mechanism to 54 in. AFF.	\$3,000	\$0	NA	
133	Biology - Psychology Building	144	3283	Academic	Emergency Shower	Lower control mechanism to 54 in. AFF.	\$3,000	\$0	NA	
134	Biology - Psychology Building	144	4235	Academic	Emergency Shower	Lower control mechanism to 54 in. AFF.	\$3,000	\$0	NA	
135	Biology - Psychology Building	144	3201	Academic	Fume Hood	Lower height of hood cabinet to 28-34 in. AFF.	\$4,000	\$0	NA	
136	Biology - Psychology Building	144	3221	Academic	Fume Hood	Lower height of hood cabinet to 28-34 in. AFF.	\$4,000	\$0	NA	
137	Biology - Psychology Building	144	3223	Academic	Fume Hood	Lower height of hood cabinet to 28-34 in. AFF.	\$4,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
138	Biology - Psychology Building	144	3247	Academic	Fume Hood	Lower height of hood cabinet to 28-34 in. AFF.	\$4,000	\$0	NA	
139	Biology - Psychology Building	144	3279	Academic	Fume Hood	Lower height of hood cabinet to 28-34 in. AFF.	\$5,000	\$0	NA	
140	Biology - Psychology Building	144	4227	Academic	Fume Hood	Lower height of hood cabinet to 28-34 in. AFF.	\$4,000	\$0	NA	
141	Biology - Psychology Building	144	4235	Academic	Fume Hood	Lower height of hood cabinet to 28-34 in. AFF.	\$4,000	\$0	NA	
142	Biology - Psychology Building	144	0205	Academic	Fume Hood	Lower height of hood cabinet to 28-34 in. AFF.	\$4,000	\$0	NA	
143	Biology - Psychology Building	144	2213	Academic	Fume Hood	Lower height of hood cabinet to 28-34 in. AFF.	\$4,000	\$0	NA	
144	Biology - Psychology Building	144	2257	Academic	Fume Hood	Lower height of hood cabinet to 28-34 in. AFF.	\$5,000	\$0	NA	
145	Biology - Psychology Building	144	3207	Academic	Fume Hood	Lower height of hood cabinet to 28-34 in. AFF.	\$4,000	\$0	NA	
146	Biology - Psychology Building	144	3275	Academic	Fume Hood	Lower height of hood cabinet to 28-34 in. AFF.	\$4,000	\$0	NA	
147	Biology - Psychology Building	144	4201	Academic	Fume Hood	Lower height of hood cabinet to 28-34 in. AFF.	\$4,000	\$0	NA	
148	Biology - Psychology Building	144	1228	Academic	Seating/Assembly	Provide additional wheelchair spaces, total >=2.	\$3,000	\$0	NA	
149	Biology - Psychology Building	144	1230	Academic	Seating/Assembly	Provide additional wheelchair spaces, total >=2.	\$3,000	\$0	NA	
150	Biology - Psychology Building	144	BLDG	Academic	Bldg Signs	Provide new directional signs w/ raised contrast. symbols.	\$11,000	\$0	NA	
151	Biology-Psychology Building	144	0263	Academic	lab	Replace door knob with lever and reverse door swing.	\$6,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
152	Biology-Psychology Building	144	0283	Academic	classroom	Replace door knob with lever and reverse door swing.	\$6,000	\$0	NA	
153	Biology-Psychology Building	144	1103	Academic	seminar room	Replace door knob with lever	\$3,000	\$0	NA	
154	Biology-Psychology Building	144	1232	Academic	classroom	Replace door knob with lever	\$3,000	\$0	NA	
155	Biology-Psychology Building	144	1238	Academic	classroom	Replace door knob with lever	\$3,000	\$0	NA	
156	Biology-Psychology Building	144	0140	Academic	lab	Replace door knob with lever	\$3,000	\$0	NA	
157	Biology-Psychology Building	144	0201	Academic	class lab	Replace door knob with lever	\$3,000	\$0	NA	
158	Biology-Psychology Building	144	0205	Academic	class lab	Replace door knob with lever	\$3,000	\$0	NA	
159	Biology-Psychology Building	144	2249	Academic	seminar room	Replace door knob with lever and reverse door swing	\$4,000	\$0	NA	New Survey 2016
160	Biology-Psychology Building	144	1193	Academic	Doorway	Replace door knob with lever.	\$3,000	\$0	NA	New Survey 2016
161	Biology-Psychology Building	144	2193	Academic	Doorway	Replace door knob with lever.	\$3,000	\$0	NA	New Survey 2016
162	Biology-Psychology Building	144	2195	Academic	Doorway	Replace door knob with lever.	\$3,000	\$0	NA	New Survey 2016
163	Biology-Psychology Building	144	3193	Academic	Doorway	Replace door knob with lever.	\$3,000	\$0	NA	New Survey 2016
164	Biology-Psychology Building	144	3195	Academic	Doorway	Replace door knob with lever.	\$3,000	\$0	NA	New Survey 2016
165	Biology-Psychology Building	144	4193	Academic	Doorway	Replace door knob with lever.	\$3,000	\$0	NA	New Survey 2016

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
166	Biology-Psychology Building	144	4195	Academic	Doorway	Replace door knob with lever.	\$3,000	\$0	NA	New Survey 2016
167	Biology-Psychology Building	144	5193	Academic	Doorway	Replace door knob with lever.	\$3,000	\$0	NA	New Survey 2016
168	Biology-Psychology Building	144	5195	Academic	Doorway	Replace door knob with lever.	\$3,000	\$0	NA	New Survey 2016
169	Biology-Psychology Building	144	0193	Academic	Doorway	Replace door knob with lever.	\$3,000	\$0	NA	New Survey 2016
170	Biology-Psychology Building	144	0195	Academic	Doorway	Replace door knob with lever.	\$3,000	\$0	NA	New Survey 2016
171	Biology-Psychology Building	144	Adjacent to room 1210	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
172	Biology-Psychology Building	144	Adjacent to room 0146	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
173	Biology-Psychology Building	144	Adjacent to room 3148	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
174	Biology-Psychology Building	144	Adjacent to room 2258A	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
175	Biology-Psychology Building	144	Adjacent to the room 4297	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
176	Biology-Psychology Building	144	Hallway 2298 near room 2202	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
177	Biology-Psychology Building	144	Next to room 1194A	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
178	Biology-Psychology Building	144	Next to room 3194A	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
179	Biology-Psychology Building	144	Next to room 0206	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
180	Biology-Psychology Building	144	Next to room 0250	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
181	Biology-Psychology Building	144	Next to room 1147D	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
182	Biology-Psychology Building	144	Next to room 2198A	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
183	Biology-Psychology Building	144	Next to room 4125	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
184	Biology-Psychology Building	144	Next to room 4147	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
185	Biology-Psychology Building	144	Next to room 4248	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
186	Biology-Psychology Building	144	On the hallway 3296	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
187	Biology-Psychology Building	144	On the hallway 3298	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
188	Biology-Psychology Building	144	To the left of room 2194A	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
189	Biology-Psychology Building	144	0275	Academic	lab	Widen door and replace door knob with lever	\$6,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
190	Biology-Psychology Building	144	BLDG	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	New Survey 2016
191	Biology-Psychology Building	144	BLDG	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	New Survey 2016
192	Biomolecular Science Building (formerly Agriculture / Life Sciences Surge Building)	296	3114A	Academic	Fixed Work Area	Adjust work area height to 28 - 34 in. AFF.	\$3,000	\$0	NA	
193	Biomolecular Science Building (formerly Agriculture / Life Sciences Surge Building)	296	3104A	Academic	Fume Hood	Increase depth of knee space to 19 in. min.	\$4,000	\$0	NA	
194	Biomolecular Science Building (formerly Agriculture / Life Sciences Surge Building)	296	3104B	Academic	Fume Hood	Increase depth of knee space to 19 in. min.	\$4,000	\$0	NA	
195	Biomolecular Science Building (formerly Agriculture / Life Sciences Surge Building)	296	3114B	Academic	Fume Hood	Increase depth of knee space to 19 in. min.	\$4,000	\$0	NA	
196	Biomolecular Science Building (formerly Agriculture / Life Sciences Surge Building)	296	3120	Academic	Fume Hood	Increase depth of knee space to 19 in. min.	\$4,000	\$0	NA	
197	Biomolecular Science Building (formerly Agriculture / Life Sciences Surge Building)	296	3114A	Academic	Fume Hood	Increase depth of knee space to 19 in. min.	\$4,000	\$0	NA	
198	Biomolecular Science Building (formerly Agriculture / Life Sciences Surge Building)	296	1118	Academic	Fixed Work Area	Install controls which do not require tight grasp/twist.	\$4,000	\$0	NA	
199	Biomolecular Science Building (formerly Agriculture / Life Sciences Surge Building)	296	3114A	Academic	Fixed Work Area	Install controls which do not require tight grasp/twist.	\$4,000	\$0	NA	
200	Biomolecular Science Building (formerly Agriculture / Life Sciences Surge Building)	296	3114B	Academic	Fixed Work Area	Install controls which do not require tight grasp/twist.	\$4,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
201	Biomolecular Science Building (formerly Agriculture / Life Sciences Surge Building)	296	3118	Academic	Fixed Work Area	Install controls which do not require tight grasp/twist.	\$4,000	\$0	NA	
202	Biomolecular Science Building (formerly Agriculture / Life Sciences Surge Building)	296	3120	Academic	Fixed Work Area	Install controls which do not require tight grasp/twist.	\$4,000	\$0	NA	
203	Biomolecular Science Building (formerly Agriculture / Life Sciences Surge Building)	296	1114B	Academic	Fume Hood	Lower height of hood cabinet to 28 - 34 in. AFF.	\$4,000	\$0	NA	
204	Biomolecular Science Building (formerly Agriculture / Life Sciences Surge Building)	296	2104A	Academic	Fume Hood	Lower height of hood cabinet to 28 - 34 in. AFF.	\$4,000	\$0	NA	
205	Biomolecular Science Building (formerly Agriculture / Life Sciences Surge Building)	296	2104B	Academic	Fume Hood	Lower height of hood cabinet to 28 - 34 in. AFF.	\$4,000	\$0	NA	
206	Biomolecular Science Building (formerly Agriculture / Life Sciences Surge Building)	296	2114A	Academic	Fume Hood	Lower height of hood cabinet to 28 - 34 in. AFF.	\$4,000	\$0	NA	
207	Biomolecular Science Building (formerly Agriculture / Life Sciences Surge Building)	296	2120	Academic	Fume Hood	Lower height of hood cabinet to 28 - 34 in. AFF.	\$4,000	\$0	NA	
208	Biomolecular Science Building (formerly Agriculture / Life Sciences Surge Building)	296	3114A	Academic	Fume Hood	Lower height of hood cabinet to 28 - 34 in. AFF.	\$4,000	\$0	NA	
209	Biomolecular Science Building (formerly Agriculture / Life Sciences Surge Building)	296	3114B	Academic	Fume Hood	Lower height of hood cabinet to 28 - 34 in. AFF.	\$4,000	\$0	NA	
210	Biomolecular Science Building (formerly Agriculture / Life Sciences Surge Building)	296	1120	Academic	Fume Hood	Lower height of hood cabinet to 28 - 34 in. AFF.	\$4,000	\$0	NA	
211	Biomolecular Science Building (formerly Agriculture / Life Sciences Surge Building)	296	2104C	Academic	Fume Hood	Lower height of hood cabinet to 28 - 34 in. AFF.	\$4,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
212	Biomolecular Science Building (formerly Agriculture / Life Sciences Surge Building)	296	2114B	Academic	Fume Hood	Lower height of hood cabinet to 28 - 34 in. AFF.	\$4,000	\$0	NA	
213	Biomolecular Science Building (formerly Agriculture / Life Sciences Surge Building)	296	3104A	Academic	Fume Hood	Lower height of hood cabinet to 28 - 34 in. AFF.	\$4,000	\$0	NA	
214	Biomolecular Science Building (formerly Agriculture / Life Sciences Surge Building)	296	3104B	Academic	Fume Hood	Lower height of hood cabinet to 28 - 34 in. AFF.	\$4,000	\$0	NA	
215	Biomolecular Science Building (formerly Agriculture / Life Sciences Surge Building)	296	3120	Academic	Fume Hood	Lower height of hood cabinet to 28 - 34 in. AFF.	\$4,000	\$0	NA	
216	Bioscience Research Building	413	1101	Academic	Lecture Hall	Widen door to comply with ADA	\$6,000	\$0	NA	
217	Center for Educational Partnership (CEP)	804	Main Entrance Door	Academic	Doors	Install two pairs of double doors with closers and locking hardware on the existing lobby frame to include on HC accessible door & relocate outside intercom to Lobby area.	\$16,000	\$0	NA	New Survey 2013
218	Center for Educational Partnership (CEP)	804	0121	Academic	Study Room	Replace door knob with lever	\$3,000	\$0	NA	New Survey 2013
219	Center for Educational Partnership (CEP)	804	0121A	Academic	Study Room	Replace door knob with lever	\$3,000	\$0	NA	New Survey 2013
220	Center for Educational Partnership (CEP)	804	0125	Academic	Study Room	Replace door knob with lever	\$3,000	\$0	NA	New Survey 2013
221	Central Animal Resources Facility	087	1118	Academic	Fixed Work Area	Adjust work area height to between 28 - 34 in.	\$3,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
222	Central Animal Resources Facility	087	1104A	Academic	Fixed Work Area	Adjust work area height to between 28 - 34 in.	\$4,000	\$0	NA	
223	Central Animal Resources Facility	087	1104	Academic	Fume Hood	Increase height of knee space to 27 in. min.	\$5,000	\$0	NA	
224	Central Animal Resources Facility	087	1104A	Academic	Fixed Work Area	Increase width of knee space to 30 in. min.	\$5,000	\$0	NA	
225	Central Animal Resources Facility	087	1120	Academic	Fume Hood	Lower height of hood cabinet to between 28 - 34 in.	\$4,000	\$0	NA	
226	Chemical & Nuclear Engineering Building	090	Adjacent to room 2118	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
227	Chemical & Nuclear Engineering Building	090	Next to room 2133	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
228	Chemical & Nuclear Engineering Building	090	2302	Academic	class lab	Replace door knob with lever	\$3,000	\$0	NA	
229	Chemical & Nuclear Engineering Building	090	Next to room 1131	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
230	Chemical & Nuclear Engineering Building	090	2210	Academic	computer lab	Widen door and replace door knob with lever	\$6,000	\$0	NA	
231	Chemical & Nuclear Engineering Building	090	Next to room 2202	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
232	Chemical and Nuclear Engineering Building	090	1208	Academic	Manual door/opng..	Install accessible door hardware.	\$3,000	\$0	NA	
233	Chemical and Nuclear Engineering Building	090	1210	Academic	Manual door/opng..	Install accessible door hardware.	\$3,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
234	Chemical and Nuclear Engineering Building	090	2309	Academic	Manual door/opng..	Install accessible door hardware.	\$3,000	\$0	NA	
235	Chemical and Nuclear Engineering Building	090	2108	Academic	Seating/Assembly	Install assistive listening system.	\$11,000	\$0	NA	
236	Chemical and Nuclear Engineering Building	090	2110	Academic	Seating/Assembly	Install assistive listening system.	\$10,000	\$0	NA	
237	Chemical and Nuclear Engineering Building	090	1136	Academic	Manual door/opng..	Replace door to provide 32 in. min. cl. opng.	\$6,000	\$0	NA	
238	Chemical and Nuclear Engineering Building	090	1208	Academic	Manual door/opng..	Replace door to provide 32 in. min. cl. opng.	\$6,000	\$0	NA	
239	Chemical and Nuclear Engineering Building	090	2309	Academic	Manual door/opng..	Replace door to provide 32 in. min. cl. opng.	\$6,000	\$0	NA	
240	Chemical and Nuclear Engineering Building	090	1210	Academic	Manual door/opng..	Replace door to provide 32 in. min. cl. opng.	\$6,000	\$0	NA	
241	Chemical and Nuclear Engineering Building	090	2118	Academic	Interior	Replace steps with accessible ramp.	\$8,000	\$0	NA	
242	Chemical and Nuclear Engineering Building	090	2120	Academic	Interior	Replace steps with accessible ramp.	\$8,000	\$0	NA	
243	Chemistry Building	091	BLDG	Academic	Signage	Install 2 granite markers to provide direction to wheelchair accessible entrance.	\$0	\$0	2/12/13	FY 2013 Access UMD Project
244	Clarice Smith Performance Arts Center	386	Next 3102	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
245	Clarice Smith Performance Arts Center	386	Next 3173	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
246	Clarice Smith Performance Arts Center	386	Next 3740	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
247	Clarice Smith Performance Arts Center	386	next to room 2201	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
248	Clarice Smith Performance Arts Center	386	1438 / 1450 1410	Academic	Accessible Seats	Provide wheelchair spaces, accessible seats in Dekelbourn & Gildenhorn Concert Halls.	\$10,000	\$0	NA	New Survey 2013
249	Clarice Smith Performance Arts Center	386	1460 / 1464 1608 / 1716 2724 / 2726	Academic	Doors	Replace door handle with lever.	\$6,000	\$0	NA	New Survey 2013
250	Clarice Smith Performing Arts Center	386	2200	Academic	classroom	Provide wheelchair space	\$3,000	\$0	NA	
251	College Park Volunteer Fire Department	802		Non-Academic	Auto Door Opener	Install automatic door opener to meet ADA requirements.	\$0	\$0	2/8/2013	FY 2013 Access UMD Project
252	Computer Science Instructional Center	406	1115	Academic	Lecture Hall	Widen door to comply with ADA	\$6,000	\$0	NA	
253	Eneergy Research Facility	223	N/A	Academic	Doorway	Install automatic door opener to double fire doors between the elevator lobby and second floor.	\$0	\$0	5/17/16	FY16 Access UMD project.
254	Engineering Laboratory Building	089	0106A	Academic	Fume Hood	Increase height of knee space to 27 in. min.	\$5,000	\$0	NA	
255	Engineering Laboratory Building	089	1155	Academic	Fume Hood	Increase height of knee space to 27 in. min.	\$5,000	\$0	NA	
256	Engineering Laboratory Building	089	0106A	Academic	Fume Hood	Lower height of hood cabinet to be 27 - 34 in.	\$4,000	\$0	NA	
257	Engineering Laboratory Building	089	1155	Academic	Fume Hood	Lower height of hood cabinet to be 27 - 34 in.	\$4,000	\$0	NA	
258	Engineering Laboratory Building	089	0123	Academic	Lab	Replace door knob with lever	\$3,000	\$0	NA	
259	Engineering Laboratory Building	089	Near Stairs 1194	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
260	Engineering Laboratory Building	089	1176	Academic	Lab	Widen door to comply with ADA	\$6,000	\$0	NA	
261	Engineering Laboratory Building	089	0121	Academic	Lab	Widen door to comply with ADA	\$6,000	\$0	NA	
262	Engineering Research Building (formerly Engineering Annex)	093	0200	Academic	Manual door/opng.	Create more clearance at latch or reverse door swing.	\$5,000	\$0	NA	
263	Engineering Research Building (formerly Engineering Annex)	093	0106	Academic	Manual door/opng.	Install lever or other accessible handle.	\$3,000	\$0	NA	
264	Engineering Research Building (formerly Engineering Annex)	093	0108	Academic	Manual door/opng.	Install lever or other accessible handle.	\$3,000	\$0	NA	
265	Engineering Research Building (formerly Engineering Annex)	093	0200	Academic	Manual door/opng.	Install lever or other accessible handle.	\$3,000	\$0	NA	
266	Engineering Research Building (formerly Engineering Annex)	093	0101	Academic	Manual door/opng.	Install lever or other accessible handle.	\$3,000	\$0	NA	
267	Engineering Research Building (formerly Engineering Annex)	093	0113	Academic	Manual door/opng.	Install lever or other accessible handle.	\$3,000	\$0	NA	
268	Engineering Research Building (formerly Engineering Annex)	093	0307	Academic	Manual door/opng.	Install lever or other accessible handle.	\$3,000	\$0	NA	
269	Francis Scott Key Hall	048	0102	Academic	Classroom	Replace door knob with lever	\$3,000	\$0	NA	
270	Francis Scott Key Hall	048	0106	Academic	Lecture Hall	Widen door to comply with ADA	\$6,000	\$0	NA	
271	Francis Scott Key Hall	048	Near Room 0111	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
272	Francis Scott Key Hall	048	1117	Academic	Classroom	Repace door knob with lever	\$3,000	\$0	NA	
273	Francis Scott Key Hall	048	0107	Academic	Seminar Room	Repace door knob with lever	\$3,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
274	Francis Scott Key Hall	048	0116	Academic	Classroom	Replace door knob with lever	\$3,000	\$0	NA	
275	Francis Scott Key Hall	048	0119	Academic	Classroom	Replace door knob with lever	\$3,000	\$0	NA	
276	Francis Scott Key Hall	048	0120	Academic	Classroom	Replace door knob with lever and reverse door swing.	\$4,000	\$0	NA	
277	Francis Scott Key Hall	048	0121	Academic	Classroom	Replace door knob with lever and reverse door swing.	\$4,000	\$0	NA	
278	Francis Scott Key Hall	048	0123	Academic	Classroom	Replace door knob with lever and reverse door swing.	\$4,000	\$0	NA	
279	Francis Scott Key Hall	048	0124	Academic	Classroom	Replace door knob with lever and reverse door swing.	\$4,000	\$0	NA	
280	Francis Scott Key Hall	048	0125	Academic	Classroom	Replace door knob with lever and reverse door swing.	\$4,000	\$0	NA	
281	Francis Scott Key Hall	048	0126	Academic	Classroom	Replace door knob with lever and reverse door swing.	\$4,000	\$0	NA	
282	Francis Scott Key Hall	048	Outside Room 1117	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
283	Francis Scott Key Hall	048	Outside Room 3112	Academic	Hallway	Replace non-ADA water cooler	\$5,000	\$0	NA	
284	Francis Scott Key Hall	048	0103	Academic	Classroom	Reverse door swing	\$4,000	\$0	NA	
285	Geology Building	237	Outside Room 1123	Academic	Hallway	Raise water cooler to comply with ADA	\$4,000	\$0	NA	
286	Geology Building	237	2117	Academic	Lab	Widen door to comply with ADA	\$6,000	\$0	NA	
287	Glenn L. Martin Hall	088	1202	Academic	Lecture Hall	Widen door to comply with ADA	\$6,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
288	Glenn L. Martin Hall	088	2152	Academic	laboratory	Replace door knob with lever	\$3,000	\$0	NA	
289	Glenn L. Martin Hall	088	3105	Academic	MML Office	Replace door knob with lever	\$3,000	\$0	NA	
290	Glenn L. Martin Hall	088	3108	Academic	Classroom Lab	Replace door knob with lever	\$3,000	\$0	NA	
291	Glenn L. Martin Hall	088	3140	Academic	Classroom	Replace door knob with lever	\$3,000	\$0	NA	
292	Glenn L. Martin Hall	088	0128F	Academic	laboratory	Replace door knob with lever	\$3,000	\$0	NA	
293	Glenn L. Martin Hall	088	0309	Academic	Design Lab	Replace door knob with lever	\$3,000	\$0	NA	
294	Glenn L. Martin Hall	088	0312	Academic	Computer Lab	Replace door knob with lever	\$3,000	\$0	NA	
295	H. J. Patterson Hall	073	3234A	Academic	Fixed Work Area	Adjust work area height to between 28 - 34 inches.	\$4,000	\$0	NA	
296	H. J. Patterson Hall	073	2242	Academic	Seating/Assembly	Disperse wheelchair seats within the room.	\$11,000	\$0	NA	
297	H. J. Patterson Hall	073	3234	Academic	Fume Hood	Increase depth of knee space to 19 in. minimum.	\$4,000	\$0	NA	
298	H. J. Patterson Hall	073	3232	Academic	Fume Hood	Increase depth of knee space to 19 in. minimum.	\$4,000	\$0	NA	
299	H. J. Patterson Hall	073	3234A	Academic	Fume Hood	Increase depth of knee space to 19 in. minimum.	\$4,000	\$0	NA	
300	H. J. Patterson Hall	073	3236	Academic	Fume Hood	Increase depth of knee space to 19 in. minimum.	\$4,000	\$0	NA	
301	H. J. Patterson Hall	073	0219	Academic	Fume Hood	Increase height of knee space to 27 in. minimum.	\$5,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
302	H. J. Patterson Hall	073	3234A	Academic	Fixed Work Area	Increase height of knee space to 28 in. minimum.	\$5,000	\$0	NA	
303	H. J. Patterson Hall	073	2242	Academic	Seating/Assembly	Install assistive listening system.	\$11,000	\$0	NA	
304	H. J. Patterson Hall	073	3234	Academic	Fume Hood	Install hood controls that do not require tight grasp/twist.	\$4,000	\$0	NA	
305	H. J. Patterson Hall	073	SE1299	Academic	Manual door/opng.	Install ramp at level change.	\$12,000	\$0	NA	
306	H. J. Patterson Hall	073	0229	Academic	Emergency Shower	Lower control mechanism.	\$3,000	\$0	NA	
307	H. J. Patterson Hall	073	0219	Academic	Emergency Shower	Lower control mechanism.	\$3,000	\$0	NA	
308	H. J. Patterson Hall	073	0219	Academic	Fume Hood	Lower height of hood cabinet to be 28 - 34 in. high.	\$4,000	\$0	NA	
309	H. J. Patterson Hall	073	0229	Academic	Fume Hood	Lower height of hood cabinet to be 28 - 34 in. high.	\$4,000	\$0	NA	
310	H. J. Patterson Hall	073	2212	Academic	Fume Hood	Lower height of hood cabinet to be 28 - 34 in. high.	\$4,000	\$0	NA	
311	H. J. Patterson Hall	073	2216	Academic	Fume Hood	Lower height of hood cabinet to be 28 - 34 in. high.	\$4,000	\$0	NA	
312	H. J. Patterson Hall	073	3232	Academic	Fume Hood	Lower height of hood cabinet to be 28 - 34 in. high.	\$4,000	\$0	NA	
313	H. J. Patterson Hall	073	3234A	Academic	Fume Hood	Lower height of hood cabinet to between 28 - 34 in. high.	\$4,000	\$0	NA	
314	H. J. Patterson Hall	073	3236	Academic	Fume Hood	Lower height of hood cabinet to between 28 - 34 in. high.	\$4,000	\$0	NA	
315	H. J. Patterson Hall	073	3234	Academic	Fume Hood	Lower height of hood cabinet to between 28 - 34 in. high.	\$4,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
316	H. J. Patterson Hall	073	2242	Academic	Lecture Room	Replace door knob with lever	\$3,000	\$0	NA	
317	H. J. Patterson Hall	073	Near Elevator 1295	Academic	Hallway	Raise water cooler to comply with ADA	\$3,000	\$0	NA	
318	H. J. Patterson Hall	073	Near Room 0220	Academic	Hallway	Raise water cooler to comply with ADA	\$3,000	\$0	NA	
319	H. J. Patterson Hall	073	2226	Academic	Lab	Replace door knob with lever	\$3,000	\$0	NA	
320	H. J. Patterson Hall	073	2230	Academic	Lab	Replace door knob with lever	\$3,000	\$0	NA	
321	H. J. Patterson Hall	073	Near Elevator 0295	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
322	H. J. Patterson Hall	073	Near Elevator 2295	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
323	H. J. Patterson Hall	073	Outside Room 2218	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
324	H. J. Patterson Hall	073	0210	Academic	Lab	Widen door to comply with ADA	\$6,000	\$0	NA	
325	H. J. Patterson Hall	073	0226	Academic	Lecture Hall	Widen door to comply with ADA	\$6,000	\$0	NA	
326	H. J. Patterson Hall	073	2104, 0107, 3103, 1125, 3111	Academic	Lab	Lower eyewash control (rooms 2104, 0107), increase knee space (rooms 3103, 0107), lower cabinet (rooms 1125, 3111) and provide wheelchair space to comply with 2010 Standards.	\$0	\$39,300	12/10/17	Project not in 2016 Transition Plan, but completed in 2018 as part of major Wing 1 Renovation

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
327	H.J. Patterson	073	0226	Academic	Classroom	Provide wheelchair accessible space and companion space in classroom 0226, replace double doors with ADA compliant door and install automatic door opener.	\$0	\$14,000	12/10/18	FY 2017 Access UMD Project
328	Health Center	140	BLDG	Academic Support	Urgent Care Room	Install HA door button @ ground floor entrance	\$4,000	\$0	NA	
329	Health Center	140	BLDG	Academic Support	Urgent Care Room	Lower HA button @ urgent care entrance	\$4,000	\$0	NA	
330	Health Center	140	Ground Floor	Academic Support	Drinking Fountain	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
331	Health Center	140	Ground Floor	Academic Support	Drinking Fountain	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
332	Hornbake Library	147	BLDG	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	New Survey 2016
333	Hornbake Library	147	0123	Library	Classroom	Replace door knob with lever	\$3,000	\$0	NA	
334	Hornbake Library	147	0103	Library	Classroom	Widen door to comply with ADA	\$6,000	\$0	NA	
335	Hornbake Library	147	0105	Library	Classroom	Widen door to comply with ADA	\$6,000	\$0	NA	
336	Hornbake Library	147	0109	Library	Classroom	Widen door to comply with ADA	\$6,000	\$0	NA	
337	Hornbake Library	147	0211	Library	Study Room	Widen door to comply with ADA	\$6,000	\$0	NA	
338	Hornbake Library	147	Outside Room 3107	Library	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
339	Hornbake Library	147	4113	Library	Seminar Room	Repace door knob with lever	\$3,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
340	Hornbake Library	147	4115	Library	Seminar Room	Replace door knob with lever	\$3,000	\$0	NA	
341	Hornbake Library	147	Suite 4105	Library	Office	Replace door knob with lever	\$12,000	\$0	NA	New Survey 2016
342	Hornbake Library	147	Outside Room 0214A	Library	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
343	Hornbake Library	147	Outside Room 1108	Library	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
344	Hornbake Library	147	Outside Room 2105	Library	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
345	Hornbake Library	147	Outside Room 2214A	Library	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
346	Hornbake Library	147	Outside Room 3214	Library	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
347	Hornbake Library	147	Outside Room 3215	Library	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
348	Hornbake Library	147	Outside Room 4106	Library	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
349	Institute for Physical Science & Technology	085	0103MT	Academic	Manual door/opening	Install lever or other accessible hardware.	\$3,000	\$0	NA	
350	Institute for Physical Science & Technology	085	2103WT	Academic	Manual door/opening	Install lever or other accessible hardware.	\$3,000	\$0	NA	
351	Institute For Physical Science & Technology	085	1116	Academic	Conference Room	Replace door knob with lever	\$3,000	\$0	NA	
352	Institute For Physical Science & Technology	085	Outside Room 0111	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
353	Institute For Physical Science & Technology	085	Outside Room 1102	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
354	Institute For Physical Science & Technology	085	Outside Room 2109	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
355	Institute For Physical Science & Technology	085	Outside Room B0107	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
356	J. M. Patterson Building	083	1210	Academic	Manual door/opening	Install lever or other accessible hardware.	\$3,000	\$0	NA	
357	J. M. Patterson Building	083	2104	Academic	Manual door/opening	Install lever or other accessible hardware.	\$3,000	\$0	NA	
358	J. M. Patterson Building	083	1201	Academic	Emergency Eyewash	Lower control mechanism.	\$4,000	\$0	NA	
359	J. M. Patterson Building	083	1110	Academic	Emergency Eyewash	Modify controls to be operable with closed fist.	\$4,000	\$0	NA	
360	J. M. Patterson Building	083	1201	Academic	Emergency Eyewash	Modify controls to be operable with closed fist.	\$4,000	\$0	NA	
361	J. M. Patterson Building	083	Near Stairs 1295	Academic	Hallway	Raise water cooler to comply with ADA	\$4,000	\$0	NA	
362	J. M. Patterson Building	083	1116	Academic	Manual door/opening	Replace door, provide 32 in. min. cl. opening.	\$6,000	\$0	NA	
363	J. M. Patterson Building	083	2115	Academic	Manual door/opening	Replace door, provide 32 in. min. cl. opening.	\$6,000	\$0	NA	
364	J. M. Patterson Building	083	1110	Academic	Manual door/opening	Replace door, provide 32 in. min. cl. opening.	\$6,000	\$0	NA	
365	J. M. Patterson Building	083	2104	Academic	Manual door/opening	Replace door, provide 32 in. min. cl. opening.	\$6,000	\$0	NA	
366	J. M. Patterson Building	083	2116	Academic	Manual door/opening	Replace door, provide 32 in. min. cl. opening.	\$6,000	\$0	NA	
367	J. M. Patterson Building	083	2120	Academic	Manual door/opening	Replace door, provide 32 in. min. cl. opening.	\$6,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
368	J. M. Patterson Building	083	1297	Academic	Drinking Fountain	Replace existing fountain with accessible unit.	\$6,000	\$0	NA	
369	J. M. Patterson Building	083	Near Elevator 1298	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
370	J. M. Patterson Building	083	Near Elevator 2298	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
371	J. M. Patterson Building	083	Near Elevator 3298	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
372	J. M. Patterson Building	083	Near Stairs 2295	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
373	J. M. Patterson Building	083	Near Stairs 3295	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
374	J.M. Patterson Building	083	1201	Academic	Lab	Repace door knob with lever	\$3,000	\$0	NA	
375	J.M. Patterson Building	083	1210	Academic	Lab	Repace door knob with lever	\$3,000	\$0	NA	
376	J.M. Patterson Building	083	1215	Academic	Computer Lab	Repace door knob with lever	\$3,000	\$0	NA	
377	J.M. Patterson Building	083	1109	Academic	Classroom	Widen door to comply with ADA	\$6,000	\$0	NA	
378	J.M. Patterson Building	083	1110	Academic	Lab	Widen door to comply with ADA	\$6,000	\$0	NA	
379	J.M. Patterson Building	083	2121	Academic	Classroom	Widen door to comply with ADA	\$6,000	\$0	NA	
380	J.M. Patterson Building	083	3201	Academic	Lecture Hall	Widen door to comply with ADA	\$6,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
381	Jimenez Hall	034	2207	Academic	Classroom	Install door lever or other accessible handle.	\$0	\$2,000	12/10/17	Project completed by Building Security (Shelter-in-Place Lock)
382	Jimenez Hall	034	3118	Academic	Seminar Room	Install door lever or other accessible handle.	\$0	\$2,000	12/10/17	Project completed by Building Security (Shelter-in-Place Lock)
383	Jimenez Hall	034	3120	Academic	Classroom	Install door lever or other accessible handle.	\$0	\$2,000	12/10/17	Project completed by Building Security (Shelter-in-Place Lock)
384	Jimenez Hall	034	3122	Academic	Seminar Room	Install door lever or other accessible handle.	\$0	\$2,000	12/10/17	Project completed by Building Security (Shelter-in-Place Lock)
385	Jimenez Hall	034	3203	Academic	Classroom	Install door lever or other accessible handle.	\$0	\$2,000	12/10/17	Project completed by Building Security (Shelter-in-Place Lock)
386	Jimenez Hall	034	1103	Academic	Seminar Room	Replace door knob with lever	\$0	\$2,000	12/10/17	Project completed by Building Security (Shelter-in-Place Lock)
387	Jimenez Hall	034	1120	Academic	Classroom	Replace door knob with lever	\$0	\$2,000	12/10/17	Project completed by Building Security (Shelter-in-Place Lock)
388	Jimenez Hall	034	1122	Academic	Classroom	Replace door knob with lever	\$0	\$2,000	12/10/17	Project completed by Building Security (Shelter-in-Place Lock)
389	Jimenez Hall	034	1124	Academic	Classroom	Replace door knob with lever	\$0	\$2,000	12/10/17	Project completed by Building Security (Shelter-in-Place Lock)
390	Jimenez Hall	034	1226	Academic	Seminar Room	Replace door knob with lever	\$0	\$2,000	12/10/17	Project completed by Building Security (Shelter-in-Place Lock)
391	Jimenez Hall	034	2117	Academic	Classroom	Replace door knob with lever	\$0	\$2,000	12/10/17	Project completed by Building Security (Shelter-in-Place Lock)
392	Jimenez Hall	034	2120	Academic	Classroom	Replace door knob with lever	\$0	\$2,000	12/10/17	Project completed by Building Security (Shelter-in-Place Lock)
393	Jimenez Hall	034	2122	Academic	Classroom	Replace door knob with lever	\$0	\$2,000	12/10/17	Project completed by Building Security (Shelter-in-Place Lock)

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
394	Jimenez Hall	034	2123	Academic	Classroom	Repace door knob with lever	\$0	\$2,000	12/10/17	Project completed by Building Security (Shelter-in-Place Lock)
395	Jimenez Hall	034	2125	Academic	Classroom	Repace door knob with lever	\$0	\$2,000	12/10/17	Project completed by Building Security (Shelter-in-Place Lock)
396	Jimenez Hall	034	0120	Academic	Classroom	Repace door knob with lever	\$0	\$2,000	12/10/17	Project completed by Building Security (Shelter-in-Place Lock)
397	Jimenez Hall	034	0122	Academic	Classroom	Repace door knob with lever	\$0	\$2,000	12/10/17	Project completed by Building Security (Shelter-in-Place Lock)
398	Jimenez Hall	034	1215	Academic	Classroom	Replace door knob with lever and reverse door swing.	\$0	\$3,000	12/10/17	Project completed by Building Security (Shelter-in-Place Lock)
399	Jimenez Hall	034	1224	Academic	Classroom	Replace door knob with lever and reverse door swing.	\$0	\$3,000	12/10/17	Project completed by Building Security (Shelter-in-Place Lock)
400	Jimenez Hall	034	Outside Room 0113	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
401	Jimenez Hall	034	Outside Room 0211	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
402	Jimenez Hall	034	Outside Room 1112	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
403	Jimenez Hall	034	Outside Room 2113	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
404	Jimenez Hall	034	Outside Room 2210	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
405	Jimenez Hall	034	Outside Room 3113	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
406	Jimenez Hall	034	Outside Room 3210	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
407	Jimenez Hall	034	Outside Room 4113	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
408	Jimenez Hall	034	Outside Room 4210	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
409	Jimenez Hall	034	0105	Academic	Lecture Room	Widen door to comply with ADA	\$6,000	\$0	NA	
410	John S. Toll Physics Building	082	1201	Academic	Classroom	Widen door to comply with ADA	\$6,000	\$0	NA	
411	John S. Toll Physics Building	082	1214	Academic	Lab	Widen door to comply with ADA	\$6,000	\$0	NA	
412	John S. Toll Physics Building	082	1412	Academic	Lecture Room	Widen door to comply with ADA	\$6,000	\$0	NA	
413	John S. Toll Physics Building	082	1219	Academic	Classroom	Install door lever or other accessible handle.	\$6,000	\$0	NA	
414	John S. Toll Physics Building	082	2207	Academic	Conference Room	Install door lever or other accessible handle.	\$3,000	\$0	NA	
415	John S. Toll Physics Building	082	3203	Academic	laboratory	Install door lever or other accessible handle.	\$3,000	\$0	NA	
416	John S. Toll Physics Building	082	3206	Academic	laboratory	Install door lever or other accessible handle.	\$3,000	\$0	NA	
417	John S. Toll Physics Building	082	3219	Academic	laboratory	Install door lever or other accessible handle.	\$3,000	\$0	NA	
418	John S. Toll Physics Building	082	3315	Academic	laboratory	Install door lever or other accessible handle.	\$3,000	\$0	NA	
419	John S. Toll Physics Building	082	3319	Academic	laboratory	Install door lever or other accessible handle.	\$3,000	\$0	NA	
420	John S. Toll Physics Building	082	0208	Academic	Lab	Install door lever or other accessible handle.	\$3,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
421	John S. Toll Physics Building	082	0405	Academic	Classroom	Install door lever or other accessible handle.	\$3,000	\$0	NA	
422	John S. Toll Physics Building	082	3210	Academic	laboratory	Replace door knob with lever and reverse door swing.	\$5,000	\$0	NA	
423	John S. Toll Physics Building	082	3211	Academic	laboratory	Replace door knob with lever and reverse door swing.	\$5,000	\$0	NA	
424	John S. Toll Physics Building	082	3213	Academic	laboratory	Replace door knob with lever and reverse door swing.	\$5,000	\$0	NA	
425	John S. Toll Physics Building	082	3214	Academic	laboratory	Replace door knob with lever and reverse door swing.	\$5,000	\$0	NA	
426	John S. Toll Physics Building	082	1402	Academic	Classroom	Widen door and change door knob with lever	\$6,000	\$0	NA	
427	John S. Toll Physics Building	082	3104	Academic	laboratory	Widen door and change door knob with lever	\$6,000	\$0	NA	
428	John S. Toll Physics Building	082	3112	Academic	laboratory	Widen door and change door knob with lever	\$6,000	\$0	NA	
429	John S. Toll Physics Building	082	3115	Academic	Computer Lab	Widen door and change door knob with lever	\$6,000	\$0	NA	
430	John S. Toll Physics Building	082	3219	Academic	laboratory	Widen door and change door knob with lever	\$8,000	\$0	NA	
431	John S. Toll Physics Building	082	3301	Academic	laboratory	Widen door and change door knob with lever	\$8,000	\$0	NA	
432	John S. Toll Physics Building	082	3310	Academic	laboratory	Widen door and change door knob with lever	\$8,000	\$0	NA	
433	John S. Toll Physics Building	082	3312	Academic	laboratory	Widen door and change door knob with lever	\$8,000	\$0	NA	
434	John S. Toll Physics Building	082	3314	Academic	laboratory	Widen door and change door knob with lever	\$8,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
435	John S. Toll Physics Building	082	3316	Academic	laboratory	Widen door and change door knob with lever	\$8,000	\$0	NA	
436	John S. Toll Physics Building	082	3317	Academic	laboratory	Widen door and change door knob with lever	\$8,000	\$0	NA	
437	John S. Toll Physics Building	082	3321	Academic	laboratory	Widen door and change door knob with lever	\$8,000	\$0	NA	
438	John S. Toll Physics Building	082	3306	Academic	laboratory	Widen door to comply with ADA	\$6,000	\$0	NA	
439	John S. Toll Physics Building	082	1410 /1412	Academic	Accessible Seats	Provide wheelchair spaces, accessible seats, and companion seats in two lecture halls (1410 & 1412).	\$0	\$0	6/29/2010	FY 2010 Access MD Project (\$738).
440	John S. Toll Physics Building	082	Near Elevator 0194	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
441	John S. Toll Physics Building	082	Near Elevator 2194	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
442	John S. Toll Physics Building	082	Near Stairs 1499	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
443	John S. Toll Physics Building	082	Outside Room 1314	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
444	John S. Toll Physics Building	082	Outside Room 2224	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
445	John S. Toll Physics Building	082	Outside Room 3304	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
446	John S. Toll Physics Building	082	Outside Room 4111	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
447	John S. Toll Physics Building	082	Outside Room 4222	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
448	Jull Hall	227	1111	Academic	Fixed Work Area	Adjust ht. of work area to 28 - 34 in.	\$4,000	\$0	NA	
449	Jull Hall	227	1111	Academic	Fixed Work Area	Increase ht. of knee space to 27 in. min.	\$5,000	\$0	NA	
450	Jull Hall	227	1117 / 1197 1101 / 1105 1111	Academic	Classroom	Install automatic door opener to rooms 1117 and 1197, replace double door and frame to room 1101 and install accessible door hardware to rooms 1105 and 1111 to comply with ADA.	\$0	\$0	2/7/13	FY13 Access UMD project.
451	Jull Hall	227	BLDG	Academic	Building Signage	Install new signs adj. to doors 54 - 60 in. AFF.	\$16,000	\$0	NA	
452	Jull Hall	227	BLDG	Academic	Building Signage	Install signage w/ raised contrasting symbols.	\$16,000	\$0	NA	
453	Jull Hall	227	Outside Room 2111	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
454	Jull Hall	227	2109	Academic	Computer Lab	Widen door to comply with ADA	\$6,000	\$0	NA	
455	Kirwan Hall (formerly Mathematics Building)	084	3206	Academic	Seating/Assembly	Disperse wheelchair seats within the room.	\$11,000	\$0	NA	
456	Kirwan Hall (formerly Mathematics Building)	084	1403	Academic	Visual Alarms	Install additional alarms as needed.	\$17,000	\$0	NA	
457	Kirwan Hall (formerly Mathematics Building)	084	2403	Academic	Visual Alarms	Install additional visual alarms as needed.	\$12,000	\$0	NA	
458	Kirwan Hall (formerly Mathematics Building)	084	3403	Academic	Visual Alarms	Install additional visual alarms as needed.	\$12,000	\$0	NA	
459	Kirwan Hall (formerly Mathematics Building)	084	0493	Academic	Visual Alarms	Install an additional visual alarm.	\$6,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
460	Kirwan Hall (formerly Mathematics Building)	084	B0499	Academic	Visual Alarms	Install an additional visual alarm.	\$6,000	\$0	NA	
461	Kirwan Hall (formerly Mathematics Building)	084	1313	Academic	Classroom	Install door lever or other accessible handle.	\$0	\$0	NA	Completed as part of Item # 488
462	Kirwan Hall (formerly Mathematics Building)	084	2300	Academic	Seminar Room	Install door lever or other accessible handle.	\$0	\$0	NA	Completed as part of Item # 488
463	Kirwan Hall (formerly Mathematics Building)	084	0101	Academic	Classroom	Install door lever or other accessible handle.	\$0	\$0	NA	Completed as part of Item # 488
464	Kirwan Hall (formerly Mathematics Building)	084	0102	Academic	Classroom	Install door lever or other accessible handle.	\$0	\$0	NA	Completed as part of Item # 488
465	Kirwan Hall (formerly Mathematics Building)	084	0103	Academic	Classroom	Install door lever or other accessible handle.	\$0	\$0	NA	Completed as part of Item # 488
466	Kirwan Hall (formerly Mathematics Building)	084	0104	Academic	Classroom	Install door lever or other accessible handle.	\$0	\$0	NA	Completed as part of Item # 488
467	Kirwan Hall (formerly Mathematics Building)	084	0105	Academic	Classroom	Install door lever or other accessible handle.	\$0	\$0	NA	Completed as part of Item # 488
468	Kirwan Hall (formerly Mathematics Building)	084	0106	Academic	Classroom	Install door lever or other accessible handle.	\$0	\$0	NA	Completed as part of Item # 488
469	Kirwan Hall (formerly Mathematics Building)	084	0201	Academic	Classroom	Install door lever or other accessible handle.	\$0	\$0	NA	Completed as part of Item # 488
470	Kirwan Hall (formerly Mathematics Building)	084	0301	Academic	Classroom	Install door lever or other accessible handle.	\$0	\$0	NA	Completed as part of Item # 488
471	Kirwan Hall (formerly Mathematics Building)	084	0302	Academic	Classroom	Install door lever or other accessible handle.	\$0	\$0	NA	Completed as part of Item # 488
472	Kirwan Hall (formerly Mathematics Building)	084	0303	Academic	Classroom	Install door lever or other accessible handle.	\$0	\$0	NA	Completed as part of Item # 488

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
473	Kirwan Hall (formerly Mathematics Building)	084	0304	Academic	Classroom	Install door lever or other accessible handle.	\$0	\$0	NA	Completed as part of Item # 488
474	Kirwan Hall (formerly Mathematics Building)	084	0305	Academic	Classroom	Install door lever or other accessible handle.	\$0	\$0	NA	Completed as part of Item # 488
475	Kirwan Hall (formerly Mathematics Building)	084	0306	Academic	Classroom	Install door lever or other accessible handle.	\$0	\$0	NA	Completed as part of Item # 488
476	Kirwan Hall (formerly Mathematics Building)	084	0307	Academic	Classroom	Install door lever or other accessible handle.	\$0	\$0	NA	Completed as part of Item # 488
477	Kirwan Hall (formerly Mathematics Building)	084	0401	Academic	Classroom	Install door lever or other accessible handle.	\$0	\$0	NA	Completed as part of Item # 488
478	Kirwan Hall (formerly Mathematics Building)	084	0403	Academic	Classroom	Install door lever or other accessible handle.	\$0	\$0	NA	Completed as part of Item # 488
479	Kirwan Hall (formerly Mathematics Building)	084	0405	Academic	Classroom	Install door lever or other accessible handle.	\$0	\$0	NA	Completed as part of Item # 488
480	Kirwan Hall (formerly Mathematics Building)	084	0407	Academic	Classroom	Install door lever or other accessible handle.	\$0	\$0	NA	Completed as part of Item # 488
481	Kirwan Hall (formerly Mathematics Building)	084	0409	Academic	Classroom	Install door lever or other accessible handle.	\$0	\$0	NA	Completed as part of Item # 488
482	Kirwan Hall (formerly Mathematics Building)	084	0411	Academic	Classroom	Install door lever or other accessible handle.	\$0	\$0	NA	Completed as part of Item # 488
483	Kirwan Hall (formerly Mathematics Building)	084	B0423	Academic	Classroom	Install door lever or other accessible handle.	\$0	\$0	NA	Completed as part of Item # 488
484	Kirwan Hall (formerly Mathematics Building)	084	B0425	Academic	Classroom	Install door lever or other accessible handle.	\$0	\$0	NA	Completed as part of Item # 488
485	Kirwan Hall (formerly Mathematics Building)	084	B0427	Academic	Classroom	Install door lever or other accessible handle.	\$0	\$0	NA	Completed as part of Item # 488

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
486	Kirwan Hall (formerly Mathematics Building)	084	B0429	Academic	Classroom	Install door lever or other accessible handle.	\$0	\$0	NA	Completed as part of Item # 488
487	Kirwan Hall (formerly Mathematics Building)	084	B0431	Academic	Seminar Room	Install door lever or other accessible handle.	\$0	\$0	NA	Completed as part of Item # 488
488	Kirwan Hall (formerly Mathematics Building)	084	B0431	Academic	Seminar Room	Install door lever or other accessible handle.	\$0	\$110,880	10/18/19	FY20 Access UMD Project implemented by Building Security (Shelter in-Place Locks)
489	Kirwan Hall (formerly Mathematics Building)	084	Near Door 0498	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
490	Kirwan Hall (formerly Mathematics Building)	084	Near Elevator 2497	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
491	Kirwan Hall (formerly Mathematics Building)	084	Near Elevator 3497	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
492	Kirwan Hall (formerly Mathematics Building)	084	Near Elevator 4497	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
493	Kirwan Hall (formerly Mathematics Building)	084	Outside Room 0106	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
494	Kirwan Hall (formerly Mathematics Building)	084	Outside Room 0302	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
495	Kirwan Hall (formerly Mathematics Building)	084	Outside Room 1114	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
496	Kirwan Hall (formerly Mathematics Building)	084	Outside Room 1303	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
497	Kirwan Hall (formerly Mathematics Building)	084	Outside Room 2116	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
498	Kirwan Hall (formerly Mathematics Building)	084	Outside Room 2313	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
499	Kirwan Hall (formerly Mathematics Building)	084	Outside Room 3116	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
500	Kirwan Hall (formerly Mathematics Building)	084	Outside Room 3304	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
501	Kirwan Hall (formerly Mathematics Building)	084	Outside Room 4204	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
502	Kirwan Hall (formerly Mathematics Building)	084	Outside Room B0421	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
503	Kirwan Hall (formerly Mathematics Building)	084	1496	Academic	Visual Alarms	Remount visual alarms at correct height.	\$4,000	\$0	NA	
504	Kirwan Hall (formerly Mathematics Building)	084	2198	Academic	Visual Alarms	Remount visual alarms at correct height.	\$4,000	\$0	NA	
505	Kirwan Hall (formerly Mathematics Building)	084	2299	Academic	Visual Alarms	Remount visual alarms at correct height.	\$4,000	\$0	NA	
506	Kirwan Hall (formerly Mathematics Building)	084	2499	Academic	Visual Alarms	Remount visual alarms at correct height.	\$4,000	\$0	NA	
507	Kirwan Hall (formerly Mathematics Building)	084	3198	Academic	Visual Alarms	Remount visual alarms at correct height.	\$4,000	\$0	NA	
508	Kirwan Hall (formerly Mathematics Building)	084	3299	Academic	Visual Alarms	Remount visual alarms at correct height.	\$4,000	\$0	NA	
509	Kirwan Hall (formerly Mathematics Building)	084	0493	Academic	Visual Alarms	Remount visual alarms at correct height.	\$4,000	\$0	NA	
510	Kirwan Hall (formerly Mathematics Building)	084	1403	Academic	Visual Alarms	Remount visual alarms at correct height.	\$4,000	\$0	NA	
511	Kirwan Hall (formerly Mathematics Building)	084	3206	Academic	Visual Alarms	Remount visual alarms at correct height.	\$4,000	\$0	NA	
512	Kirwan Hall (formerly Mathematics Building)	084	3399	Academic	Visual Alarms	Remount visual alarms at correct height.	\$4,000	\$0	NA	
513	Kirwan Hall (formerly Mathematics Building)	084	B0499	Academic	Visual Alarms	Remount visual alarms at correct height.	\$4,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
514	Knight Hall	417	NA	Academic	Signage	Install 2 granite markers on the east side of Knight Hall to direct individuals in wheelchairs to the accessible entrance.	\$0	\$0	7/30/12	FY 2012 Access UMD Project (\$365)
515	Knight Hall	417	Across 1105	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
516	Knight Hall	417	Across 2105	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
517	Knight Hall	417	Across 3105	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
518	Lefrak Hall	038	2166	Academic	Classroom	Replace door knob with lever	\$3,000	\$0	NA	
519	Lefrak Hall	038	2205	Academic	Lecture Hall	Widen door and change door knob with lever	\$6,000	\$0	NA	
520	Lefrak Hall	038	2205	Academic	Lecture Hall	Widen door and change door knob with lever	\$6,000	\$0	NA	
521	Lefrak Hall	038	2205	Academic	Lecture Hall	Widen door and change door knob with lever	\$6,000	\$0	NA	
522	Lefrak Hall	038	2205	Academic	Lecture Hall	Widen door and change door knob with lever	\$6,000	\$0	NA	
523	Lefrak Hall	038	2205	Academic	Lecture Hall	Widen door and change door knob with lever	\$6,000	\$0	NA	
524	Lefrak Hall	038	2205	Academic	Lecture Hall	Widen door and change door knob with lever	\$6,000	\$0	NA	
525	Lefrak Hall	038	2205	Academic	Lecture Hall	Widen door and change door knob with lever	\$6,000	\$0	NA	
526	Lefrak Hall	038	0191 / 0194	Academic	Clinic Room	Install automatic door opener to entrance doors 0191 and 0194.	\$19,000	\$0	NA	New Survey 2016

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
527	Lefrak Hall	038	1201	Academic	Classroom	Install door lever or other accessible handle.	\$3,000	\$0	NA	
528	Lefrak Hall	038	1208	Academic	Classroom	Install door lever or other accessible handle.	\$3,000	\$0	NA	
529	Lefrak Hall	038	1220	Academic	Classroom	Install door lever or other accessible handle.	\$3,000	\$0	NA	
530	Lefrak Hall	038	1221	Academic	Lecture Room	Install door lever or other accessible handle.	\$3,000	\$0	NA	
531	Lefrak Hall	038	1222	Academic	Classroom	Install door lever or other accessible handle.	\$3,000	\$0	NA	
532	Lefrak Hall	038	0225	Academic	laboratory	Install door lever or other accessible handle.	\$3,000	\$0	NA	
533	Lefrak Hall	038	0229	Academic	laboratory	Install door lever or other accessible handle.	\$3,000	\$0	NA	
534	Lefrak Hall	038	N/A	Academic	Signage	Install wayfinding signs for wheelchairs users to locate ramps at Lefrak Hall.	\$3,000	\$0	NA	New Survey 2016
535	Lefrak Hall	038	0104	Academic	Doors (Office)	Replace door knob with lever or other accessible handle	\$3,000	\$0	NA	New Survey 2016
536	Lefrak Hall	038	0110	Academic	Doors (waiting room)	Replace door knob with lever or other accessible handle	\$3,000	\$0	NA	New Survey 2016
537	Lefrak Hall	038	0111	Academic	Clinic Room	Replace door knob with lever or other accessible handle	\$3,000	\$0	NA	New Survey 2016
538	Lefrak Hall	038	0116	Academic	Doors (observation room)	Replace door knob with lever or other accessible handle	\$3,000	\$0	NA	New Survey 2016
539	Lefrak Hall	038	0118	Academic	Doors (therapy Room)	Replace door knob with lever or other accessible handle	\$3,000	\$0	NA	New Survey 2016
540	Lefrak Hall	038	0119	Academic	Doors (Research)	Replace door knob with lever or other accessible handle	\$3,000	\$0	NA	New Survey 2016

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
541	Lefrak Hall	038	0120	Academic	Doors (Classroom)	Replace door knob with lever or other accessible handle	\$3,000	\$0	NA	New Survey 2016
542	Lefrak Hall	038	0123	Academic	Doors (Office)	Replace door knob with lever or other accessible handle	\$3,000	\$0	NA	New Survey 2016
543	Lefrak Hall	038	0125	Academic	Doors (Office)	Replace door knob with lever or other accessible handle	\$3,000	\$0	NA	New Survey 2016
544	Lefrak Hall	038	0127	Academic	Doors (Office)	Replace door knob with lever or other accessible handle	\$3,000	\$0	NA	New Survey 2016
545	Lefrak Hall	038	0129	Academic	Doors (Office)	Replace door knob with lever or other accessible handle	\$3,000	\$0	NA	New Survey 2016
546	Lefrak Hall	038	0130	Academic	Doors	Replace door knob with lever or other accessible handle	\$3,000	\$0	NA	New Survey 2016
547	Lefrak Hall	038	0133	Academic	Doors (Research)	Replace door knob with lever or other accessible handle	\$3,000	\$0	NA	New Survey 2016
548	Lefrak Hall	038	0136	Academic	Doors (therapy Room)	Replace door knob with lever or other accessible handle	\$3,000	\$0	NA	New Survey 2016
549	Lefrak Hall	038	0138	Academic	Doors (Research)	Replace door knob with lever or other accessible handle	\$3,000	\$0	NA	New Survey 2016
550	Lefrak Hall	038	0141	Academic	Doors (Office)	Replace door knob with lever or other accessible handle	\$3,000	\$0	NA	New Survey 2016
551	Lefrak Hall	038	0291	Academic	Doors	Replace door knob with lever or other accessible handle	\$3,000	\$0	NA	New Survey 2016
552	LeFrak Hall	038	Near Stairs 2195	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
553	Lefrak Hall	038	1138	Academic	Computer Lab	Reverse door swing	\$4,000	\$0	NA	
554	Lefrak Hall	038	BLDG	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	New Survey 2016

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
555	Marie Mount Hall	046	1304	Academic	Classroom	Widen door to comply with ADA	\$6,000	\$0	NA	
556	Marie Mount Hall	046	0110C	Academic	Fixed Work Area	Adjust work area height to 28 - 34 in. AFF.	\$3,000	\$0	NA	
557	Marie Mount Hall	046	2211	Academic	Fixed Work Area	Adjust work area height to 28 - 34 in. AFF.	\$5,000	\$0	NA	
558	Marie Mount Hall	046	3401	Academic	Fume Hood	Increase depth of knee space to 19 in. min.	\$4,000	\$0	NA	
559	Marie Mount Hall	046	2201	Academic	Fume Hood	Increase depth of knee space to 19 in. min.	\$4,000	\$0	NA	
560	Marie Mount Hall	046	2211	Academic	Fume Hood	Increase depth of knee space to 19 in. min.	\$4,000	\$0	NA	
561	Marie Mount Hall	046	3401	Academic	Fixed Work Area	Increase height of knee space to 27 in. min.	\$5,000	\$0	NA	
562	Marie Mount Hall	046	2211	Academic	Fixed Work Area	Increase height of knee space to 27 in. min.	\$5,000	\$0	NA	
563	Marie Mount Hall	046	2218	Academic	Fixed Work Area	Increase height of knee space to 27 in. min.	\$5,000	\$0	NA	
564	Marie Mount Hall	046	1407	Academic	Study Room	Install beveled door threshold	\$8,000	\$0	NA	
565	Marie Mount Hall	046	2211	Academic	Fume Hood	Install controls that do not require tight grasp/twist.	\$5,000	\$0	NA	
566	Marie Mount Hall	046	2218	Academic	Fume Hood	Install controls that do not require tight grasp/twist.	\$5,000	\$0	NA	
567	Marie Mount Hall	046	3401	Academic	Fume Hood	Install controls that do not require tight grasp/twist.	\$5,000	\$0	NA	
568	Marie Mount Hall	046	2201	Academic	Fume Hood	Install controls that do not require tight grasp/twist.	\$5,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
569	Marie Mount Hall	046	1218	Academic	Seminar Room	Install door lever or other accessible handle.	\$3,000	\$0	NA	
570	Marie Mount Hall	046	3112	Academic	Teaching Lab	Install door lever or other accessible handle.	\$3,000	\$0	NA	
571	Marie Mount Hall	046	3422	Academic	laboratory	Install door lever or other accessible handle.	\$3,000	\$0	NA	
572	Marie Mount Hall	046	3424	Academic	laboratory	Install door lever or other accessible handle.	\$3,000	\$0	NA	
573	Marie Mount Hall	046	0401	Academic	Class Lab	Install door lever or other accessible handle.	\$3,000	\$0	NA	
574	Marie Mount Hall	046	1407D	Academic	Study Room	Install door lever or other accessible handle.	\$3,000	\$0	NA	
575	Marie Mount Hall	046	2201	Academic	Fume Hood	Lower height of hood cabinet to 28 - 34 in. AFF.	\$4,000	\$0	NA	
576	Marie Mount Hall	046	2401	Academic	Fume Hood	Lower ht. of hood cabinet to 28 - 34 in. AFF.	\$4,000	\$0	NA	
577	Marie Mount Hall	046	3401	Academic	Fume Hood	Lower ht. of hood cabinet to 28 - 34 in. AFF.	\$0	\$0	00/00/16	Completed 2016
578	Marie Mount Hall	046	2211	Academic	Fume Hood	Lower ht. of hood cabinet to 28 - 34 in. AFF.	\$4,000	\$0	NA	
579	Marie Mount Hall	046	Near Stairs 1298	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
580	Marie Mount Hall	046	Outside Room 1218	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
581	Marie Mount Hall	046	Outside Room 3218	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
582	Marie Mount Hall	046	1400	Academic	Multimedia Lecture Room	Widen door and change door knob with lever	\$6,000	\$0	NA	
583	Marie Mount Hall	046	1400	Academic	Multimedia Lecture Room	Widen door to comply with ADA	\$6,000	\$0	NA	
584	Marie Mount Hall	046	3401	Academic	laboratory	Widen door to comply with ADA	\$6,000	\$0	NA	
585	Marie Mount Hall	046	BLDG	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	New Survey 2016
586	Martin Hall	088	2140	Academic	Fume Hood	Increase width of knee space to 30 in. min.	\$5,000	\$0	NA	
587	Martin Hall	088	2103	Academic	Seating/Assembly	Install hearing loss signs at primary entrances.	\$9,000	\$0	NA	
588	Martin Hall	088	2107	Academic	Seating/Assembly	Install hearing loss signs at primary entrances.	\$9,000	\$0	NA	
589	Martin Hall	088	2140	Academic	Fume Hood	Lower ht. of hood cabinet to between 28 - 34 in.	\$4,000	\$0	NA	
590	Martin Hall	088	0136	Academic	Fume Hood	Lower ht. of hood cabinet to between 28 - 34 in.	\$4,000	\$0	NA	
591	McKeldin Library	035	3213	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
592	McKeldin Library	035	3215	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
593	McKeldin Library	035	3217	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
594	McKeldin Library	035	3219	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
595	McKeldin Library	035	3221	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
596	McKeldin Library	035	3223	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
597	McKeldin Library	035	3225	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
598	McKeldin Library	035	3227	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
599	McKeldin Library	035	3231	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
600	McKeldin Library	035	3235	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
601	McKeldin Library	035	3237	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
602	McKeldin Library	035	3239	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
603	McKeldin Library	035	3241	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
604	McKeldin Library	035	3243	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
605	McKeldin Library	035	3245	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
606	McKeldin Library	035	3247	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
607	McKeldin Library	035	3249	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
608	McKeldin Library	035	3251	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
609	McKeldin Library	035	3253	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
610	McKeldin Library	035	3255	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
611	McKeldin Library	035	3257	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
612	McKeldin Library	035	3259	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
613	McKeldin Library	035	3261	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
614	McKeldin Library	035	4100	Library	Study Room	Replace door knob with lever	\$3,000	\$0	NA	
615	McKeldin Library	035	4114	Library	Computer Lab	Replace door knob with lever	\$3,000	\$0	NA	
616	McKeldin Library	035	4209	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
617	McKeldin Library	035	4211	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
618	McKeldin Library	035	4213	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
619	McKeldin Library	035	4215	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
620	McKeldin Library	035	4217	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
621	McKeldin Library	035	4219	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
622	McKeldin Library	035	4221	Library	Tele Comm	Replace door knob with lever	\$3,000	\$0	NA	
623	McKeldin Library	035	4223	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
624	McKeldin Library	035	4225	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
625	McKeldin Library	035	4227	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
626	McKeldin Library	035	4229	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
627	McKeldin Library	035	4231	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
628	McKeldin Library	035	4235	Library	Study Room	Replace door knob with lever	\$3,000	\$0	NA	
629	McKeldin Library	035	4237	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
630	McKeldin Library	035	4239	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
631	McKeldin Library	035	4241	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
632	McKeldin Library	035	4243	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
633	McKeldin Library	035	4245	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
634	McKeldin Library	035	4247	Library	Tele Comm	Replace door knob with lever	\$3,000	\$0	NA	
635	McKeldin Library	035	4249	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
636	McKeldin Library	035	4251	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
637	McKeldin Library	035	4253	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
638	McKeldin Library	035	4255	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
639	McKeldin Library	035	4257	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
640	McKeldin Library	035	4259	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
641	McKeldin Library	035	6209	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
642	McKeldin Library	035	6211	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
643	McKeldin Library	035	6215	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
644	McKeldin Library	035	6217	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
645	McKeldin Library	035	6219	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
646	McKeldin Library	035	6221	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
647	McKeldin Library	035	6223	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
648	McKeldin Library	035	6225	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
649	McKeldin Library	035	6227	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
650	McKeldin Library	035	6229	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
651	McKeldin Library	035	6235	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
652	McKeldin Library	035	6237	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
653	McKeldin Library	035	6239	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
654	McKeldin Library	035	6241	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
655	McKeldin Library	035	6243	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
656	McKeldin Library	035	6245	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
657	McKeldin Library	035	6247	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
658	McKeldin Library	035	6249	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
659	McKeldin Library	035	6251	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
660	McKeldin Library	035	6253	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
661	McKeldin Library	035	6255	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
662	McKeldin Library	035	6257	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
663	McKeldin Library	035	6259	Library	UMUC Reference	Replace door knob with lever	\$3,000	\$0	NA	
664	McKeldin Library	035	6261	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
665	McKeldin Library	035	7209	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
666	McKeldin Library	035	7211	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
667	McKeldin Library	035	7213	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
668	McKeldin Library	035	7215	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
669	McKeldin Library	035	7217	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
670	McKeldin Library	035	7219	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
671	McKeldin Library	035	7221	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
672	McKeldin Library	035	7223	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
673	McKeldin Library	035	7225	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
674	McKeldin Library	035	7227	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
675	McKeldin Library	035	7229	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
676	McKeldin Library	035	7231	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
677	McKeldin Library	035	7235	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
678	McKeldin Library	035	7237	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
679	McKeldin Library	035	7239	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
680	McKeldin Library	035	7241	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
681	McKeldin Library	035	7243	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
682	McKeldin Library	035	7245	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
683	McKeldin Library	035	7247	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
684	McKeldin Library	035	7251	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
685	McKeldin Library	035	7253	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
686	McKeldin Library	035	7255	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
687	McKeldin Library	035	7257	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
688	McKeldin Library	035	7259	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
689	McKeldin Library	035	7261	Library	Study Carrel	Replace door knob with lever	\$3,000	\$0	NA	
690	McKeldin Library	035	1113B	Library	Study Room	Replace door knob with lever	\$3,000	\$0	NA	
691	McKeldin Library	035	1141	Library	Study Room	Widen door to comply with ADA	\$6,000	\$0	NA	
692	McKeldin Library	035	2100	Library	Library areas	Adjust height, computer resources to 28-34" AFF.	\$16,000	\$0	NA	
693	McKeldin Library	035	Adjacent to Room 1103	Library	Hallway	Raise water cooler to comply with ADA	\$4,000	\$0	NA	
694	McKeldin Library	035	Outside Room 1205	Library	Hallway	Raise water cooler to comply with ADA	\$4,000	\$0	NA	
695	McKeldin Library	035	Outside Room 3203	Library	Hallway	Raise water cooler to comply with ADA	\$4,000	\$0	NA	
696	McKeldin Library	035	Outside Room 4203	Library	Hallway	Raise water cooler to comply with ADA	\$4,000	\$0	NA	
697	McKeldin Library	035	Outside Room 6203	Library	Hallway	Raise water cooler to comply with ADA	\$4,000	\$0	NA	
698	Memorial Chapel	009	Pew	Non-Academic	Accessible Seats	Cutting of two pews in West Chapel for Wheelchair access.	\$0	\$0	8/6/2013	FY 2014 Access UMD Project

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
699	MFRI Office/ Classroom Bldg. (College Park, MD)	199	1102	Academic Support - MFRI	Open Lab	Install door lever or other accessible handle.	\$3,000	\$0	NA	
700	MFRI Office/ Classroom Bldg. (College Park, MD)	199	1105	Academic Support - MFRI	Class	Install door lever or other accessible handle.	\$3,000	\$0	NA	
701	MFRI Office/ Classroom Bldg. (College Park, MD)	199	1127	Academic Support - MFRI	Open Lab	Install door lever or other accessible handle.	\$3,000	\$0	NA	
702	MFRI Office/ Classroom Bldg. (College Park, MD)	199	1129	Academic Support - MFRI	Open Lab	Install door lever or other accessible handle.	\$3,000	\$0	NA	
703	MFRI Office/ Classroom Bldg. (College Park, MD)	199	2101	Academic Support - MFRI	Class Lab	Install door lever or other accessible handle.	\$3,000	\$0	NA	
704	MFRI Office/ Classroom Bldg. (College Park, MD)	199	1104WT	Academic Support - MFRI	Manual door/opng.	Install lever or other accessible handle.	\$3,000	\$0	NA	
705	MFRI Office/ Classroom Bldg. (College Park, MD)	199	1106MT	Academic Support - MFRI	Manual door/opng.	Install lever or other accessible handle.	\$3,000	\$0	NA	
706	Microbiology Building	231	1107	Academic	Fixed Work Area	Adjust one work area height to 28 - 34 in. AFF.	\$4,000	\$0	NA	
707	Microbiology Building	231	1135	Academic	Fixed Work Area	Adjust one work area height to 28 - 34 in. AFF.	\$4,000	\$0	NA	
708	Microbiology Building	231	1138	Academic	Fixed Work Area	Adjust one work area height to 28 - 34 in. AFF.	\$4,000	\$0	NA	
709	Microbiology Building	231	1114	Academic	Fixed Work Area	Adjust one work area height to 28 - 34 in. AFF.	\$4,000	\$0	NA	
710	Microbiology Building	231	1138	Academic	Fixed Work Area	Adjust width of one knee space to 30 in. min.	\$4,000	\$0	NA	
711	Microbiology Building	231	1114	Academic	Fixed Work Area	Adjust width of one knee space to 30 in. min.	\$4,000	\$0	NA	
712	Microbiology Building	231	1135	Academic	Fixed Work Area	Adjust width of one knee space to 30 in. min.	\$4,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
713	Microbiology Building	231	2201	Academic	Fixed Work Area	Adjust width of one knee space to 30 in. min.	\$3,000	\$0	NA	
714	Microbiology Building	231	1135	Academic	Fume Hood	Increase depth of knee space to 19 in. min.	\$4,000	\$0	NA	
715	Microbiology Building	231	1107	Academic	Fume Hood	Increase depth of one knee space to 19 in. min.	\$4,000	\$0	NA	
716	Microbiology Building	231	1143	Academic	Fume Hood	Increase depth of one knee space to 19 in. min.	\$4,000	\$0	NA	
717	Microbiology Building	231	1135	Academic	Class Lab	Install door lever or other accessible handle.	\$3,000	\$0	NA	
718	Microbiology Building	231	1138	Academic	Class Lab	Install door lever or other accessible handle.	\$3,000	\$0	NA	
719	Microbiology Building	231	1143	Academic	Class Lab	Install door lever or other accessible handle.	\$3,000	\$0	NA	
720	Microbiology Building	231	1201	Academic	Class Lab	Install door lever or other accessible handle.	\$3,000	\$0	NA	
721	Microbiology Building	231	1206	Academic	Class Lab	Install door lever or other accessible handle.	\$3,000	\$0	NA	
722	Microbiology Building	231	1143	Academic	Fume Hood	Lower height of one hood cabinet to 28 - 34 in. AFF.	\$4,000	\$0	NA	
723	Microbiology Building	231	1107	Academic	Fume Hood	Lower height of one hood cabinet to 28 - 34 in. AFF.	\$4,000	\$0	NA	
724	Microbiology Building	231	1135	Academic	Fume Hood	Lower height of one hood cabinet to 28 - 34 in. AFF.	\$4,000	\$0	NA	
725	Microbiology Building	231	2201	Academic	Fume Hood	Lower height of one hood cabinet to 28 - 34 in. AFF.	\$4,000	\$0	NA	
726	Microbiology Building	231	1207	Academic	Seating/Assembly	Provide addnl. wheelchair spaces total, >=4.	\$8,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
727	Microbiology Building	231	1207	Academic	Seating/Assembly	Provide adjacent companion seating.	\$8,000	\$0	NA	
728	Mitchell Building	052	0199	Administrative	Drinking Fountain	Replace exit. fountain with accessible unit.	\$6,000	\$0	NA	
729	Morrill Hall	040	EE1198	Academic	Manual door/opngs.	Provide min. 32 in. clear opening.	\$6,000	\$0	NA	
730	Morrill Hall	040	BLDG	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	New Survey 2016
731	Physics Building	082	4303	Academic	Fume Hood	Lower height of hood cabinet to be 28-34 in.	\$4,000	\$0	NA	
732	Plant Sciences Building	036	Next to Room 3162	Aademic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
733	Plant Sciences Building	036	Next to Room 4119	Aademic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
734	Plant Sciences Building	036	Next to Room 4152	Aademic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
735	Plant Sciences Building	036	Next to Room 5146	Aademic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
736	Plant Sciences Building	036	Next to Room 6146	Aademic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
737	Plant Sciences Building	036	Next to Room 1111	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
738	Plant Sciences Building	036	Across to Room 2104	Academic	Hallway	Lower or raise one water cooler to comply with ADA	\$4,000	\$0	NA	
739	Plant Sciences Building	036	Next to Room 1129	Academic	Hallway	Lower or raise one water cooler to comply with ADA	\$4,000	\$0	NA	
740	Plant Sciences Building	036	Next to Room 1150	Academic	Hallway	Lower or raise one water cooler to comply with ADA	\$4,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
741	Plant Sciences Building	036	Next to Room 1181	Academic	Hallway	Lower or raise one water cooler to comply with ADA	\$4,000	\$0	NA	
742	Plant Sciences Building	036	Next to Room 2153	Academic	Hallway	Lower or raise one water cooler to comply with ADA	\$4,000	\$0	NA	
743	Preinkert Hall	054	112	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
744	Preinkert Hall	054	2102	Academic	Class Lab	Widen door to comply with ADA	\$6,000	\$0	NA	
745	School of Public Health Buiding	255	NA	Academic	Doors	Add two 110 volt outlets (one each) at 2 new handicap operator locations.	\$0	\$0	11/2/2010	UMD Funded Project (\$1,600)
746	School of Public Health Buiding	255	2303	Academic	Doors	Renovate Suite 2303 Lab & associated work to meet ADA.	\$0	0	9/28/2012	FY 2011 Access UMD Project (\$26,322)
747	School of Public Health Building	255		Academic	Auto Door Opener	Install automatic door openers at the two main entrances to the ground level of the building.	\$0	\$0	8/8/2012	FY 2012 Access UMD Project (\$16,272)
748	School of Public Health Building	255	1301	Academic	Class	Install door lever or other accessible handle.	\$3,000	\$0	NA	
749	School of Public Health Building	255	1302	Academic	Class	Install door lever or other accessible handle.	\$3,000	\$0	NA	
750	School of Public Health Building	255	1303	Academic	Lecture	Install door lever or other accessible handle.	\$3,000	\$0	NA	
751	School of Public Health Building	255	0301	Academic	Class	Install door lever or other accessible handle.	\$3,000	\$0	NA	
752	School of Public Health Building	255	0302	Academic	Class	Install door lever or other accessible handle.	\$3,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
753	School of Public Health Building	255	0308	Academic	Class	Install door lever or other accessible handle.	\$3,000	\$0	NA	
754	School of Public Health Building	255	Across from 0114	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
755	School of Public Health Building	255	Near 0394	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
756	School of Public Health Building	255	Next to 0107	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
757	School of Public Health Building	255	Next to 0115	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
758	School of Public Health Building	255	Next to 0124	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
759	School of Public Health Building	255	Next to 0124	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
760	School of Public Health Building	255	Next to 0311	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
761	School of Public Health Building	255	Next to 1307	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
762	School of Public Health Building	255	Next to 1308	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
763	Seyern Building	810	BLDG	Non-Academic	Manual door/opng.	Replace entry doors and install automatic door openers with key card access.	\$0	\$23,000	12/10/17	FY 2017 Design & Const Funded Project
764	Shoemaker Building	037	2109 / 2125	Academic	Classroom	Install card access to automatic door opener to testing Suite 2109/2125.	\$0	\$0	5/17/16	FY16 Access UMD Project.
765	Skinner Building	044	0200	Academic	Seating/Assembly	Disperse wheelchair locations within the room.	\$11,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
766	Skinner Building	044	1112	Academic	Class	Install door lever or other accessible handle.	\$0	\$0	00/00/16	Completed 2016
767	Skinner Building	044	1116	Academic	Seminar Room	Install door lever or other accessible handle.	\$3,000	\$0	NA	
768	Skinner Building	044	Next to 0113	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
769	Skinner Building	044	0105	Academic	Study Room	Widen door and change door knob with lever	\$6,000	\$0	NA	
770	Skinner Building	044	2117	Academic	Open Lab	Widen door to comply with ADA	\$6,000	\$0	NA	
771	Skinner Building	044	3117	Academic	Seminar Room	Widen door to comply with ADA	\$6,000	\$0	NA	
772	Susquehanna Hall	233	1101	Academic	classroom	Install door lever or other accessible handle.	\$3,000	\$0	NA	
773	Susquehanna Hall	233	1103	Academic	classroom	Install door lever or other accessible handle.	\$3,000	\$0	NA	
774	Susquehanna Hall	233	1105	Academic	classroom	Install door lever or other accessible handle.	\$3,000	\$0	NA	
775	Susquehanna Hall	233	1107	Academic	classroom	Install door lever or other accessible handle.	\$3,000	\$0	NA	
776	Susquehanna Hall	233	1111	Academic	classroom	Install door lever or other accessible handle.	\$3,000	\$0	NA	
777	Susquehanna Hall	233	1117	Academic	classroom	Install door lever or other accessible handle.	\$3,000	\$0	NA	
778	Susquehanna Hall	233	1119	Academic	classroom	Install door lever or other accessible handle.	\$3,000	\$0	NA	
779	Susquehanna Hall	233	1121	Academic	classroom	Install door lever or other accessible handle.	\$3,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
780	Susquehanna Hall	233	1123	Academic	classroom	Install door lever or other accessible handle.	\$3,000	\$0	NA	
781	Susquehanna Hall	233	2101	Academic	Office	Install door lever or other accessible handle.	\$3,000	\$0	NA	
782	Susquehanna Hall	233	2101A	Academic	Office	Install door lever or other accessible handle.	\$3,000	\$0	NA	New Survey 2020
783	Susquehanna Hall	233	2101B	Academic	Office	Install door lever or other accessible handle.	\$3,000	\$0	NA	New Survey 2020
784	Susquehanna Hall	233	2101D	Academic	Office	Install door lever or other accessible handle.	\$3,000	\$0	NA	New Survey 2020
785	Susquehanna Hall	233	2101E	Academic	Office	Install door lever or other accessible handle.	\$3,000	\$0	NA	New Survey 2020
786	Susquehanna Hall	233	2117	Academic	classroom	Install door lever or other accessible handle.	\$3,000	\$0	NA	
787	Susquehanna Hall	233	2119	Academic	classroom	Install door lever or other accessible handle.	\$3,000	\$0	NA	
788	Susquehanna Hall	233	2121	Academic	classroom	Install door lever or other accessible handle.	\$3,000	\$0	NA	
789	Susquehanna Hall	233	4135	Academic	Conference Room	Install door lever or other accessible handle.	\$3,000	\$0	NA	
790	Susquehanna Hall	233	2116E	Academic	open lab	Install door lever or other accessible handle.	\$3,000	\$0	NA	
791	Susquehanna Hall	233	1120	Academic	Lecture Hall	Widen door to comply with ADA	\$6,000	\$0	NA	
792	Symons Hall	076	2213	Academic	Manual door/opening	Create more clearance at latch or reverse door swing.	\$5,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
793	Symons Hall	076	0115	Academic	Open Lab	Install auto door opener to increase inside door approach for ADA.	\$9,000	\$0	NA	New Survey 2016
794	Symons Hall	076	1321	Academic	Open Lab	Install beveled door threshold	\$8,000	\$0	NA	
795	Symons Hall	076		Academic	Hallway	Install new ADA accessible Water Coolers, total of four (4) on 1st, 2nd, and 3rd floor Public Hallway.	\$0	\$0	5/7/12	FY 2013 Access UMD Project (\$12,976)
796	Symons Hall	076	0200	Academic	Seating/Assembly	Provide additional wheelchair spaces so total >=4.	\$0	\$0	00/0/15	Completed 2015
797	Symons Hall	076	2195	Academic	Drinking Fountain	Replace existing fountain with accessible unit.	\$0	\$0	00/0/15	Completed 2015
798	Symons Hall	076	3299	Academic	Drinking Fountain	Replace existing fountain with accessible unit.	\$0	\$0	00/0/15	Completed 2015
799	Symons Hall	076	1195	Academic	Drinking Fountain	Replace existing fountain with accessible unit.	\$0	\$0	00/0/15	Completed 2015
800	Symons Hall	076	Outside Room 0202	Academic	Hallway	Replace non-ADA water cooler	\$0	\$0	00/0/15	Completed 2015
801	Symons Hall	076	Outside Room 1125	Academic	Hallway	Replace non-ADA water cooler	\$0	\$0	00/0/15	Completed 2015
802	Symons Hall	076	Outside Room 1203	Academic	Hallway	Replace non-ADA water cooler	\$0	\$0	00/0/15	Completed 2015
803	Symons Hall	076	Outside Room 2101	Academic	Hallway	Replace non-ADA water cooler	\$0	\$0	00/0/15	Completed 2015
804	Symons Hall	076	Outside Room 2125	Academic	Hallway	Replace non-ADA water cooler	\$0	\$0	00/0/15	Completed 2015
805	Symons Hall	076	Outside Room 3125	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
806	Taliaferro Hall	043	0197	Academic	Drinking Fountain	Replace exist. fountain with accessible unit.	\$6,000	\$0	NA	
807	Taliaferro Hall	043	Across 2106	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
808	Taliaferro Hall	043	Next to 0107	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
809	Taliaferro Hall	043	Next to 1123A	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
810	Taliaferro Hall	043	Next to 0106	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
811	Taliaferro Hall	043	Next to 1104	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
812	Taliaferro Hall	040	BLDG	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	New Survey 2016
813	Turfgrass Research Facility (Paint Branch)	395	NA	Academic	Auto Door Opener	Install six power operating door opener at the over head doors.	\$30,000	\$0	NA	New Survey
814	Turner Hall	079	2101	Administrative	Circulation Spaces	Bevel change of level (max. slope 1: 12).	\$3,000	\$0	NA	
815	Tydings Hall	042	1101	Academic	Lecture	Install door lever or other accessible handle.	\$3,000	\$0	NA	
816	Tydings Hall	042	2108	Academic	Class	Install door lever or other accessible handle.	\$3,000	\$0	NA	
817	Tydings Hall	042	2110	Academic	Class	Install door lever or other accessible handle.	\$3,000	\$0	NA	
818	Tydings Hall	042	Next 0107	Academic	Hallway	Raise cooler to comply with ADA	\$4,000	\$0	NA	
819	Tydings Hall	042	Next 2109	Academic	Hallway	Raise water cooler to comply with ADA	\$4,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
820	Tydings Hall	042	0196	Academic	Drinking Fountain	Replace exist. fountain with accessible unit.	\$6,000	\$0	NA	
821	Tydings Hall	042	Near 3107	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
822	Tydings Hall	042	Near 3120	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
823	Tydings Hall	042	Next 0120	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
824	Tydings Hall	042	Next 1101	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
825	Tydings Hall	042	Next 1196	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
826	Tydings Hall	042	Next 2102	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
827	Tydings Hall	042	Next 4107	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
828	Tydings Hall	042	Next 4120	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
829	Tydings Hall	042	BLDG	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	New Survey 2016
830	Tydings Hall	042	Next to 3105 and 3105	Academic	Hallway	Replace non-ADA water cooler next to rooms 3104 and 3105	\$0	\$3,700	12/10/17	Projcet not in 2016 Transition Plan, but completed in 2017
831	Van Munching Hall	039	Next 1329 (ii)	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
832	Van Munching Hall	039	Next 1597 (ii)	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
833	Van Munching Hall	039	Next 2329 (i)	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
834	Van Munching Hall	039	Next 2501 (i)	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
835	Van Munching Hall	039	Next 3327 (ii)	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
836	Van Munching Hall	039	Next 3501 (i)	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
837	Van Munching Hall	039	Next 4330 (ii)	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
838	Van Munching Hall	039	Next 4597 (i)	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
839	Van Munching Hall	039	Next to 1289 (i)	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
840	Van Munching Hall	039	1212	Academic	Lecture	Provide wheelchair space	\$3,000	\$0	NA	
841	Van Munching Hall	039	1412	Academic	Class	Provide wheelchair space	\$3,000	\$0	NA	
842	Van Munching Hall	039	1418	Academic	Class	Provide wheelchair space	\$3,000	\$0	NA	
843	William E. Kirwan Hall (formerly Mathematics Building)	084	0402B	Academic	Classroom	Replace existing doors to comply with ADA (one with cardswipe); renovate space to provide a classroom for Developmental Math as part of Cole Relocation effort.	\$0	\$0	12/31/15	Completed 2015 (Operation & Maintenance)
844	Wind Tunnel Building	081	1101A	Academic	Manual door/opening	Replace door, provide 32 in. min. cl. opening.	\$6,000	\$0	NA	
845	Woods Hall	047	1130	Academic	Class	Install door lever or other accessible handle.	\$3,000	\$0	NA	
846	Woods Hall	047	1131	Academic	Class	Install door lever or other accessible handle.	\$3,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
847	Woods Hall	047	0124C	Academic	Class lab	Install door lever or other accessible handle.	\$3,000	\$0	NA	
848	Woods Hall	047	Next 0110	Academic	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
849	Woods Hall	047	0104 / 1102 0110 / 0100	Academic	Classroom & Drinking Fountains	Replace classroom doors 0104 and 1102; lower water cooler next to room 0110 and replace water cooler next to room 0100 to comply with ADA.	\$0	\$31,000	10/3/17	FY 2017 Access UMD Project
850	Woods Hall	047	0104	Academic	Seating/Assembly	Replace door to provide 32 in. min. cl. opng.	\$0	\$0	10/3/17	Project completed as part of Item # 878
851	Woods Hall	047	1114	Academic	Seating/Assembly	Replace door to provide 32 in. min. cl. opng.	\$6,000	\$0	NA	
852	Woods Hall	047	2101	Academic	Drinking Fountain	Replace exit. fountain with accessible unit.	\$6,000	\$0	NA	
853	Woods Hall	047	Across 0100	Academic	Hallway	Replace non-ADA water cooler	\$0	\$0	10/3/17	Project completed as part of Item # 878
854	Woods Hall	047	Across 1101	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
855	Woods Hall	047	Across 2101F	Academic	Hallway	Replace non-ADA water cooler	\$6,000	\$0	NA	
856	Woods Hall	047	1102	Academic	Seminar room	Widen door and change door knob with lever	\$0	\$0	10/3/17	Project completed as part of Item # 878
857	Woods Hall	047	0110	Academic	Hallway	Replace non-ADA water cooler	\$0	\$0	10/3/17	Project not in 2016 Transition Plan but completed in 2017 as part of Item # 878
858	Woods Hall	047	1114	Academic	Class	Widen door to comply with ADA	\$6,000	\$0	NA	

ADA TRANSITION PLAN UPDATE 2020

OTHER UPGRADES

[illegible]

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
1	Annapolis Hall	008	0101	Auxiliary-Residence Hall Central Offices	Manual door/opng.	Install lever or other accessible handle.	\$3,000	\$0	NA	
2	Annapolis Hall	008	0102B	Auxiliary-Residence Hall Central Offices	Manual door/opng.	Install lever or other accessible handle.	\$3,000	\$0	NA	
3	Annapolis Hall	008	1111	Auxiliary-Residence Hall Central Offices	Manual door/opng.	Install lever or other accessible handle.	\$3,000	\$0	NA	
4	Annapolis Hall	008	BLDG	Auxiliary-Residence Hall Central Offices	Bldg. Signs	Install new info. Signs w/ raised contrast. symbols.	\$16,000	\$0	NA	
5	Annapolis Hall	008	1199	Auxiliary-Residence Hall Central Offices	Service Counter	Modify portion of counter so height is 36 in. AFF.	\$4,000	\$0	NA	
6	Anne Arundel Hall	060	BLDG	Auxiliary-Residence Hall Honors and Humanities	Bldg Signage	Install new info. signs w/ raised contrasting symbols.	\$16,000	\$0	NA	
7	Anne Arundel Hall	060	BLDG	Auxiliary-Residence Hall Honors and Humanities	Bldg Signage	Install new signs adj. to interior doors, 54-60 in. AFF.	\$16,000	\$0	NA	
8	Baltimore Hall	016	BLDG	Auxiliary-Residence Hall Suites and Apartments	Bldg. Signage	Install signs with raised contrasting symbols.	\$16,000	\$0	NA	
9	Baltimore Hall	016	BLDG	Auxiliary-Residence Hall Suites and Apartments	Bldg. Signage	Install signs adj. to interior doors, 54-60 in. AFF.	\$16,000	\$0	NA	
10	Baltimore Hall	016	0104	Auxiliary-Residence Hall Suites and Apartments	Kitchen	Provide accessible' work surface.	\$5,000	\$0	NA	
11	Byrd Concessions 2	363	1104	Auxiliary-ICA	Service Counter	Modify portion of counter ht. to 36 in. AFF.	\$4,000	\$0	NA	
12	Byrd Concessions 3	364	1102	Auxiliary-ICA	Service Counter	Modify portion of counter ht. to 36 in. AFF.	\$4,000	\$0	NA	
13	Byrd Concessions 3	364	1106	Auxiliary-ICA	Service Counter	Modify portion of counter ht. to 36 in. AFF.	\$4,000	\$0	NA	
14	Cambridge Community Center	097	Next to room 1100A	Auxiliary	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
15	Centreville Hall	098	1193	Auxiliary-Residence Hall College Park Scholars	Mailboxes	Install controls which do not require tight grasp/twist.	\$4,000	\$0	NA	
16	Centreville Hall	098	BLDG	Auxiliary-Residence Hall College Park Scholars	Bldg Signage	Install new info. signs w/ raised contrasting symbols.	\$16,000	\$0	NA	
17	Centreville Hall	098	BLDG	Auxiliary-Residence Hall College Park Scholars	Bldg Signage	Install new signs adjacent to doors, 54-60 in. AFF.	\$16,000	\$0	NA	
18	Delta Chi Fraternity(#6)	131	1101	Auxiliary-Fraternity / Sorority Row Houses	Manual door/opng.	Install lever or other accessible handle.	\$4,000	\$0	NA	
19	Ellicott Hall	256	1108	Auxiliary-Residence Hall Gemstone	Manual door/opng.	Create more clearance at latch or reverse door swing.	\$4,000	\$0	NA	
20	Ellicott Hall	256	1110	Auxiliary-Residence Hall Gemstone	Manual door/opng.	Create more clearance at latch or reverse door swing.	\$4,000	\$0	NA	
21	Ellicott Hall	256	1108	Auxiliary-Residence Hall Gemstone	Manual door/opng.	Install lever or other accessible handle.	\$3,000	\$0	NA	
22	Ellicott Hall	256	BLDG	Auxiliary-Residence Hall Gemstone	Bldg. Signage	Install new info. signs w/raised contrast. Symbols.	\$16,000	\$0	NA	
23	Ellicott Hall	256	BLDG	Auxiliary-Residence Hall Gemstone	Bldg. Signage	Install new signs adj. to doors 54 - 60 in. AFF.	\$16,000	\$0	NA	
24	Ellicott Hall	256	1110	Auxiliary-Residence Hall Gemstone	Manual door/opng.	Replace door to provide min. 32 in. cl. opng.	\$6,000	\$0	NA	
25	Ellicott Hall	256	1 108	Auxiliary-Residence Hall Gemstone	Manual door/opng.	Replace door to provide min. 32 in. cl. opng.	\$6,000	\$0	NA	
26	Ellicott Hall	256	1192	Auxiliary-Residence Hall Gemstone	Drinking Fountain	Replace existing fountain with accessible unit.	\$6,000	\$0	NA	
27	House 1 (Kappa Alpha Fraternity)	126	EE0105	Auxiliary-Fraternity / Sorority Row Houses	Manual door/opng.	Install access. dr. w/ lever or other access. hdw.	\$13,000	\$0	NA	
28	House 1 (Kappa Alpha Fraternity)	126	1106	Auxiliary-Fraternity / Sorority Row Houses	Manual door/opng.	Install lever or other accessible handle.	\$3,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
29	House 1 (Kappa Alpha Fraternity)	126	BLDG	Auxiliary-Fraternity / Sorority Row Houses	Bldg. Signs	Install new info. signs w/ raised contrast. symbols.	\$16,000	\$0	NA	
30	House 1 (Kappa Alpha Fraternity)	126	BLDG	Auxiliary-Fraternity / Sorority Row Houses	Bldg. Signs	Install new signs adj. to interior doors 54 - 60 in. AFF.	\$16,000	\$0	NA	
31	House 1 (Kappa Alpha Fraternity)	126	1106	Auxiliary-Fraternity / Sorority Row Houses	Manual door/opng.	Replace door to provide min. 32 in. cl. opng.	\$6,000	\$0	NA	
32	House 13 (Zeta Psi Fraternity)	138	EE0105	Auxiliary-Fraternity / Sorority Row Houses	Manual door/opng	Install access door w/ lever or other access. Hdw.	\$13,000	\$0	NA	
33	House 13 (Zeta Psi Fraternity)	138	1101	Auxiliary-Fraternity / Sorority Row Houses	Manual door/opng	Install lever or other accessible handle.	\$3,000	\$0	NA	
34	House 13 (Zeta Psi Fraternity)	138	1106	Auxiliary-Fraternity / Sorority Row Houses	Manual door/opng	Install lever or other accessible handle.	\$3,000	\$0	NA	
35	House 13 (Zeta Psi Fraternity)	138	BLDG	Auxiliary-Fraternity / Sorority Row Houses	Bldg. Signs	Install new info. Signs w/ raised contrast. Symbols.	\$16,000	\$0	NA	
36	House 13 (Zeta Psi Fraternity)	138	BLDG	Auxiliary-Fraternity / Sorority Row Houses	Bldg. Signs	Install new signs adj. to interior doors 54 - 60 in. AFF - above finish floor.	\$16,000	\$0	NA	
37	House 13 (Zeta Psi Fraternity)	138	1106	Auxiliary-Fraternity / Sorority Row Houses	Manual door/opng	Replace door to provide min. 32 in. cl. opng.	\$6,000	\$0	NA	
38	House 14 (Zeta Beta Tau Fraternity)	139	WE0105	Auxiliary-Fraternity / Sorority Row Houses	Manual door/opng	Install access. dr. w/ lever or other access. hdw.	\$13,000	\$0	NA	
39	House 14 (Zeta Beta Tau Fraternity)	139	BLDG	Auxiliary-Fraternity / Sorority Row Houses	Bldg. Signs	Install new info. signs w/ raised contrast. symbols.	\$16,000	\$0	NA	
40	House 14 (Zeta Beta Tau Fraternity)	139	BLDG	Auxiliary-Fraternity / Sorority Row Houses	Bldg. Signs	Install new signs adj. to interior doors 54 - 60 in. AFF.	\$16,000	\$0	NA	
41	House 2 (Pi Kappa Alpha Fraternity)	127	BLDG	Auxiliary-Fraternity / Sorority Row Houses	Bldg. Signs	Install new info. signs w/ raised contrast. symbols.	\$16,000	\$0	NA	
42	House 2 (Pi Kappa Alpha Fraternity)	127	BLDG	Auxiliary-Fraternity / Sorority Row Houses	Bldg. Signs	Install new signs adj. to interior doors 54 - 60 in. AFF.	\$16,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
43	House 2 (Pi Kappa Alpha Fraternity)	127	1101	Auxiliary-Fraternity / Sorority Row Houses	Manual door/opng.	Replace door to provide min. 32 in. cl. opng.	\$0	\$0	00/00/16	Completed 2016
44	House 3 (Tau Kappa Epsilon Fraternity)	128	0103A	Auxiliary-Fraternity / Sorority Row Houses	Manual door/opng.	Install lever or other accessible handle.	\$4,000	\$0	NA	
45	House 3 (Tau Kappa Epsilon Fraternity)	128	1103	Auxiliary-Fraternity / Sorority Row Houses	Manual door/opng.	Install lever or other accessible handle.	\$3,000	\$0	NA	
46	House 3 (Tau Kappa Epsilon Fraternity)	128	BLDG	Auxiliary-Fraternity / Sorority Row Houses	Bldg. Signs	Install new info. Signs w/ raised contrast. Symbols.	\$16,000	\$0	NA	
47	House 3 (Tau Kappa Epsilon Fraternity)	128	BLDG	Auxiliary-Fraternity / Sorority Row Houses	Bldg. Signs	Install new signs adj. to interior doors 54 - 60 in. AFF.	\$16,000	\$0	NA	
48	House 3 (Tau Kappa Epsilon Fraternity)	128	0103A	Auxiliary-Fraternity / Sorority Row Houses	Manual door/opng.	Replace door to provide min. 32 in. cl. opng.	\$6,000	\$0	NA	
49	House 3 (Tau Kappa Epsilon Fraternity)	128	1101	Auxiliary-Fraternity / Sorority Row Houses	Manual door/opng.	Replace door to provide min. 32 in. cl. opng.	\$0	\$0	00/00/16	Completed 2016
50	House 3 (Tau Kappa Epsilon Fraternity)	128	1103	Auxiliary-Fraternity / Sorority Row Houses	Manual door/opng.	Replace door to provide min. 32 in. cl. opng.	\$6,000	\$0	NA	
51	House 4 (Alpha Epsilon Pi Fraternity)	129	1101	Auxiliary-Fraternity / Sorority Row Houses	Manual door/opng.	Install lever or other accessible handle.	\$3,000	\$0	NA	
52	House 4 (Alpha Epsilon Pi Fraternity)	129	1103	Auxiliary-Fraternity / Sorority Row Houses	Manual door/opng.	Install lever or other accessible handle.	\$3,000	\$0	NA	
53	House 4 (Alpha Epsilon Pi Fraternity)	129	BLDG	Auxiliary-Fraternity / Sorority Row Houses	Bldg. Signs	Install new info. signs w/ raised contrast. symbols.	\$16,000	\$0	NA	
54	House 4 (Alpha Epsilon Pi Fraternity)	129	BLDG	Auxiliary-Fraternity / Sorority Row Houses	Bldg. Signs	Install new signs adj. to interior doors 54 - 60 in. AFF.	\$16,000	\$0	NA	
55	House 4 (Alpha Epsilon Pi Fraternity)	129	1103	Auxiliary-Fraternity / Sorority Row Houses	Manual door/opng.	Replace door to provide min. 32 in. cl. opng.	\$6,000	\$0	NA	
56	House 5 (Phi Kappa Tau Fraternity)	130	1101	Auxiliary-Fraternity / Sorority Row Houses	Manual door/opng.	Install lever or other accessible handle.	\$3,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
57	House 5 (Phi Kappa Tau Fraternity)	130	1103	Auxiliary-Fraternity / Sorority Row Houses	Manual door/opng.	Install lever or other accessible handle.	\$3,000	\$0	NA	
58	House 5 (Phi Kappa Tau Fraternity)	130	BLDG	Auxiliary-Fraternity / Sorority Row Houses	Bldg. Signs	Install new info. signs w/ raised contrast. symbols.	\$16,000	\$0	NA	
59	House 5 (Phi Kappa Tau Fraternity)	130	BLDG	Auxiliary-Fraternity / Sorority Row Houses	Bldg. Signs	Install new signs adj. to interior doors 54 - 60 in. AFF.	\$16,000	\$0	NA	
60	House 5 (Phi Kappa Tau Fraternity)	130	1101	Auxiliary-Fraternity / Sorority Row Houses	Manual door/opng.	Replace door to provide min. 32 in. cl. opng.	\$6,000	\$0	NA	
61	House 5 (Phi Kappa Tau Fraternity)	130	1103	Auxiliary-Fraternity / Sorority Row Houses	Manual door/opng.	Replace door to provide min. 32 in. cl. opng.	\$6,000	\$0	NA	
62	House 6 (Delta Chi Fraternity)	131	1103	Auxiliary-Fraternity / Sorority Row Houses	Manual door/opng.	Install lever or other accessible handle.	\$3,000	\$0	NA	
63	House 6 (Delta Chi Fraternity)	131	BLDG	Auxiliary-Fraternity / Sorority Row Houses	Bldg. Signs	Install new info. signs w/ raised contrast. symbols.	\$16,000	\$0	NA	
64	House 6 (Delta Chi Fraternity)	131	BLDG	Auxiliary-Fraternity / Sorority Row Houses	Bldg. Signs	Install new signs adj. to interior doors 54 - 60 in. AFF.	\$16,000	\$0	NA	
65	House 6 (Delta Chi Fraternity)	131	1101	Auxiliary-Fraternity / Sorority Row Houses	Manual door/opng.	Replace door to provide min. 32 in. cl. opng.	\$6,000	\$0	NA	
66	House 6 (Delta Chi Fraternity)	131	1103	Auxiliary-Fraternity / Sorority Row Houses	Manual door/opng.	Replace door to provide min. 32 in. cl. opng.	\$6,000	\$0	NA	
67	House 7 (Lamda Chi Alpha Fraternity)	132	1101	Auxiliary-Fraternity / Sorority Row Houses	Manual door/opng.	Install lever or other accessible handle.	\$3,000	\$0	NA	
68	House 7 (Lamda Chi Alpha Fraternity)	132	1103	Auxiliary-Fraternity / Sorority Row Houses	Manual door/opng.	Install lever or other accessible handle.	\$3,000	\$0	NA	
69	House 7 (Lamda Chi Alpha Fraternity)	132	WE1198	Auxiliary-Fraternity / Sorority Row Houses	Manual door/opng.	Install lever or other accessible handle.	\$3,000	\$0	NA	
70	House 7 (Lamda Chi Alpha Fraternity)	132	BLDG	Auxiliary-Fraternity / Sorority Row Houses	Bldg. Signs	Install new info. signs w/ raised contrast. symbols.	\$16,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
71	House 7 (Lamda Chi Alpha Fraternity)	132	BLDG	Auxiliary-Fraternity / Sorority Row Houses	Bldg. Signs	Install new signs adj. to interior doors 54 - 60 in. AFF.	\$16,000	\$0	NA	
72	House 7 (Lamda Chi Alpha Fraternity)	132	1103	Auxiliary-Fraternity / Sorority Row Houses	Manual door/opng.	Replace door to provide min. 32 in. cl. opng.	\$6,000	\$0	NA	
73	LaPlata Hall	259	0103	Auxiliary-Residence Hall Coed	Fixed Work Area	Increase ht. of knee space to 27 in. min. AFF.	\$5,000	\$0	NA	
74	LaPlata Hall	259	BLDG	Auxiliary-Residence Hall Coed	Bldg. Signage	Install signs adj. to interior doors, 54-60 in. AFF.	\$16,000	\$0	NA	
75	LaPlata Hall	259	BLDG	Auxiliary-Residence Hall Coed	Bldg. Signage	Install signs with raised contrasting symbols.	\$16,000	\$0	NA	
76	Leonardtown Community Center	250	1102	Auxiliary-Central Offices	Interior	Install handrails with 1 1/2 in. dia. Handrails.	\$4,000	\$0	NA	
77	Leonardtown Community Center	250	BLDG	Auxiliary-Central Offices	Bldg. Signs	Install new info. signs w/ raised contrast. symbols.	\$16,000	\$0	NA	
78	Leonardtown Community Center	250	BLDG	Auxiliary-Central Offices	Bldg. Signs	Install new signs adj. to interior doors 54 - 60 in. AFF.	\$16,000	\$0	NA	
79	Leonardtown Office Building	201	1205M	Auxiliary-Central Offices	Manual door/opng.	Install lever or other accessible handle.	\$3,000	\$0	NA	
80	Leonardtown Office Building	201	BLDG	Auxiliary-Central Offices	Bldg. Signs	Install new info. signs w/ raised contrast. symbols.	\$16,000	\$0	NA	
81	Leonardtown Office Building	201	BLDG	Auxiliary-Central Offices	Bldg. Signs	Install new signs adj. to interior doors 54 - 60 in. AFF.	\$16,000	\$0	NA	
82	Leonardtown Office Building	201	1295	Auxiliary-Central Offices	Service Counter	Modify portion of counter so height is 36 in. AFF.	\$4,000	\$0	NA	
83	Leonardtown Office Building	201	1208	Auxiliary-Central Offices	Visual Alarms	Remount visual alarms at correct height.	\$0	\$0	00/00/16	Completed 2016
84	Leonardtown Office Building	201	1199	Auxiliary-Central Offices	Visual Alarms	Remount visual alarms at correct height.	\$0	\$0	00/00/16	Completed 2016

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
85	Leonardtown Office Building	201	1200	Auxiliary-Central Offices	Visual Alarms	Remount visual alarms at correct height.	\$0	\$0	00/00/16	Completed 2016
86	Leonardtown Office Building	201	1299	Auxiliary-Central Offices	Drinking Fountain	Replace existing fountain with accessible unit.	\$6,000	\$0	NA	
87	New Leonardtown Apt. Building	248	BLDG	Auxiliary-Apartment	Kitchen	Renovate kitchen to comply with ADA.	\$20,000	\$0	NA	New Survey 2016
88	Patuxent Building	010	Near 2102	Auxiliary	Hallway	Lower water cooler to comply with ADA	\$4,000	\$0	NA	
89	Reckord Armory	078	0101	Auxiliary	Manual door/opng.	Install door lever or other accessible handle.	\$3,000	\$0	NA	
90	Reckord Armory	078	0103	Auxiliary	Manual door/opng.	Install door lever or other accessible handle.	\$3,000	\$0	NA	
91	Reckord Armory	078	0105	Auxiliary	Manual door/opng.	Install door lever or other accessible handle.	\$3,000	\$0	NA	
92	Reckord Armory	078	0110	Auxiliary	Manual door/opng.	Install door lever or other accessible handle.	\$3,000	\$0	NA	
93	Reckord Armory	078	0117	Auxiliary	Manual door/opng.	Install door lever or other accessible handle.	\$3,000	\$0	NA	
94	Reckord Armory	078	0118	Auxiliary	Manual door/opng.	Install door lever or other accessible handle.	\$3,000	\$0	NA	
95	Reckord Armory	078	0119	Auxiliary	Manual door/opng.	Install door lever or other accessible handle.	\$3,000	\$0	NA	
96	Reckord Armory	078	0120	Auxiliary	Manual door/opng.	Install door lever or other accessible handle.	\$3,000	\$0	NA	
97	Reckord Armory	078	0121	Auxiliary	Manual door/opng.	Install door lever or other accessible handle.	\$3,000	\$0	NA	
98	Reckord Armory	078	0131-1	Auxiliary	Lecture	Widen door to comply with ADA	\$6,000	\$0	NA	

**ADA TRANSITION PLAN UPDATE 2020
OTHER UPGRADES**

Item No	Bldg Name	Bldg No	Room No	Bldg Classification	Room Use	Basic Scope of Work	Current Estimate	Project Fund / Complete \$	Complete Date	Comment
99	Reckord Armory	078	0135-1	Auxiliary	Lecture	Widen door to comply with ADA	\$6,000	\$0	NA	
100	Regents Drive Parking Garage (formerly PG 2)	202	0189	Auxiliary-Campus Parking	Circulation Spaces	Bevel change of level with a max. slope of 1:2	\$3,000	\$0	NA	
101	Regents Drive Parking Garage (formerly PG 2)	202	BLDG	Auxiliary-Campus Parking	Bldg. Signs	Install signs adj. to doors, 54-60 in. AFF.	\$16,000	\$0	NA	
102	Regents Drive Parking Garage (formerly PG 2)	202	GNORTH Telephone 1	Auxiliary-Campus Parking	Phone	Lower phone so highest operable part is <=54 in.	\$4,000	\$0	NA	
103	Varsity Sports Teamhouse	158	0112	Auxiliary-ICA	Shower Room	Remove curb at shower room entrances.	\$5,000	\$0	NA	
104	Varsity Sports Teamhouse	158	0199	Auxiliary-ICA	Drinking Fountain	Replace exit. fountain with accessible unit.	\$6,000	\$0	NA	
105	Varsity Sports Teamhouse	158	1199	Auxiliary-ICA	Drinking Fountain	Replace exit. fountain with accessible unit.	\$6,000	\$0	NA	
						SUB-TOTAL AUXILIARY	\$863,000	\$0		
						TOTAL STATE SUPPORTED AND AUXILIARY	\$4,541,000	\$283,380		