

Description:

The purpose of the section is to highlight the current applicable UMD Design Standards for both public and private restrooms and, equipment standards utilized by the maintenance and residential housing departments.

Related Sections:

- 08 27 13 Door Hardware
- 10 21 10 Restroom Requirements

Effective Date:

January 1, 2023

Applicable Standards:

- TBD

General Requirements:

Partition shall meet the interior finish requirements of NFPA 101. (Note: The required fire test is ASTM E-84, which is the same as ANSI 2.5, CAN/ULC S102M, NFPA 255, UBC 42-1, UL723; Flame Spread Max. 200 and Smoke Developed Max. 450) Partitions shall have Site Proof doors and a heat sink at bottom edges.

Standard Requirements:**Restroom Fixture Partitions**

- Partitions shall be floor mounted overhead braced solid plastic, mounted to walls using continuous wall brackets and continuous hinges. The head rail shall be a heavy-duty anti-grip design to prevent vandalism.
- Acceptable manufacturers: Comtec Industries and Rockville Partitions Incorporated.
- Final assemblies should have no excess gaps between panels.